



OIML Certificate

OIML Member State The Netherlands



Number R46/2012-A-NL1-20.01 revision 1 Project number 2439852 Page 1 of 3

Issuing authority NMi Certin B.V.

Person responsible: M. Boudewijns

Applicant and ZIV Aplicaciones y Tecnología S.L. Manufacturer Parque Tecnologico de Bizkaia, 210 Zamudio, 48170

Spain

Identification of the certified type

A measuring instrument Type: 5CTB3CBS010AS00

Characteristics See page 2 and further

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R 46-1/-2 (2012) "Active electrical energy meters"

Accuracy class

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority NMi Certin B.V., OIML Issuing Authority NL1

18 February 2021

Certification Board







This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.











OIML Certificate



Number R46/2012-A-NL1-20.01 revision 1 Project number 2439852 Page 2 of 3

The conformity was established by the results of tests and examinations provided in the associated reports:



- No. NMi-2439852-03 dated 26 June 2020 that includes 53 pages;
- No. NMi-2439852-03b dated 16 February 2021 that includes 53 pages;
- No. NMi-2439852-03c dated 16 February 2021 that includes 54 pages;
- No. NMi-2439852-04 dated 20 May 2020 that includes 16 pages;
- No. NMi-2439852-04a dated 16 February 2021 that includes 16 pages;

Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented.

Table 1 General characteristics

General characteristics		
Meter type	Static	
Connection mode (phase, wires, elements)	3p, 4w, 3e	
Direction of energy flow / registers	Two-registers, bi-directional	
Terminal arrangement	DIN	
Protective class (+)	Category 2	
Environmental application		
Ambient temperature range -40 °C to +70 °C (3k7) – tested up to +75 °C as a specific customer requirement.		
Humidity class H1		
IP Rating / environmental use	IP54	
Meter quantities		
Nominal voltage (U _{nom})	3x133/230V3x230/400V	
Nominal frequency (f _{nom})	60 Hz	
Maximum current (I _{max})	100 A	
Transitional current (I _{tr})	1 A (I _b = 10 A)	
Minimum current (I _{min})	0,5 A	
Starting current (I _{st})	0,04 A	
Meter constant	1.000 imp./kWh	
Product version		
Hardware version	2R7	
Software identification	2.9.7.	





OIML Certificate



Number R46/2012-A-NL1-20.01 revision 1 Project number 2439852 Page 3 of 3



Revision History



This revision replaces the previous versions.

Revision	Date	Change(s)
Initial	26-06-2020	Initial issue
1	18-02-2021	Editorial changes: Correction of OIML Certificate instead of OIML Certificate of Conformity









