



OIML Certificate

OIML Member StateThe Netherlands



Number R46/2012-A-NL1-20.07 Project number 2509324 Page 1 of 2

Issuing authority Person responsible:

NMi Certin B.V. M. Boudewijns



Applicant and Manufacturer

Alfanar Electrical Division Alfanar industrial city New Alkharj Road 14338 Riyadh Saudi Arabia

Identification of the certified type

A measuring instrument

Type: DTSD545-ALF

Characteristics See page 2 and further

This OIML Certificate is issued under scheme A

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):



Accuracy class B

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority NMi Certin B.V., OIML Issuing Authority NL1

3 December 2020



Certification Board





NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.









OIML Certificate



Number R46/2012-A-NL1-20.07 Project number 2509324 Page 2 of 2

The conformity was established by the results of tests and examinations provided in the associated reports:



- No. NMi-2509324-01 dated 23 November 2020 that includes 61 pages;
- No. NMi-2509324-02 dated 23 November 2020 that includes 13 pages.

Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented.

Table 1 General characteristics

| General characteristics | |
|--|--|
| Meter type | static |
| Connection mode (phase, wires, elements) | 3p, 4w, 3e |
| Direction of energy flow / registers | bi-directional; Import Active energy $(1.8.0) = +A1 + +A2 + +A3 $; Export Active energy $(2.8.0) = -A1 + -A2 + -A3 $; Absolute active energy $(15.8.0) = +A1 + +A2 + +A3 + -A1 + -A2 + -A3 $ |
| Terminal arrangement | BS |
| Protective class | Category 2 |
| Environmental application | |
| Ambient temperature range | -40 °C to +75 °C |
| Humidity class | H2 |
| IP Rating / environmental use | IP54 / indoor |
| Meter quantities | |
| Nominal voltage (U_{nom}) | 3x133/230 V and 3x230/400 V |
| Nominal frequency (f _{nom}) | 60 Hz |
| Maximum current (I _{max}) | 100 A |
| Transitional current ($I_{\rm tr}$) | 1 A (I _b = 10 A) |
| Minimum current (/ _{min}) | 0,5 A |
| Starting current (Ist) | 0,04 A |
| Meter constant | 1.000 imp./kWh |
| Product version | |
| Hardware version | 17-X100-01VS1.1 |
| Software identification | Version number: ALHWCV1-20200618 Checksum: AB66FBBE |