

OIML Member State
The Netherlands

Number R46/2012-A-NL1-21.11
Project number 2516581
Page 1 of 2

Issuing authority NMI Certin B.V.
Person responsible: M. Boudewijns

Applicant and Manufacturer
Jiangsu Linyang Energy Co. Ltd.
Linyang Road 666
Jiangsu Province 226299
Qidong
P.R. China

Identification of the certified type
A measuring instrument
Type: NW34-R08

Characteristics See next page

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R 46-1/-2 (2012) "Active electrical energy meters"

Accuracy class B

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority **NMI Certin B.V., OIML Issuing Authority NL1**
25 February 2021

Certification Board

The conformity was established by the results of tests and examinations provided in the associated report(s):

- No. NMI-2516581-01 dated 23 February 2021 that includes 59 pages;
- No. NMI-2516581-02 dated 23 February 2021 that includes 11 pages.

Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented.

Table 1 General characteristics

General characteristics	
Meter type	static
Connection mode (phase, wires, elements)	3p, 4w, 3e
Direction of energy flow / registers	bi-directional
Terminal arrangement	BS
Protective class	Category 2
Environmental application	
Ambient temperature range	-40 °C to +70 °C; tested up to +75°C as a specific customer requirement.
Humidity class	H1
IP Rating / environmental use	IP54 / Indoor
Meter quantities	
Nominal voltage (U_{nom})	3x133/230 V and 3x230/400 V
Nominal frequency (f_{nom})	60 Hz
Maximum current (I_{max})	100 A
Transitional current (I_{tr})	1 A
Minimum current (I_{min})	0,5 A
Starting current (I_{st})	0,04 A
Meter constant	1.000 imp./kWh
Product version	
Hardware version	7.825.002562v2.1
Software identification	Version number: LY1N1-2020-06-16 Checksum: 5E2C