

**OIML Member State**  
The Netherlands

Number R46/2012-A-NL1-21.12  
Project number 2516581  
Page 1 of 2

Issuing authority NMI Certin B.V.  
Person responsible: M. Boudewijns

Manufacturer M/S EnergyCare Company for Information Technology  
6481 Nahdat Al Jil – Ar Rwadah District.  
Prince Mohammed Bin Abdulaziz St. (Tahlia) -Unit.2  
Jeddah 23432  
Saudi Arabia

Identification of the certified type **A measuring instrument**  
Type: NW34-R08

Characteristics See next page

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

**R 46-1/-2 (2012) "Active electrical energy meters"**

Accuracy class B

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority **NMI Certin B.V., OIML Issuing Authority NL1**  
25 February 2021

Certification Board

The conformity was established by the results of tests and examinations provided in the associated report(s):

- No. NMI-2516581-01 dated 23 February 2021 that includes 59 pages;
- No. NMI-2516581-02 dated 23 February 2021 that includes 11 pages.

### Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented.

**Table 1 General characteristics**

<b>General characteristics</b>	
Meter type	static
Connection mode (phase, wires, elements)	3p, 4w, 3e
Direction of energy flow / registers	bi-directional
Terminal arrangement	BS
Protective class	Category 2
<b>Environmental application</b>	
Ambient temperature range	-40 °C to +70 °C; tested up to +75°C as a specific customer requirement.
Humidity class	H1
IP Rating / environmental use	IP54 / Indoor
<b>Meter quantities</b>	
Nominal voltage ( $U_{nom}$ )	3x133/230 V and 3x230/400 V
Nominal frequency ( $f_{nom}$ )	60 Hz
Maximum current ( $I_{max}$ )	100 A
Transitional current ( $I_{tr}$ )	1 A
Minimum current ( $I_{min}$ )	0,5 A
Starting current ( $I_{st}$ )	0,04 A
Meter constant	1.000 imp./kWh
<b>Product version</b>	
Hardware version	7.825.002562v2.1
Software identification	Version number: LY1N1-2020-06-16 Checksum: 5E2C