

OIML Certificate

OIML Member State The Netherlands

Number R46/2012-A-NL1-21.19 Project number 2630085 Page 1 of 2

Issuing authority Person responsible:	NMi Certin B.V. M.Ph.D. Schmidt
Applicant and Manufacturer	Basic Electronics Company Limited, CR#2050129466 Al Hassan Al Basri Street, Al Khaldiah Al Janobiah District, Dammam, Kingdom of Saudi Arabia
Identification of the certified type	
Characteristics	See page 2

This OIML Certificate is issued under scheme A

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):



R 46-1/-2 (2012) "Active electrical energy meters"

Accuracy class



This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial guotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority

NMi Certin B.V., OIML Issuing Authority NL1 18 November 2021



NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

Certification Board

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.







OIML Certificate



Number R46/2012-A-NL1-21.19 Project number 2630085 Page 2 of 2

The conformity was established by the results of tests and examinations provided in the associated report(s):

- No. NMi-2630085-01 dated 16 November 2021 that includes 54 pages;
- No. NMi-2630085-02 dated 16 November 2021 that includes 17 pages.

Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented. The construction of the measuring instrument is recorded in the Documentation folder no. 2630085-1.

Table 1 General characteristics

General characteristics	
Meter type	static
Connection mode (phase, wires, elements)	3р, 4w, 3е
Direction of energy flow / registers	bi-directional
Terminal arrangement	DIN
Protective class 🔒	2
Environmental application	
Ambient temperature range	-40 °C to +70°C – tested up to +75°C as a specific customer requirement.
Humidity class	H1
IP Rating / environmental use	IP54 / Indoor
Meter quantities	
Nominal voltage (Unom)	3x 133/230 V and 3x 230/400 V
Nominal frequency (f _{nom})	60 Hz
Maximum current (I _{max})	160 A
Transitional current (I _{tr})	2 A
Minimum current (I _{min})	0,5 A
Starting current (I _{st})	0,08 A
Meter constant	1000 imp./ kWh
Product version	
Hardware version	CT3T013_P1_V01.03 (Main PCB), CT3T013_P2_V01.02 (Power PCB)
Software identification	Version number: P0015 Checksum: 8ED2DC0D