



OIML Certificate

OIML Member State

The Netherlands



Number R46/2012-A-NL1-22.01 Project number 2557963 Page 1 of 2

Issuing authority Person responsible: NMi Certin B.V. M.Ph.D. Schmidt



Manufacturer

Globaltronics Address

Lot 120, CPC Industrial Park, Northen extension area

12573/48, 6 October City, Giza

Country

Egypt

Identification of the

certified type

An active electrical energy meter

Type: GE300-SS

Characteristics

See page 2 and further

This OIML Certificate is issued under scheme A

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R 46-1/-2 (2012) "Active electrical energy meters"

Accuracy class



This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report is not permitted, although either may be reproduced in full.

Issuing Authority NMi Certin B.V., OIML Issuing Authority NL1

8 March 2022

Certification Board







NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T+31 88 636 2332 certin@nmi.nl www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.









OIML Certificate



Number R46/2012-A-NL1-22.01 Project number 2557963 Page 2 of 2

The conformity was established by the results of tests and examinations provided in the associated report:



- No. NMi-2557963-01 dated 8 March 2022 that includes 56 pages.

Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented. The construction of the measuring instrument is recorded in the Documentation folder no. R46-2012-A-NL1-22.01-1.

Table 1 General characteristics

General characteristics	
Meter type	static
Connection mode (phase, wires, elements)	3p, 4w, 3e
Direction of energy flow / registers	One-register, bi-directional.
Terminal arrangement	DIN
Protective class	Category 2
Environmental application	
Ambient temperature range	-40 °C to +70°C and 75 °C (3k7)
Humidity class	Н3
IP Rating / environmental use	IP54 / outdoor
Meter quantities	
Nominal voltage (U _{nom})	3x230/400 V
Nominal frequency (f _{nom})	60 Hz
Maximum current (I _{max})	100 A
Transitional current (Itr)	1 A (I _b = 10 A)
Minimum current (I _{min})	0,25 A
Starting current (I _{st})	0,04 A
Meter constant	1.000 imp./kWh
Product version	
Hardware version	GE300-S_V1.0_03-2020
Software identification	Version number: KSA_GE300-SS_V1.0-03- 20_V1.0.0_04-2021 Checksum: 70B48E8B