

# Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

Member State of OIML  
Germany



OIML Certificate No.  
**R60/2000-DE1-12.01**  
Revision 1

## OIML CERTIFICATE OF CONFORMITY

### Issuing Authority

Name: Physikalisch-Technische Bundesanstalt  
Address: Bundesallee 100, 38116 Braunschweig  
Person responsible: Dr. Oliver Mack

### Applicant

Name: Sartorius Mechatronics T&H GmbH  
Address: Meiendorfer Str. 205, 22145 Hamburg

Manufacturer of the certified type is the applicant.

### Identification of the certified type

Digital strain gauge compressions load cell  
Type: PR 6204

Further characteristics see page 2 and 3

This Certificate attests the conformity of the above identified type (represented by the sample or samples identified in the associated Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

**R60**, edition 2000  
for accuracy classes D1, C3, C6

This Certificate relates only to the metrological and technical characteristics of the type of instrument covered by the relevant OIML Recommendation identified above.

This Certificate does not bestow any form of legal international approval.

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
**R60/2000-DE1-12.01**  
**Revision 1**

The conformity was established by the results of tests and examinations provided in the associated Test Reports

No. 1.12-4051023-3 including 20 pages (SN: 396395 / 2t / C3 / Y10000 )  
No. 1.12-4051023-4 including 32 pages (SN: 383982 / 3t / C3 / Y14000 / digital tests )  
No. 1.12-4051023-5 including 33 pages (SN: 285218 / 12.5t / C6 / Y20000 / digital tests /  $p_{LC} = 0.8$  )  
No. 1.12-4051023-6 including 20 pages (SN: 396396 / 0.5t / D1 / Y2500 / Temp. -25°C to 55°C)  
No. 1.12-4051023-7 including 19 pages (SN: 396404 / 1t / D1 / Y5000 / Temp. -25°C to 55°C )  
No. 1.12-4051023-8 including 18 pages (SN: 396395 / 2t / D1 / Y5000 / Temp. -25°C to 55°C )  
No. 1.12-4051023-9 including 18 pages (SN: 285218 / 12.5t / D1 / Y5000 / Temp. -25°C to 55°C )

An OIML Basic Certificate has been issued, because the Test Reports mentioned above are based on measurements performed at the laboratories of the applicant.

## The Issuing Authority

Dr. O. Mack  
Head of Working group

22.02.2013

## The OIML Member

Dr. R. Schwartz  
Head of Division

22.02.2013

The load cells of the series PR 6204 are compact compression load cells for self-centering pendulum applications. The strain gauge application is hermetically sealed; the deep-drawn and micro plasma welded housing is made of stainless steel and filled with inert gas. The analog signal of the strain gauge bridge is amplified, scaled and filtered by the integrated module. The load cell is equipped with an interface RS485.

The load can only be used in combination with a data processing device of manufacturer Sartorius.

The metrological characteristics for application in approved weighing instruments are listed in table 1.

Table 1: Essential data

Accuracy class		D1 <sup>1)</sup>	C3	C6
Maximum number of load cell intervals $n_{LC}$		1000	3000	6000
Maximum capacity $E_{max}$	t	0.5 / 1 / 2 / 3 / 5 / 10 / 12.5 / 20 / 25 / 30 / 50 / 60	2 / 3 / 5 / 10 / 12.5 / 20 / 25 / 30 / 50 / 60	12.5 / 20 / 25 / 30 / 50 / 60
Minimum load cell verification interval $v_{min} = (E_{max} / Y)$		$E_{max} / 5000$ <sup>2)</sup>	$E_{max} / 14000$ <sup>3)</sup>	$E_{max} / 20000$
Minimum dead load output return $DR = (\frac{1}{2} \cdot E_{max} / Z)$		$\frac{1}{2} \cdot E_{max} / 1000$	$\frac{1}{2} \cdot E_{max} / 3000$	$\frac{1}{2} \cdot E_{max} / 8000$

Dead load:  $0\% \cdot E_{max}$

Safe overload:  $200\% \cdot E_{max}$  for  $E_{max} < 25$  t;  $150\% \cdot E_{max}$  for  $E_{max} \geq 25$  t

Fraction:  $p_{LC} = 0.7$  for D1 and C3;  $p_{LC} = 0.8$  for C6

<sup>1)</sup> Extended temperature range:  $-25^{\circ}\text{C}$  to  $55^{\circ}\text{C}$

<sup>2)</sup> For  $E_{max} = 0.5$  t:  $v_{min} = E_{max} / 2500$

<sup>3)</sup> For  $E_{max} = 2$  t:  $v_{min} = E_{max} / 10000$

**Important note:** Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate is issued, partial quotation of the Certificate and of the associated Test Report(s) is not permitted, although either may be reproduced in full.