



OIML Certificate of Conformity

OIML Member State
The Netherlands

Number R60/2000-NL1-15.10
Project number 15200282
Page 1 of 2

Issuing authority	NMi Certin B.V. Person responsible: C. Oosterman
Applicant and Manufacturer	HOPE TECHNOLOGIC (XIAMEN) Co.,Ltd 3fl Heng Sheng Building Yue Hua E. rd. Hu-Li Xiamen 361006 P.R. China
Identification of the certified type	A single point load cell , with strain gauges. Type : NA... and NA... M
Characteristics	See next page

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

OIML R60 - Edition 2000 (E) for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority **NMi Certin B.V., OIML Issuing Authority NL1**
3 July 2015


C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
the Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMI (see www.nmi.nl).





OIML Certificate of Conformity

OIML Member State
The Netherlands

Number R60/2000-NL1-15.10
Project number 15200282
Page 2 of 2

The conformity was established by the results of tests and examinations provided in the associated OIML Test Report(s):

- No. R60/2000-NL1-07.18 dated 22 November 2007 that includes 40 pages;
- No. NMI-15200282-01 dated 29 June 2015 that includes 51 pages;
- No. NMI-15200282-02 dated 29 June 2015 that includes 46 pages;
- No. NMI-15200282-03 dated 29 June 2015 that includes 46 pages.

Characteristics of the load cell:

Maximum capacity (E_{max})	3 kg up to and including 15 kg	20 kg up to and including 100 kg	200 kg up to and including 1500 kg
Minimum dead load	0 kg		
Accuracy Class	C		
Rated Output	2 mV/V		
Maximum number of load cell intervals (n)	3000	5000	3000
Ratio of minimum LC Verification interval $Y = E_{max} / V_{min}$	7900	10000	7000
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$	9500	5000	5500
Input impedance	410 $\Omega \pm 15 \Omega$		
Temperature range	-10 °C / + 40 °C		
Fraction p_{LC}	0,7		
Humidity Class	CH		
Safe overload	150 % of E_{max}		
Output impedance	350 $\Omega \pm 5 \Omega$		
Recommended excitation	5 - 12 V AC / DC		
Excitation maximum	15 V AC / DC		
Transducer material	Aluminium		
Atmospheric protection	Silicone rubber		

The characteristics for n_{max} and Y can be reduced separately. Z is proportional or equal to n_{max} .

Each produced load cell is provided with an accompanying document with information about its characteristics.

The above identified Type except for the capacity range 20kg up to and including 100 kg (represented by the sample(s) identified in the OIML Test Report) have been found to comply with the additional national requirements established by the United States of America (NIST Handbook 44 and NCWM Publication 14), included in the MAA Declaration of Mutual Confidence:

- R 60 DoMC-01 rev.0, Additional requirements from the United States;
- R 60 DoMC-02 rev.0, Additional requirements from the United States.