



Member State
Denmark

OIML Certificate N°
R76/2006-DK3-14.01

OIML CERTIFICATE OF CONFORMITY

Issuing authority

Name: **DELTA**
Address: Venlighedsvej 4
2970 Hørsholm
Denmark

Person responsible: J. Hovgård Jensen

Applicant

Name: **Tscale Electronics Mfg. (Kunshan) Co., Ltd.**
Address: No. 99 Shunchang Road,
Zhoushi, Kunshan, Jiangsu
CHINA

Manufacturer

of the certified pattern: **Tscale Electronics Mfg. (Kunshan) Co., Ltd.**

Identification

of the certified pattern: **Non-automatic weighing instrument**
Type: V7-nn / B7-nn / C7-nn / NS7-nn / S7-nn / T7-nn /
C8-nn / U8-nn,
where nn is 20, 40 or 50
Further characteristics are set out on page 2.

This certificate attests the conformity of the above mentioned pattern (represented by the samples identified in the associated test report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R76
edition 2006
for accuracy class III

This certificate relates only to the metrological and technical characteristics of the pattern of the instrument concerned, as covered by the relevant OIML International Recommendation.

This certificate does not bestow any form of legal international approval.

Page 1. This certificate includes 2 pages



OIML Certificate N° R76/2006-DK3-14.01

The conformity was established by tests described in the associated test reports from DELTA, DK, No. DANAK-1912989, dated 13-09-2013 that includes 127 pages

The issuing authority: **DELTA, OIML Issuing Authority DK3**
15 January 2014


J. Hovgård Jensen
Certification Officer

Characteristics

Accuracy class		III
Weighing range		Single-interval
Number of intervals	Max / e	≤ 3000
Subtractive tare	T	≤ -Max
Minimum input voltage	ΔU_{\min}	1.5 μ V per VSI
Excitation voltage	U_{exc}	5 VDC
Load cell impedance	Min. / Max.	87 ohm / 1200 ohm
Load cell connecting system		4-wire or 6-wire, shielded
Module fractional factor	p_i	0.5 for the indicator
Interface		Protective, according to paragraph 5.3.6
Connected load cells		Shall comply with R60
Supply voltage		100-240 VAC using ext. AC/DC adapter, 12 VDC, optional 6 V internal battery
Temperature range for the indicator		0 °C / +40 °C
Software identification:		Weighing software: 1.10 Application software: A1.xx
Max cable length to junction box		580 m/mm ²

Important note:

Apart from the mention of the certificate's reference number and the name of the OIML Member State in which the certificate was issued, partial quotation of the certificate or of the associated test report is not permitted, though they may be reproduced in full.