



National Metrology Institute of Japan

## T e s t r e p o r t

Test report number : R117/1995-JP1-2013-02

Specimen : Fuel dispenser for motor vehicles

Issued by : National Metrology Institute of Japan

Test address : National Metrology Institute of Japan  
1-1-1 Umezono, Tsukuba 305-8563, Japan

Test specifications : OIML R118 (edition 1995)

Application : TOMINAGA MFG.CO.

Manufacturer : TOMINAGA MFG.CO.

Signature : Hiroaki Morinaka

Hiroaki MORINAKA  
Chief of Legal Flow Metrology Section Fluid Flow Division

Date of issue : : 26 August 2013

## GENERAL INFORMATION CONCERNING THE PATTERN

Applicant No. :	<u>25-001</u>
Applicant :	<u>TOMINAGA MFG.CO.</u>
Manufacturer :	<u>TOMINAGA MFG.CO.</u>
<b>Measuring system</b>	
Pattern designation:	<u>HAXC6463</u>
Low flow rate:	<u>30 litres/min</u>
High flow rate:	<u>70 litres/min</u>
Maximum flow rate:	<u>70 litres/min</u>
Minimum flow rate:	<u>3 litres/min</u>
Minimum measured quantity:	<u>2 litres</u>
Maximum pressure:	<u>0.31 MPa</u>
Minimum pressure:	<u>0.12 MPa</u>
Maximum unit price (number of digits):	<u>5 digits</u>
Maximum price to pay (number of digits):	<u>6 digits</u>
Temperature range:	<u>- 20 °C to + 40 °C</u>
Liquids (or viscosity range):	<u>Gasoline / Diesel / Kerosene</u>
Mains power:	
Voltage:	<u>AC100-240V</u>
Frequency:	<u>50Hz , 60Hz</u>
Type of display:	<u>LCD</u>
<b>Meter</b>	
Manufacturer :	<u>TOMINAGA MFG.CO.</u>
Pattern designation:	<u>FM1</u>
Pattern approval mark:	
Maximum flow rate:	<u>70 litres/min</u>
Minimum flow rate:	<u>3 litres/min</u>
Minimum measured quantity:	<u>2 litres</u>
<b>Gas elimination device (integral with pump)</b>	
Manufacturer :	<u>TOMINAGA MFG.CO.</u>
Pattern designation:	<u>PA6</u>
Volume:	
Maximum flow rate:	<u>70 litres/min</u>
Minimum flow rate:	<u>3 litres/min</u>
Maximum pressure:	<u>0.31 MPa</u>
Minimum pressure:	<u>0.12 MPa</u>
<b>Measuring transducer</b>	
Manufacturer:	<u>TATSUNO Corporation</u>
Pattern designation:	<u>ZE-1945</u>
Number of pulses per revolution	<u>50 pulses</u>

**Calculator**

Manufacturer :	TOMINAGA MFG.CO.
Pattern designation:	PB-0451 , PB-0452
Mains power:	
Voltage:	AC100-240V
Frequency:	50Hz , 60 Hz

**Hose**

Manufacturer:	TOGAWA RUBEER CO., LTD.
Pattern designation:	3N5/8, 3N3/4

**Nozzle**

Manufacturer:	TOMINAGA MFG.CO.
Pattern designation:	TNAS-520C, TNAS-520R, TNASD-520C, TNASD-520R TNAS-525C, TNAS-525R, TNASD-525C, TNASD-525R TNASW-525C, TNASW-525R 10-3/4, 10-1

**Break valve**

Manufacturer:	TOMINAGA MFG.CO.
Pattern designation:	Double Poppet Valve:2
Manufacturer:	
Pattern designation:	

## CHECK LIST

**Notes:** 1 Item numbering refers to international Recommendation OIML R117 , Edition 1995(E)

2 For each test , the check list has been completed according to the example:

+	-
×	
	×
/	/

if the instrument has passed the test

if the instrument has failed

if the test is not applicable

§(R117)	Requirement	+	-	Remarks
<b>GENERAL PROVISIONS</b>				
2.19.1	<b>MARKINGS</b>			
	Markings applied legibly and indelibly on the dial of the indicating device or on a special data plate:	×		
	· Pattern approval sign	/	/	
	· Manufacturers identification mark or trade mark designation	×		TOMINAGA MFG.CO.
	· Serial number	×		
	· Year of manufacture	×		
	· Minimum measured quantity (MMQ)	×		2L
	· Maximum flowrate (Qmax)	×		40, 60, 65, 70 L/min
	· Minimum flowrate (Qmin)	×		3L/min
	· Maximum pressure	×		0.33 MPa
	· Minimum pressure	×		0.12 MPa
	· Liquids	×		
	· Temperature range	×		Class C
2.9.1	<b>INDICATIONS</b>			
2.9.5	Unit of volume: litre( 1 or L)	×		
	Difference between volume indications of more than one indicating device $\leq 1$ scale interval of indicating device with the greatest scale	×		
2.16.1	<b>BRANCHES AND BY-PASSES</b>			
	Branches downstream of meter: diversion to any receiving receptacle(s) other than that intended is	×		
2.20.1	<b>SEALING DEVICES AND STAMPING PLATE</b>			
	Seals easily accessible and preventing access to components which allow alteration of the measurement result without damaging the seals including the stamping plate	×		
<b>REQUIREMENTS FOR ANCILLARY DEVICES</b>				
	<b>ADJUSTMENT DEVICE</b>			
3.1.4	Difference between consecutive values of the ratio $\leq 0.001$	×		
	Adjustment by means of a by-pass of the meter impossible	×		
3.2.1.1	Reading precise, easy and unambiguous by simple juxtaposition	×		
	Decimal sign clear	×		
	<b>VOLUME INDICATING DEVICE</b>			
3.2.1.2	Scale interval: $1 \times 10^n$ , $2 \times 10^n$ or $5 \times 10^n$	×		
3.2.1.4	Continuous indicating device: MSVD $\geq$ volume corresponding to 2 mm on the scale, and $\geq 1/5$ of scale interval	/	/	

<b>§(R117)</b>	<b>Requirement</b>	<b>+</b>	<b>-</b>	<b>Remarks</b>
<b>VOLUME INDICATING DEVICE</b>				
3.2.1.4	Discontinuous indicating device: MSVD $\geq$ 2 scale intervals	×		MSVD $=2 \times 2 \times 0.5 \times 1/100$ $=0.02$ MSVD $\geq$ 0.002
3.2.2.1	Element with graduation entirely visible (except element corresponding to the maximum range of the indicator): one revolution corresponds to 10n authorized units of volume	/	/	
3.2.2.2	Element with graduation entirely visible: one revolution of the element corresponds to scale interval of the following element	/	/	
3.2.2.3	Element with only part of graduation visible through a window (except first element) : discontinuous movement	/	/	
3.2.2.4	Advance by one figure of following element when preceding element passes from 9 to 0	/	/	
3.2.2.5	Dimension of the window for the first element $\geq 1.5 \times$ (distance between two graduated scale marks)	/	/	
3.2.2.6	Width of scale mark $\leq 1/4$ of scale spacing	/	/	
	Apparent scale spacing $\geq 2$ mm	/	/	
3.2.3	Electronic indicating device continuous display of volume during the period of measurement	×		
3.2.4.2	Zero setting device not permitting any alteration of the result	×		
3.2.4.3	No indication of any result during zeroing	×		
3.2.4.4	Continuous indicating device: residual indication after zeroing $\leq 1/2$ of MSVD	/	/	
3.2.4.5	Discontinuous indicating device: indicate zero without any ambiguity	×		
<b>PRICE INDICATING DEVICE</b>				
3.3.2	Unit price adjustable and indicated before measurement by a displaying device; valid for the whole transaction	×		
	Elapsed time between changing unit price and before next measurement starts: at least five seconds	×		
3.3.3	(mutatis mutandis)			
(3.2.1.1)	Reading precise, easy and unambiguous	×		
(3.2.2.4)	Advance by figure of following element when preceding element passes from 9 to 0	/	/	
(3.2.4.2)	Zero setting device not permitting any alteration of the result	×		
(3.2.4.3)	No indication of any result during zeroing	×		
<b>PRICE INDICATING DEVICE</b>				
3.3.4	Monetary unit or its symbol in the immediate vicinity of the indicating device.	×		
3.3.5	Zero setting devices of price indication and volume indication: zeroing of either of them automatically involves zeroing the other	×		
3.3.6	Continuous indicating device: MSPD $\geq$ price corresponding to 2 mm on the scale, and $\geq$ price corresponding to 1/5 of scale interval	/	/	
	Discontinuous indicating device: MSPD $\geq$ price corresponding to 2 scale intervals	×		MSPD $=2 \times 2 \times 0.5 \times 1/100$ $=0.02$ MSPD $\geq$ 0.002
3.3.8	Continuous indicating device: residual indication after zeroing $\leq 1/2$ of MSPD	/	/	
3.3.9	Discontinuous indicating device: indicate zero without any ambiguity	×		

<b>§(R117)</b>	<b>Requirement</b>	<b>+</b>	<b>-</b>	<b>Remarks</b>
	<b>PRINTING DEVICE</b>			
3.4.1	Printed volume scale interval: $1 \times 10^n, 2 \times 10^n$ or $5 \times 10^n$ and $\leq$ MSVD, and smallest scale interval of indicating device	×		
3.4.2	Unit of volume: litre (l or L) Figures, unit or symbol, (and decimal sign) of volume printed on	×		
3.4.3	If connected to more than one measuring system: print identification	×		
3.4.4	If repetition of printing: copies are marked clearly	×		
3.4.5	If volume determination by difference between two printed values: withdrawal of ticket during measurement impossible	/	/	
3.4.6	Zeroing device of printer and volume indicator: zeroing of one of them involves zeroing the other	/	/	
3.4.7	Figures monetary unit or symbol, (and decimal sign) of price printed on ticket	×		
3.4.8	Printed price scale interval: $1 \times 10^n, 2 \times 10^n$ or $5 \times 10^n$ monetary unit, and $\leq$ MSPD	×		
	<b>PRE-SETTING DEVICE</b>			
3.6.2	If several independent controls: scale interval corresponding to one control equals range of control of the next lower order	×		
3.6.4	Figures of pre-setting display clearly distinguishable from those of volume indicator	×		
3.6.5	Indication of the selected quantity during delivery remains unaltered or returns progressively to zero	×		
3.6.6	Difference between pre-set volume and indicated volume $\leq$ MSVD	×		
3.6.7	Unit of pre-set volume same as that of volume indicator	×		
3.6.8	Marking of unit of volume or its symbol on pre-setting mechanism	×		
3.6.8	Scale interval of pre-setting device $\geq$ scale interval of volume indicator	×		
3.6.10	(mutatis mutandis for price pre-setting devices)			
(3.6.2)	If several independent controls: scale interval corresponding to one control equals range of control of the next lower order	×		
(3.6.4)	Figures of pre-setting display clearly distinguishable from those of price indicator	×		
(3.6.5)	Indication of the selected quantity during delivery remains unaltered or returns progressively to zero	×		
(3.6.6)	Difference between pre-set price and indicated price $\leq$ MSPD	×		
(3.6.7)	Unit of pre-set price same as that of price indicator	×		
(3.6.8)	Marking of monetary unit or its symbol on pre-setting mechanism	×		
(3.6.8)	Scale interval of pre-setting device $\geq$ scale interval of price	×		
<b>SPECIFIC REQUIREMENTS FOR MEASURING SYSTEMS EQUIPPED WITH ELECTRONIC DEVICES</b>				
	<b>CHECKING FACILITIES FOR MEASUREMENT TRANSDUCER</b>			
4.3.2.1	When each pulse represents elementary volume, at least security level B defined by ISO 6551	×		
	Checking facilities of type P	×		
	Checking interval not exceeding the duration of measurement of amount of liquid equal to MSVD	×		
	Possibility of testing the operation of checking facilities during pattern approval and verification	×		

<b>S(R117)</b>	<b>Requirement</b>	<b>+</b>	<b>-</b>	<b>Remarks</b>
<b>CHECKING FACILITIES FOR CALCULATION</b>				
4.3.3.1	Checking facilities for operation of type P or I	×		
	Checking interval for type I at each delivery	×		
4.3.3.2	Checking facilities for validity of calculation of type P	×		
	Existence of a means for controlling continuity	×		
<b>CHECKING FACILITIES FOR INDICATING DEVICE</b>				
4.3.4.1	Checking facilities for operation of type P or I if indication can be reconstituted	×		
4.3.4.2	Tests "all displaying" - "all blanking" - "all zeros" test with duration of each sequence $\geq 0.75\text{s}$	×		
4.3.4.3	Possibility of testing the operation of checking facilities during verification	×		
<b>CHECKING FACILITIES FOR PRINTING DEVICE</b>				
4.3.5	Checking facilities of type I or P Checking includes presence of paper and of electronic control circuits Possibility of testing the operation of checking facilities during pattern approval and verification Where action is a warning: given on or by the printing device	×		
<b>OTHER SPECIFIC REQUIREMENTS FOR FUEL DISPENSERS</b>				
5.1.1	Ratio between maximum flowrate and minimum flowrate: at least ten	×		
5.1.2	If integral pump: gas elimination device placed immediately upstream of the meter inlet	×		
5.1.3	If no integral pump: check that the installation schemes provide for necessary securities	×		
5.1.4	Device for resetting the volume indicator to zero present Height of figures of volume indicator with zero setting device $\geq 10\text{ mm}$	×		
	If price indicator, presence of zero setting device	×		
5.1.5	Next delivery inhibited until nozzle(s) replaced and indicator reset to zero	×		
5.1.6	When maximum flowrate ( $O_{max}$ ) $\leq 3.6\text{ m}^3/\text{h}$ , $MMQ \leq 5\text{ L}$	×		$MMQ = 2\text{ L}$
5.1.8	Fuel dispenser interruptible	×		
5.1.9	Minimum duration of operation of display after power failure $\geq 15\text{ min}$ continuously and automatically, or $\geq 5\text{ min}$ in one or several periods controlled manually during 1 h Delivery interrupted by power failure: impossible to continue delivery if power failure has lasted more than 15 s	×		
5.1.10	Delay time between measurement value and indicated values $\leq 500\text{ ms}$	×		$\leq 250\text{ms}$
5.1.12	Hidden volume at the beginning of the delivery $\leq 2 \times MSVD$ Hidden price at the beginning of the delivery $\leq 2 \times MSPD$	×		0.04=2×0.02

## CONCLUSION OF TESTS

Application No. :25-001

Date : 2013/8/20

No.	Test description	+	-	Remark
1	Accuracy	×		
2	Minimum mesured quantity	×		
3	Flow interruption	×		
4	Gas elimination device	×		
5	Variation in the internal volume of hose	×		
6	Endurance test	×		
7	Dry heat (non-condensing)	×		
8	Cold	×		
21	Damp heat, cyclic (condensing)	×		
22	Power voltage variations	×		
23	Short-time power reductions	×		
24	Electrical bursts	×		
25	Electrostatic discharges	×		
26	Electromagnetic susceptibility	×		

Notes :

+	-
×	
	×
/	/

if the instrument has passed the test  
if the instrument has failed  
if the test is not applicable

Remarks :

Observer :

# TEST REPORT

Symbols, units and equations:

$P_u$	Unit price (¥/L)
$t$	Time (s)
$Q$	Flowrate of liquid (L/min)
$V_i$	Volume indication of dispenser (L)
$P_i$	Price indication (or printed if not fitted with a price indicator) of dispenser (¥)
$P_c$	Calculated price (¥)
$V_n$	Volume indication of test measure or computed volume from simulated pulses (L)
$T$	Temperature of liquid in the test measure (°C)
$T_r$	Reference temperature of test measure (°C)
$T_m$	Temperature of liquid passing through the meter (°C)
$E_v$	Error of volume indication (%)
$E_p$	Error of price indication (¥)
$Q_a$	Flowrate of air (L/min)
$V_a$	Volume of air (L)
$\alpha$	Cubic expansion coefficient of test liquid due to temperature (°C <sup>-1</sup> )
$\beta$	Cubic expansion coefficient of test measure due to temperature (°C <sup>-1</sup> )
$V_{nc}$	Volume of test measure, compensated for deviation from reference temperature (L)
$V_{mc}$	Volume passing through the meter compensated for deviation from reference temperature and pressure (L)
$\bar{E}$	Mean value of error of indication (% or ¥)
n	Number of tests at the same condition
$P_c$	= $V_i \times P_u$
$E_v$	= $(V_i - V_n) / V_n \times 100$ $V_n$ may be replaced by $V_{nc}$ , if appropriate
$E_p$	= $P_i \times P_c$
$Q$	= $(V_i \times 60) / t$
$V_{nc}$	= $V_n \times [1 + \beta(T - T_r)]$
$\bar{E}$	= $[E(1) + E(2) + \dots + E(n)] / n$
Range = Maximum error — minimum error (%) or Yen)	

Note: If significant differences are recorded between the temperature of the liquid in the meter and the test measure, a correction on the liquid volume passing though the meter is computed as follows:

$$V_{mc} = V_{nc} \times [1 + \alpha(T_m - T)]$$

and in this case  $V_{nc}$  is to be replaced by  $V_{mc}$  in the whole text.

If  $\beta$  is not known, the following values can be used.

Material	$\beta$ (°C <sup>-1</sup> )
	(uncertainty: $5 \times 10^{-6}$ °C <sup>-1</sup> )
Borosilica glass	$10 \times 10^{-6}$
Glass	$27 \times 10^{-6}$
Mild steel	$33 \times 10^{-6}$
Stainless steel	$51 \times 10^{-6}$
Copper, Brass	$53 \times 10^{-6}$
Aluminium	$69 \times 10^{-6}$

## 1 Accuracy (Page 1)

Application No. 25\_001 Date: 2013/7/2

Signature: Y.Fujimoto, Y.Miyazawa

Liquid:	<u>Gasoline</u>	Viscosity:	<u>0.90</u> mPa.s
$Q(1)$ L/min	$P_u$ kL	$V_i$ L	$P_i$ kL
40.0	123	50.18	6172
40.0	123	50.13	6166
40.0	123	50.24	6180
$E_v$	+0.08 %	Range	0.01 %
Ambient conditions			$E_p$ +0.12
Temperature:	<u>28.3</u> °C	Humidity:	<u>45.5</u> %RH
			Pressure: <u>1011.2</u> hPa

Ambient conditions  
Temperature: 28.0 °C Humidity: 50.0 %RH Pressure: 1011.0 hPa

$Q(2)$ L/min	$P_u$ kL	$V_i$ L	$P_i$ kL	$V_n$ L	$E_s$ L	$T$ °C	$E_T$ °C	$P_c$ kL	$V_{nc}$ L	$E_v$ %	mpe	$E_p$	MSPD
23.8	123	50.11	6164	50.085	0.037	23.4	-0.1	6163.53	50.07	+0.08	0.5	+0.47	2.46
23.8	123	50.09	6161	50.051	0.037	23.6	-0.1	6161.07	50.04	+0.11	0.5	-0.07	2.46
23.8	123	50.10	6162	50.066	0.037	23.6	-0.1	6162.30	50.05	+0.10	0.5	-0.30	2.46
$E_v$	+0.10 %	Range	0.03 %		$E_p$	+0.03							
Ambient conditions													
Temperature:	<u>28.0</u> °C	Humidity:	<u>50.0</u> %RH	Pressure:	<u>1011.0</u> hPa								

$Q(3)$ L/min	$P_u$ kL	$V_i$ L	$P_i$ kL	$V_n$ L	$E_s$ L	$T$ °C	$E_T$ °C	$P_c$ kL	$V_{nc}$ L	$E_v$ %	mpe	$E_p$	MSPD
14.2	123	50.00	6150	49.996	0.037	24.0	-0.1	6150.00	49.98	+0.04	0.5	0.00	2.46
14.2	123	50.09	6161	50.057	0.037	24.2	-0.1	6161.07	50.04	+0.10	0.5	-0.07	2.46
14.2	123	50.07	6159	50.038	0.037	24.4	-0.1	6158.61	50.02	+0.09	0.5	+0.39	2.46
$E_v$	+0.08 %	Range	0.06 %		$E_p$	+0.11							
Ambient conditions													
Temperature:	<u>27.5</u> °C	Humidity:	<u>48.8</u> %RH	Pressure:	<u>1010.9</u> hPa								

## 1 Accuracy (Page 2)

Application No: 25-001 Date: 2013/7/2

Signature: Y.Fujimoto, Y.Miyazawa

Liquid: Gasoline Viscosity: 0.86 mPa.s

$\frac{Q(4)}{L_{min}}$	$P_u$	$V_i$	$P_i$	$V_n$	$E_s$	$T$	$E_T$	$P_c$	$V_{\infty}$	$E_v$	mpe	$E_p$	MSPD
8.5	123	10.06	1237	10.045	0.001	26.1	-0.1	1237.38	10.05	+0.11	0.5	-0.38	2.46
8.5	123	10.03	1234	10.025	0.001	26.2	-0.1	1233.69	10.03	+0.01	0.5	+0.31	2.46
8.5	123	10.02	1232	10.014	0.001	26.4	-0.1	1232.46	10.02	+0.01	0.5	-0.46	2.46
$E_v$	+0.04 %	Range	0.10 %			$E_p$	-0.18						

Ambient conditions Temperature: 28.6 °C Humidity: 50.0 %RH Pressure: 1010.6 hPa

$\frac{Q(5)}{L_{min}}$	$P_u$	$V_i$	$P_i$	$V_n$	$E_s$	$T$	$E_T$	$P_c$	$V_{\infty}$	$E_v$	mpe	$E_p$	MSPD
5.0	123	10.02	1232	10.023	0.001	26.6	-0.1	1232.46	10.03	-0.08	0.5	-0.46	2.46
5.0	123	10.04	1235	10.025	0.001	26.8	-0.1	1234.92	10.03	+0.10	0.5	+0.08	2.46
5.0	123	10.02	1232	10.015	0.001	27.0	-0.1	1232.46	10.02	0.00	0.5	-0.46	2.46
$E_v$	+0.01 %	Range	0.18 %			$E_p$	-0.28						

Ambient conditions Temperature: 28.5 °C Humidity: 48.1 %RH Pressure: 1010.5 hPa

$\frac{Q(6)}{L_{min}}$	$P_u$	$V_i$	$P_i$	$V_n$	$E_s$	$T$	$E_T$	$P_c$	$V_{\infty}$	$E_v$	mpe	$E_p$	MSPD
3.0	123	10.02	1232	10.014	0.001	25.5	-0.1	1232.46	10.02	+0.02	0.5	-0.46	2.46
3.0	123	10.01	1231	10.008	0.001	26.8	-0.1	1231.23	10.01	-0.03	0.5	-0.23	2.46
3.0	123	10.03	1234	10.017	0.001	27.6	-0.1	1233.69	10.02	+0.08	0.5	+0.31	2.46
$E_v$	+0.02 %	Range	0.11 %			$E_p$	-0.13						

Ambient conditions Temperature: 29.3 °C Humidity: 45.8 %RH Pressure: 1009.8 hPa

### 1 Accuracy (Page 3)

Application No: 25-001 Date: 2013/7/1

Signature: T.Ito, M.Sugaya

Liquid: Diesel Viscosity: 3.73 mPa.s

$\frac{Q(1)}{L_{min}}$	$P_u$	$V_i$	$P_i$	$V_n$	$E_s$	$T$	$E_T$	$P_c$	$V_{ac}$	$E_v$	mpe	$E_p$	MSPD
70.0	123	100.18	12322	99.943	0.063	22.6	-0.1	12322.14	99.92	+0.26	0.5	-0.14	2.46
70.0	123	100.33	12341	100.114	0.063	22.7	-0.1	12340.59	100.09	+0.24	0.5	+0.41	2.46
70.0	123	100.36	12344	100.140	0.063	22.3	-0.1	12344.28	100.11	+0.25	0.5	-0.28	2.46
$E_v$	+0.25 %	Range	0.02 %		$E_p$	0.00							

Ambient conditions Temperature: 26.8 °C Humidity: 50.5 %RH Pressure: 1010.57 hPa

$\frac{Q(2)}{L_{min}}$	$P_u$	$V_i$	$P_i$	$V_n$	$E_s$	$T$	$E_T$	$P_c$	$V_{ac}$	$E_v$	mpe	$E_p$	MSPD
37.3	123	100.01	12301	99.733	0.063	22.6	-0.1	12301.23	99.71	+0.30	0.5	-0.23	2.46
37.3	123	100.09	12311	99.796	0.063	22.8	-0.1	12311.07	99.77	+0.32	0.5	-0.07	2.46
37.3	123	100.16	12320	99.868	0.063	23.0	-0.1	12319.68	99.84	+0.32	0.5	+0.32	2.46
$E_v$	+0.31 %	Range	0.02 %		$E_p$	+0.01							

Ambient conditions Temperature: 27.4 °C Humidity: 43.8 %RH Pressure: 1010.57 hPa

$\frac{Q(3)}{L_{min}}$	$P_u$	$V_i$	$P_i$	$V_n$	$E_s$	$T$	$E_T$	$P_c$	$V_{ac}$	$E_v$	mpe	$E_p$	MSPD
19.9	123	19.96	2455	19.895	0.010	26.5	-0.1	2455.08	19.90	+0.32	0.5	-0.08	2.46
19.9	123	20.06	2467	20.000	0.010	26.2	-0.1	2467.38	20.00	+0.29	0.5	-0.38	2.46
19.9	123	19.91	2449	19.857	0.010	25.8	-0.1	2448.93	19.86	+0.27	0.5	+0.07	2.46
$E_v$	+0.29 %	Range	0.05 %		$E_p$	-0.13							

Ambient conditions Temperature: 29.3 °C Humidity: 39.5 %RH Pressure: 1010.57 hPa

## 1 Accuracy (Page 4)

Application No: 25-001 Date: 2013/7/1

Signature: T.Ito, M.Sugaya

Liquid: Diesel Viscosity: 3.38 mPa.s

$\frac{Q(4)}{L_{min}}$	$P_u$	$V_i$	$P_i$	$V_n$	$E_s$	$T$	$E_T$	$P_c$	$V_{nc}$	$E_v$	mpe	$E_p$	MSPD
10.6	123	20.00	2460	19.936	0.010	25.1	-0.1	2460.00	19.94	+0.32	0.5	0.00	2.46
10.6	123	19.97	2456	19.911	0.010	25.7	-0.1	2456.31	19.91	+0.30	0.5	-0.31	2.46
10.6	123	20.02	2462	19.959	0.010	26.1	-0.1	2462.46	19.96	+0.30	0.5	-0.46	2.46
$E_v$	+0.31 %	Range	0.02 %			$E_p$	-0.26						

Ambient conditions  
Temperature: 29.0 °C Humidity: 43.0 %RH Pressure: 1010.57 hPa

$\frac{Q(5)}{L_{min}}$	$P_u$	$V_i$	$P_i$	$V_n$	$E_s$	$T$	$E_T$	$P_c$	$V_{nc}$	$E_v$	mpe	$E_p$	MSPD
5.6	123	10.01	1231	9.973	0.001	25.7	-0.1	1231.23	9.98	+0.33	0.5	-0.23	2.46
5.6	123	10.02	1232	9.982	0.001	26.5	-0.1	1232.46	9.99	+0.33	0.5	-0.46	2.46
5.6	123	9.95	1224	9.907	0.001	27.2	-0.1	1223.85	9.91	+0.38	0.5	+0.15	2.46
$E_v$	+0.35 %	Range	0.05 %			$E_p$	-0.18						

Ambient conditions  
Temperature: 25.8 °C Humidity: 59.2 %RH Pressure: 1010.57 hPa

$\frac{Q(6)}{L_{min}}$	$P_u$	$V_i$	$P_i$	$V_n$	$E_s$	$T$	$E_T$	$P_c$	$V_{nc}$	$E_v$	mpe	$E_p$	MSPD
3.0	123	10.01	1231	9.972	0.001	27.6	-0.1	1231.23	9.98	+0.33	0.5	-0.23	2.46
3.0	123	10.00	1230	9.959	0.001	28.4	-0.1	1230.00	9.96	+0.36	0.5	0.00	2.46
3.0	123	10.01	1231	9.970	0.001	29.1	-0.1	1231.23	9.98	+0.34	0.5	-0.23	2.46
$E_v$	+0.34 %	Range	0.03 %			$E_p$	-0.15						

Ambient conditions  
Temperature: 25.6 °C Humidity: 59.1 %RH Pressure: 1010.57 hPa

## 2 Minimum measured quantity

Application No: 25-001 Date: 2013/7/1

Signature: T.Ito, M.Sugaya

Liquied Gasoline Viscosity: 0.90 mPa.s

Q( 1 ) L/min	$V_i$ L	$V_n$ L	T °C	$T_s$ °C	$E_s$ L	$V_{nc}$ L	$E_v$ %	mpe %
40.0	2.010	2.007	23.8	-0.1	0.000	2.007	+0.15	0.5
40.0	2.000	1.999	23.8	-0.1	0.000	1.999	+0.05	0.5
40.0	2.010	2.012	24.1	-0.1	0.000	2.012	-0.10	0.5

Ambient conditions

Temperature: 26.3 °C  
Humidity: 54.0 %RH  
Pressure: 1010.0 hPa

Application No: 25-001 Date: 2013/7/1

Signature: Ito, Fujimoto, Miyazawa

Liquied Gasoline Viscosity: 0.89 mPa.s

Q( 6 ) L/min	$V_i$ L	$V_n$ L	T °C	$T_s$ °C	$E_s$ L	$V_{nc}$ L	$E_v$ %	mpe %
3.0	1.980	1.977	24.5	-0.1	0.000	1.978	+0.10	0.5
3.0	2.010	2.007	24.7	-0.1	0.000	2.008	+0.10	0.5
3.0	2.000	2.002	25.0	-0.1	0.000	2.003	-0.15	0.5

Ambient conditions

Temperature: 26.7 °C  
Humidity: 52.8 %RH  
Pressure: 1010.0 hPa

Test measures used: No.28-1  
 $\beta$ : 0.000048

Reference temperature: 15 °C

Test measures used: No.28-1  
 $\beta$ : 0.000048

Reference temperature: 15 °C

### 3 Flow interruption

Application No: 25-001 Date: 2013/6/18

Signature: Y.Fujimoto, M.Sugaya

Liquid: Gasoline Viscosity: 0.92 mPa.s

<u>Q( 1 )</u> <u>L/min</u>	<u>P<sub>u</sub></u> <u>Pa</u>	<u>V<sub>i</sub></u> <u>L</u>	<u>P<sub>i</sub></u> <u>Pa</u>	<u>V<sub>n</sub></u> <u>L</u>	<u>T</u> <u>°C</u>	<u>T<sub>s</sub></u> <u>°C</u>	<u>E<sub>s</sub></u> <u>L</u>	<u>P<sub>c</sub></u> <u>Pa</u>	<u>V<sub>nc</sub></u> <u>L</u>	<u>E<sub>v</sub></u> <u>%</u>	<u>mpe</u> <u>%</u>	<u>E<sub>p</sub></u> <u>Pa</u>	<u>MSPD</u> <u>Pa</u>
40.0	123.0	50.150	6168	50.173	22.7	-0.1	+0.037	6168.45	50.155	-0.01	0.5	-0.45	2.46
40.0	123.0	50.100	6162	50.094	22.8	-0.1	+0.037	6162.30	50.076	+0.05	0.5	-0.30	2.46
40.0	123.0	50.300	6187	50.293	22.8	-0.1	+0.037	6186.90	50.275	+0.05	0.5	+0.10	2.46
<i>E<sub>v</sub></i>	<b>0.03</b> %		<b>E<sub>p</sub></b>	<b>-0.22</b> %									

Ambient conditions

Temperature: 16.5 °C      Humidity: 60.0 %RH      Pressure: 1013.2 hPa

Application No: 25-001 Date: 2013/6/19

Signature: Ito, Fujimoto, Miyazawa

Liquid: Diesel Viscosity: 4.00 mPa.s

<u>Q( 1 )</u> <u>L/min</u>	<u>P<sub>u</sub></u> <u>Pa</u>	<u>V<sub>i</sub></u> <u>L</u>	<u>P<sub>i</sub></u> <u>Pa</u>	<u>V<sub>n</sub></u> <u>L</u>	<u>T</u> <u>°C</u>	<u>T<sub>s</sub></u> <u>°C</u>	<u>E<sub>s</sub></u> <u>L</u>	<u>P<sub>c</sub></u> <u>Pa</u>	<u>V<sub>nc</sub></u> <u>L</u>	<u>E<sub>v</sub></u> <u>%</u>	<u>mpe</u> <u>%</u>	<u>E<sub>p</sub></u> <u>Pa</u>	<u>MSPD</u> <u>Pa</u>
70.0	123.0	100.390	12348	100.161	21.5	-0.1	+0.063	12347.97	100.130	+0.26	0.5	+0.03	2.46
70.0	123.0	100.460	12357	100.233	21.5	-0.1	+0.063	12356.58	100.202	+0.26	0.5	+0.42	2.46
70.0	123.0	100.340	12342	100.106	21.5	-0.1	+0.063	12341.82	100.075	+0.26	0.5	+0.18	2.46
<i>E<sub>v</sub></i>	<b>0.26</b> %		<b>E<sub>p</sub></b>	<b>0.30</b> %									

Ambient conditions

Temperature: 25.0 °C      Humidity: 90.5 %RH      Pressure: 990.0 hPa

Test measures used: No.98-5

β: 0.000048

Reference temperature: 15.0 °C

#### 4 Gas elimination device (Page 1)

Application No. 25-001 Date: 2013/6/18

Signature: Y.Fujimoto, M.Sugaya

Liquid: Gasolin Viscosity: 0.92 mPa.s

Temperature: 32.6 °C Humidity: 55.3 %RH Pressure: 995.4 hPa

Remarks:

$V_a$	$V_i$	$V_n$	$T$	$T_s$	$E_s$	$V_{nc}$	$E_v$	mpε	$V_d/V_n$	Air bubble
L	L	L	°C	°C	L	L	%	%	$V_d/V_{nc}$	%
0.00	50.15	50.143	22.0	-0.1	+0.037	50.123	+0.05	0.50	0.00	no
0.00	50.10	50.090	22.1	-0.1	+0.037	50.070	+0.06	0.50	0.00	no
0.00	50.09	50.082	22.3	-0.1	+0.037	50.063	+0.05	0.50	0.00	no

Ambient conditions

Temperature: 32.6 °C

Humidity: 55.3 %RH

Pressure: 995.4 hPa

Remarks:

Test measures used: No.98.5  
 $\beta$ : 0.000948

Reference temperature: 15 °C

Gas meter used: ED007

Suction height: 1.5 m

Diameter: 25.0 mm

Length: 4.6 m

$V_a$	$V_i$	$V_n$	$T$	$T_s$	$E_s$	$V_{nc}$	$E_v$	mpε	$V_d/V_n$	Air bubble
L	L	L	°C	°C	L	L	%	%	$V_d/V_{nc}$	%
4.00	50.15	50.150	23.2	-0.1	+0.037	50.133	+0.03	0.50	4.00	no
8.00	50.49	50.482	23.2	-0.1	+0.037	50.465	+0.05	0.50	7.90	no
12.00	50.06	50.047	23.4	-0.1	+0.037	50.030	+0.06	0.50	12.00	no
16.00	50.03	50.013	18.3	-0.1	+0.037	49.996	+0.07	0.50	16.00	no
20.00	49.86	49.833	23.2	-0.1	+0.037	49.816	+0.09	0.50	20.10	no

Ambient conditions

Temperature: 30.2 °C

Humidity: 62.4 %RH

Pressure: 995.0 hPa

Remarks:

#### 4 Gas elimination device (Page 2)

Application No: 25-001 Date: 2013/6/19

Signature: T.Ito, Y.Fujimoto, Y.Miyazawa

Liquid: Diesel Viscosity: 4.00 mPa.s

Ambient conditions Temperature: 25.7 °C

Remarks:

$V_a$	$V_i$	$V_n$	$T$	$T_s$	$E_s$	$V_{ac}$	$E_v$	mpc	$V_s/V_n$	Air bubble
L	L	L	°C	°C	L	L	%	%	$V_s/V_{ac}$	%
0.00	100.210	99.976	21.5	-0.1	+0.063	99.945	+0.27	0.50	0.00	no
0.00	100.400	100.174	21.4	-0.1	+0.063	100.142	+0.26	0.50	0.00	no
0.00	100.120	99.890	21.4	-0.1	+0.063	99.858	+0.26	0.50	0.00	no

Ambient conditions Temperature: 25.7 °C

Remarks:

Humidity: 88.4 %RH

Pressure: 990.0 hPa

Test measures used: No.98-6  
 $\beta$ : 0.000048

Reference temperature: 15 °C

Gas meter used: ED007  
 Suction height: 1.5 m  
 Diameter: 25.0 mm  
 Length: 4.6 m

$V_a$	$V_i$	$V_n$	$T$	$T_s$	$E_s$	$V_{ac}$	$E_v$	mpc	$V_s/V_n$	Air bubble
L	L	L	°C	°C	L	L	%	%	$V_s/V_{ac}$	%
4.00	100.370	100.138	22.8	-0.1	+0.063	100.113	+0.26	0.50	4.00	no
8.00	100.050	99.818	22.3	-0.1	+0.063	99.790	+0.26	0.50	8.00	no
12.00	100.070	99.821	22.1	-0.1	+0.063	99.792	+0.28	0.50	12.00	no
16.00	100.190	99.940	18.3	-0.1	+0.063	99.912	+0.28	0.50	16.00	no
20.00	100.280	100.032	22.2	-0.1	+0.063	100.004	+0.28	0.50	20.00	no

Ambient conditions Temperature: 27.6 °C

Remarks:

Humidity: 77.3 %RH

Pressure: 990.1 hPa

## 5 variation in the internal volume of hose

Application No: 25-001 Date: 2013/8/13

Signature: Fujimoto

Mean value of variation		Without hose reel	With hose reel	20 mL	2×MSVD
8.9	mL			" mL	" mL

MSVD		Ambient conditions		Model of hose:	
Temperature:	22.6 °C	Temperature:	22.6 °C	Length:	4.72 m
Humidity:	50.7 %RH	Humidity:	50.7 %RH	Inner diameter:	19.0 mm
Pressure:	1006.4 hPa	Pressure:	1006.4 hPa	Maximum operating	0.31 MPa

Y	Y-X	Scale division	Variation
41.6	8.6	mL	8.6
50.8	9.2	2	9.2

## 6 Endurance test (Page 1)

Application No: 25-001

Signature: T.Ito, M.Sugaya

Date of accuracy test before endurance test: 2013/7/5

Liquid: Gasoline

Viscosity: 0.88 mPa.s

Volume per delivery: 2621.97 L

Total time of endurance test: 100.0 h

Total volume per meter: 262197.0 L

Resetting between deliveries: -

Number of stops: -

Change of grade: -

Date of accuracy test after endurance test: 2013/7/29

The liquid used for this test was gasoline for industrial purpose.

## 6 Endurance test (Page 2)

Application No: 25-001 Date: 2013/7/29

Signature: Ito, M.Sugaya

Liquid: Gasoline Viscosity: 0.90 mPa.s

Temperature: 25.4 °C Humidity: 85.4 %RH Pressure: 1001.0 hPa

$Q(1)$ L/min	$P_u$ kPa	$V_i$ L	$P_i$ kPa	$V_n$ L	$E_s$ °C	$T$ °C	$E_T$ °C	$P_c$ kPa	$V_{nc}$ L	$E_v$ %	$mpe$	$E_p$ kPa	MSPD %
40.0	123	50.04	6155	50.001	0.037	23.2	-0.1	6154.92	49.96	+0.15	0.5	+0.08	2.46
40.0	123	50.04	6155	49.991	0.037	23.3	-0.1	6154.92	49.95	+0.17	0.5	+0.08	2.46
40.0	123	50.13	6166	50.097	0.037	23.3	-0.1	6165.99	50.06	+0.14	0.5	+0.01	2.46
$E_v$	+0.15 %	Range	0.03 %		$E_p$	+0.06							

Ambient conditions

Temperature: 24.5 °C Humidity: 90.2 %RH Pressure: 1000.1 hPa

$Q(2)$ L/min	$P_u$ kPa	$V_i$ L	$P_i$ kPa	$V_n$ L	$E_s$ °C	$T$ °C	$E_T$ °C	$P_c$ kPa	$V_{nc}$ L	$E_v$ %	$mpe$	$E_p$ kPa	MSPD %
23.8	123	50.13	6166	50.077	0.037	23.6	-0.1	6165.99	50.04	+0.18	0.5	+0.01	2.46
23.8	123	49.98	6148	49.923	0.037	23.6	-0.1	6147.54	49.89	+0.19	0.5	+0.46	2.46
23.8	123	50.07	6159	50.020	0.037	23.6	-0.1	6158.61	49.98	+0.17	0.5	+0.39	2.46
$E_v$	+0.18 %	Range	0.02 %		$E_p$	+0.29							

Ambient conditions

Temperature: 24.5 °C Humidity: 90.4 %RH Pressure: 1000.7 hPa

$Q(3)$ L/min	$P_u$ kPa	$V_i$ L	$P_i$ kPa	$V_n$ L	$E_s$ °C	$T$ °C	$E_T$ °C	$P_c$ kPa	$V_{nc}$ L	$E_v$ %	$mpe$	$E_p$ kPa	MSPD %
14.2	123	50.23	6178	50.179	0.037	23.8	-0.1	6178.29	50.14	+0.18	0.5	-0.29	2.46
14.2	123	50.06	6157	50.008	0.037	23.9	-0.1	6157.38	49.97	+0.18	0.5	-0.38	2.46
14.2	123	50.07	6159	50.020	0.037	23.7	-0.1	6158.61	49.98	+0.17	0.5	+0.39	2.46
$E_v$	+0.18 %	Range	0.01 %		$E_p$	-0.09							

Ambient conditions

Temperature: 24.3 °C Humidity: 90.4 %RH Pressure: 1000.7 hPa

## 6 Endurance test (Page 3)

Application No: 25-001 Date: 2013/7/29

Signature: T.Ito, M.Sugaya

Liquid: Gasoline Viscosity: 0.86 mPa.s 26.1

$Q(4)$ L/min	$P_u$ kPa	$V_i$ L	$P_i$ kPa	$V_n$ L	$E_s$ °C	$T$ °C	$E_T$ °C	$P_c$ kPa	$V_{nc}$ L	$E_v$ %	$mpe$ %	$E_p$ kPa	MSPD %
8.5	123	10.01	1231	9.989	0.001	25.8	-0.1	1231.23	9.99	+0.22	0.5	-0.23	2.46
8.5	123	10.03	1234	10.012	0.001	25.8	-0.1	1233.69	10.01	+0.19	0.5	+0.31	2.46
8.5	123	10.03	1234	10.009	0.001	26.2	-0.1	1233.69	10.01	+0.22	0.5	+0.31	2.46
$E_v$	+0.21 %	Range	0.03 %			$E_p$	+0.13						

Ambient conditions

Temperature: 26.6 °C Humidity: 83.8 %RH Pressure: 999.2 hPa

$Q(5)$ L/min	$P_u$ kPa	$V_i$ L	$P_i$ kPa	$V_n$ L	$E_s$ °C	$T$ °C	$E_T$ °C	$P_c$ kPa	$V_{nc}$ L	$E_v$ %	$mpe$ %	$E_p$ kPa	MSPD %
5.0	123	9.99	1229	9.970	0.001	26.1	-0.1	1228.77	9.97	+0.21	0.5	+0.23	2.46
5.0	123	10.01	1231	9.992	0.001	26.2	-0.1	1231.23	9.99	+0.19	0.5	-0.23	2.46
5.0	123	10.02	1232	10.000	0.001	26.2	-0.1	1232.46	10.00	+0.21	0.5	-0.46	2.46
$E_v$	+0.20 %	Range	0.02 %			$E_p$	-0.15						

Ambient conditions

Temperature: 26.5 °C Humidity: 84.9 %RH Pressure: 999.0 hPa

$Q(6)$ L/min	$P_u$ kPa	$V_i$ L	$P_i$ kPa	$V_n$ L	$E_s$ °C	$T$ °C	$E_T$ °C	$P_c$ kPa	$V_{nc}$ L	$E_v$ %	$mpe$ %	$E_p$ kPa	MSPD %
3.0	123	9.99	1229	9.973	0.001	26.2	-0.1	1228.77	9.97	+0.18	0.5	+0.23	2.46
3.0	123	9.98	1228	9.964	0.001	26.3	-0.1	1227.54	9.96	+0.17	0.5	+0.46	2.46
3.0	123	10.01	1231	9.995	0.001	26.2	-0.1	1231.23	9.99	+0.16	0.5	-0.23	2.46
$E_v$	+0.17 %	Range	0.02 %			$E_p$	+0.15						

Ambient conditions

Temperature: 26.1 °C Humidity: 86.2 %RH Pressure: 999.0 hPa

**7 Dry heat (non condensing)**

Application No: 25-001 Date: 2013/6/25

Signature: Fujimoto

Test condition	Q L/min	P <sub>u</sub> kPa	V <sub>i</sub> L	P <sub>i</sub> kPa	V <sub>u</sub> L	P <sub>c</sub> kPa	E <sub>v</sub> %	mpe %	E <sub>p</sub> kPa	MSPD kPa
20°C	70.0	123	100.07	12309	100.07	12308.6	0.00	0.5	+0.39	6.15
55°C	70.0	123	100.63	12377	100.62	12377.5	+0.01	0.5	-0.49	6.15
20°C	70.0	123	100.07	12309	100.07	12308.6	0.00	0.5	+0.39	6.15

Ambient conditions (20°C); Temperature: 22.9 °C

Ambient conditions (55°C); Temperature: 23.6 °C

Ambient conditions (20°C); Temperature: 23.8 °C

Humidity: 52.9 %RH

Humidity: 52.5 %RH

Humidity: 52.5 %RH

Pressure: 1005.4 hPa

Pressure: 1005.0 hPa

Pressure: 1004.7 hPa

Remarks:  
Simulator used in this test  
Simulator manufacturer: TOMINAGA  
mechanical type(0.01L/P)

## 8 Cold

Application No: 25-001

Date: 11/06/21-28

Signature: Fujimoto, Ito

Test condition	Q L/min	P <sub>u</sub> kPa	V <sub>i</sub> L	P <sub>i</sub> kPa	V <sub>a</sub> L	P <sub>c</sub> kPa	E <sub>v</sub> %	mpe %	E <sub>p</sub> kPa	MSPD kPa
20°C	701.0	123	100.66	12381	100.66	12381	0.00	0.5	0.00	6.15
-23°C	701.0	123	100.27	12333	100.27	12333	0.00	0.5	0.00	6.15
20°C	701.0	123	107.46	13218	107.46	13218	0.00	0.5	0.00	6.15

Ambient conditions (20°C):

Temperature: 23.1 °C      Humidity: 50.7 %RH      Pressure: 1001.3 hPa

Ambient conditions (-23°C):

Temperature: 22.9 °C      Humidity: 49.9 %RH      Pressure: 1006.2 hPa

Ambient conditions (20°C):

Temperature: 23.3 °C      Humidity: 50.8 %RH      Pressure: 1004.9 hPa

Remarks:

Simulator used in this test  
Simulator manufacturer: TOMINAGA  
mechanical type(0.01L/P)

## 9 Damp heat, cyclic (condensing)

Application No: 25-001 Date: 2013/06/27-7/1

Signature: Fujimoto

Test condition	$Q(6')$ L/min	$P_u$ %	$V_i$ L	$H_i$ %	$P_i$ %	$V_n$ L	$P_c$ %	$E_v$ %	type %	$E_p$ %	MSPD %
20°C	70	123	107.46	47.6	13218	107.46	13217.58	0.00	0.5	+0.42	6.15
50%RH											

Damp heat, cyclic (24 hours x 2 cycles)

20°C	70	123	101.07	48.2	12432	101.07	12431.61	0.00	0.5	+0.39	6.15
50%RH											

$H_i$ :Relative humidity indication

Ambient conditions  
Temperature: 23.4 °C      Humidity: 50.4 %RH      Pressure: 1011.0 hPa

Remarks:  
Simulator used in this test  
Simulator manufacturer: TOMINAGA  
mechanical type(0.011LP)

## 10 Power voltage variation

Application No: 25-001 Date: 2013/7/4

Signature: sugaya

Test condition	$U_i$ V	$Q$ L/min	$P_u$ W/L	$V_i$ L	$P_i$ W	$V_n$ L	$P_c$ W	$E_v$ %	$mpe$ %	$E_p$ W	MSPD V
$U$	100.0	80.0	123	100.980	12421	100.98	12421	<b>0.00</b>	0.5	0.00	6.15
$1.1 U$	264.0	80.0	123	100.040	12305	100.00	12305	<b>+0.04</b>	0.5	0.00	6.15
$0.85 U$	85.0	80.0	123	100.160	12320	100.12	12320	<b>+0.04</b>	0.5	0.00	6.15

$U$  : Mains voltage

$U_i$ : Indicated mains voltage

Ambient conditions  
Temperature: 27.4 °C      Humidity: 64.9 %RH      Pressure: 1000.9 hPa

Remarks:  
Simulator used in this test  
Simulator manufacturer: TOMINAGA  
mechanical type(0.01LP)  
Power circuit: No.  
Voltage:

## 11 Short-time power reductions

Application No. 25-001

Date: 2013/7/4

Signature: sugaya,fujimoto

Test condition	Q L/min	P <sub>u</sub> kPa	V <sub>i</sub> L	P <sub>i</sub> kPa	V <sub>a</sub> L	P <sub>c</sub> kPa	E <sub>v</sub> %	S.F. %	E <sub>p</sub> kPa	MSPD %	Checking facility
No reduction	80.0	123	80.150	9858	80.15	9858.0	0.00	<b>0.00</b>	0.00	6.15	-
100% reduction 1/2 cycle, 10 yimes	80.0	123	89.260	10979	89.23	10979.0	+0.03	<b>0.03</b>	0.00	6.15	yes
50% reduction 1 cycle, 10 yimes	80.0	123	89.060	10954	89.06	10954.0	0.00	<b>0.00</b>	0.00	6.15	yes

Ambient conditions      Temperature: 27.1 °C      Humidity: 62 %RH      Pressure: 999.7 hPa

Remarks:

Simulator used in this test  
Simulator manufacturer:TOMINAGA  
mechanical type(0.01L/P)

## 12 Electrical bursts

Application No: 25-001 Date: 2013/7/4 Signature: sugaya,fujimoto

Test condition	Q L/min	P <sub>u</sub> kPa	V <sub>i</sub> L	P <sub>i</sub> kPa	V <sub>a</sub> L	P <sub>c</sub> kPa	E <sub>v</sub> %	S.F. %	E <sub>p</sub> kPa	MSPD kPa	Checking facility
Noiseless	70.0	123	100.160	12320	100.12	12320	+0.04	0.00	0.00	6.15	No
L1, Positive	70.0	123	74.290	9138	74.25	9138	+0.05	0.01	0.00	6.15	yes
L1, Negative	70.0	123	73.020	8981	72.98	8981	+0.05	0.01	0.00	6.15	yes
L2, Positive	70.0	123	71.770	8828	71.73	8828	+0.06	0.02	0.00	6.15	yes
L2, Negative	70.0	123	73.980	9100	73.95	9100	+0.04	0.00	0.00	6.15	yes
PE, Positive	70.0	123	74.290	9138	74.25	9138	+0.05	0.01	0.00	6.15	yes
PE, Negative	70.0	123	73.910	9087	73.88	9091	+0.04	0.00	-4.00	6.15	yes
PE, Negative	70.0	123	73.750	9071	73.75	9071	0.00	0.04	0.00	6.15	yes
PE, Negative	70.0	123	73.640	9054	73.57	9058	+0.10	0.06	-4.00	6.15	yes
PE, Negative	70.0	123	73.680	9063	73.68	9063	0.00	0.04	0.00	6.15	yes
PE, Negative	70.0	123	73.640	9058	73.61	9058	+0.04	0.00	0.00	6.15	yes
PE, Negative	70.0	123	74.030	9106	73.99	9106	+0.05	0.01	0.00	6.15	yes
PE, Negative	70.0	123	73.570	9049	73.53	9049	+0.05	0.01	0.00	6.15	yes
L1+L2+PE, Positive	70.0	123	74.220	9129	74.18	9129	+0.05	0.01	0.00	6.15	yes
L1+L2+PE, Negative	70.0	123	75.290	9261	75.25	9261	+0.05	0.01	0.00	6.15	yes

Line 1: Phase/Neutral  
Line 2: Phase/Neutral

Ambient conditions  
Temperature: 27.3 °C  
Humidity: 59.5 %RH  
Pressure: 1000.7 hPa

Remarks:

Simulator used in this test  
Simulator manufacturer: TOMINAGA  
mechanical type(0.01LP)

Pressure: 1000.7 hPa

### 13 Electrostatic discharge (Page 1)

Application No: 25-001

Date: 2013/8/12

Signature: Fujimoto


Test Condition		Q L/min	P <sub>u</sub> kPa	V <sub>i</sub> L	P <sub>i</sub> kPa	V <sub>a</sub> L	P <sub>c</sub> kPa	E <sub>v</sub> %	S.F. %	E <sub>p</sub> kPa	MSPD %	Checking facility
Non-discharge	70	123	100.10	12312	100.10	12312	0.00	0.00	0.00	0.00	6.15	yes
Front	+	70	123	104.91	12904	104.91	12904	0.00	0.00	0.00	6.15	yes
Back	-	70	123	104.98	12913	104.98	12913	0.00	0.00	0.00	6.15	yes
Right	+	70	123	104.91	12904	104.91	12904	0.00	0.00	0.00	6.15	yes
(Nozzle boot)	-	70	123	104.65	12872	104.65	12872	0.00	0.00	0.00	6.15	yes
Left	+	70	123	104.86	12898	104.86	12898	0.00	0.00	0.00	6.15	yes
(Nozzle boot)	-	70	123	104.91	12904	104.91	12904	0.00	0.00	0.00	6.15	yes
Top	+	70	123	107.14	13178	107.13	13178	+0.01	0.01	0.00	6.15	yes
	-	70	123	105.48	12974	105.48	12974	0.00	0.00	0.00	6.15	yes
	+	70	123	107.50	13223	107.51	13223	-0.01	0.01	0.00	6.15	yes
	-	70	123	107.60	13235	107.60	13235	0.00	0.00	0.00	6.15	yes
Front	+	70	123	116.00	14268	116.00	14268	0.00	0.00	0.00	6.15	yes
Air discharge	-	70	123	118.49	14574	118.49	14574	0.00	0.00	0.00	6.15	yes
Back	+	70	123	116.67	14350	116.66	14350	+0.01	0.01	0.00	6.15	yes
	-	70	123	115.29	14181	115.29	14181	0.00	0.00	0.00	6.15	yes
Front(1)	+	70	123	108.71	13371	108.71	13371	0.00	0.00	0.00	6.15	yes
	-	70	123	105.96	13525	109.96	13525	0.00	0.00	0.00	6.15	yes
Right(2)	+	70	123	105.54	12981	105.54	12981	0.00	0.00	0.00	6.15	yes
Indirect discharge	-	70	123	105.79	13012	105.78	13012	+0.01	0.01	0.00	6.15	yes
Back(3)	+	70	123	106.08	13048	106.08	13048	0.00	0.00	0.00	6.15	yes
	-	70	123	106.71	13125	106.71	13125	0.00	0.00	0.00	6.15	yes
Left(4)	+	70	123	105.22	12942	105.22	12942	0.00	0.00	0.00	6.15	yes
	-	70	123	106.37	13084	106.37	13084	0.00	0.00	0.00	6.15	yes

Ambient conditions


Temperature: 22.3 °C      Humidity: 50.2 %RH      Pressure: 1006.2 hPa

### 13 Electrostatic discharge (Page 2)


Direct discharge



Indirect discharge




↓ facing EUT



X :Contact discharges

O :Air discharges



#### 14 Electromagnetic susceptibility (Page 1)

Application No: 25-001

Date: 2013/7/2

Signature: ITO

Test condition	S.V. decade/s	Q L/min	P <sub>a</sub> V/L	V <sub>i</sub> L	P <sub>i</sub> V <sub>a</sub> L	V <sub>a</sub> L	P <sub>c</sub> %	E <sub>v</sub> %	S.F. %	E <sub>p</sub> %	MSPD	Checking facility
Noiseless	0	70	123	101.07	12432	101.07	12432	0.00	0.00	0.00	6.15	Yes
Front	V	1.5x10-3	70	123	3517.370	432637	3517.37	432637	0.00	0.00	6.15	Yes
	H	1.5x10-3	70	123	3574.440	439656	3574.44	439656	0.00	0.00	6.15	Yes
Right	V	1.5x10-3	70	123	3581.080	440473	3581.08	440473	0.00	0.00	6.15	Yes
	H	1.5x10-3	70	123	3727.230	458449	3727.23	458449	0.00	0.00	6.15	Yes
Left	V	1.5x10-3	70	123	3796.690	466993	3796.69	466993	0.00	0.00	6.15	Yes
	H	1.5x10-3	70	123	3547.020	436283	3547.02	436283	0.00	0.00	6.15	Yes
Back	V	1.5x10-3	70	123	3488.080	429034	3488.08	429034	0.00	0.00	6.15	Yes
	H	1.5x10-3	70	123	3805.070	468024	3805.07	468024	0.00	0.00	6.15	Yes

Ambient conditions


Temperature: 29.3 °C

Humidity: 44.7 %RH

Pressure: 1010.6 hPa

S.V.: Sweep Velocity  
F.S.: Field Strength  
V: Vertical  
H: Horizontal

↓ facing EUT



**14 Electromagnetic susceptibility (Page 2)**

