



# OIML Certificate

**OIML Member State**  
The Netherlands

Number R137/2012-A-NL1-20.07 revision 5  
Project number 3937886  
Page 1 of 6

Issuing authority  
Person responsible:

NMi Certin B.V.  
M.Ph.D. Schmidt

Applicant and  
Manufacturer

Elster GmbH  
Steinern Straße 19-21  
55252 Mainz-Kastel  
Germany

Identification of the  
certified type

An **Ultrasonic Gas Meter**  
Manufacturers mark: Elster  
Type: Q.Sonic<sup>max</sup>, Q.Sonic<sup>max6</sup>

Characteristics

See page 2 and further

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

**R 137-1:2012 "Gas meters"**

Accuracy class

0.5; 1.0 for Q.Sonic<sup>max</sup>  
1.0 for Q.Sonic<sup>max6</sup>

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above.  
This Certificate does not bestow any form of legal international approval.

This certificate and supporting reports comply with the requirements of OIML-CS-PD-07 clause 6.2.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority

**NMi Certin B.V., OIML Issuing Authority NL1**  
14 July 2025

## Certification Board

**NMi Certin B.V.**  
Thijssseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certin@nmi.nl](mailto:certin@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at [www.oiml.org](http://www.oiml.org)

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.



**OIML Member State**  
The Netherlands

Number R137/2012-A-NL1-20.07 revision 5  
Project number 3937886  
Page 2 of 6

The conformity was established by the results of tests and examinations provided in the associated reports:

- NMI-9200288-01 dated 18 January 2012 that includes in total 48 pages;
- NMI-16200535-01 revision 1 dated 1 September 2017 that includes 35 pages;
- NMI-1902121-01 dated 12 October 2018 that includes 14 pages.
- NMI-2326650-01 dated 12 October 2020 that includes 20 pages.
- NMI-2500011-01 dated 29 June 2021 that includes 21 pages.
- NMI-3567045-01 dated 13 December 2022 that includes 19 pages.
- NMI-3684021-01 dated 6 June 2025 that includes 40 pages.
- NMI-3715752-01 dated 6 June 2025 that includes 15 pages.

## Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented.

Table 2 gives an overview of the software versions of the electronics.

Table 3 and Table 4 give an overview of the general characteristics of the family of instruments.

The construction of the measuring instrument is recorded in documentation folder number T10586-5.

**Table 1 General characteristics**

Destined for the measurement of	Gas volume
Environmental classes	M1 / E2 Condensing humidity
Accuracy class	0.5 ; 1.0 for Q.Sonic <sup>max</sup> 1.0 for Q.Sonic <sup>max6</sup>
Transducers	MHz
Path Angle	50°
Path configuration	Q.Sonic <sup>max</sup> : 6 direct paths and 2 reflection swirl paths. Q.Sonic <sup>max6</sup> : 6 direct paths <sup>[1]</sup> .
Working pressure	The meter is either programmed with a density and viscosity setting, corresponding to the applied gas at preset pressure or using live pressure value from the optional pressure sensor. When using a preset value, the maximum operating range for pressure $p_{max} / p_{min}$ is 6,25 symmetrically divided around the preset pressure.
Ambient temperature range	-40 ... +70 °C gas meter -40 ... +55 °C gas meter with EVCD
Gas temperature range	-40 ... +100 °C gas meter -30 ... +80 °C gas meter with EVCD
Orientation	Horizontal; vertical up; vertical down and all orientations.
Power supply voltage	18 – 30 V DC

[1] Basically the Q.Sonic<sup>max6</sup> is identical to the Q.Sonic<sup>max</sup> with the two swirl paths removed.

**OIML Member State**  
The Netherlands

Number R137/2012-A-NL1-20.07 revision 5  
Project number 3937886  
Page 3 of 6

**Table 2 Software identification**

Software part	Software version	Checksum	Software version	Checksum
NGQFB	01.00.06	0x8A36A8B7	01.00.08	0x350616D6
	01.00.07	0xB7568107	01.00.09	0x06BDB754
NGQMB	01.00.08	0x81905758	01.00.12	0xD8615DF7
	01.00.10	0x0C432F97		
Basic system	02.08.00.0029	0xEBF74980	03.02.00.0000	0x36B6BE1E
	02.10.01.0003	0x7C01880E	03-40-A	0x0EA0B879
	02.11.00.0018	0x75574588	03-44-A	0xCE9961F4
Density & Viscosity	02.04.00.0000	0x804BDA24	03.00.00.0000	0xE062B4B9
	02.04.00.0001	0xBB87257F	03-01-A	0xA5C2AE67
	02.04.00.0005	0x1DF2525D	03-02-B	0xC3614274
Geometry Correction	02.04.00.0000	0x90D4BD88	03.00.00.0000	0x4F26E00E
	02.04.00.0001	0xD8D14A5F	03-01-A	0xFD14CF91
	02.05.00.0000	0x6C1DF991	03-02-B	0xD84D93A5
USM	02.08.00.0000	0x57D99098	03.02.00.0000	0x46340214
	02.10.00.0000	0x3DE0303F	03-03-A	0xC1006EAD
	02.11.00.0018	0x9B8E6234	03-05-A	0x95DB58DB
Gas Quality <sup>(★)</sup>	02-09-B	0x31D9C769	03-13-A	0x98B1FD23
	02-09-C	0xC83315E2	03-15-F	0x05CB4161
	02-09-D	0xBD083158	03-18-A	0x0E781C1F
Flow Conversion <sup>(★)</sup>	02-07-C	0x5A084FC6	03-10-D	0xC2172756
	02-07-D	0x587979DE	03-14-C	0x3BE626FB
	02-07-E	0xC960A68C	03-14-F	0x6D579C63
Postprocessing	02-08-B	0x2C4B20EC	03-09-D	0x816A45E3
	02-08-C	0x459B14C1	03-12-E	0xDBEB2D99
	02-08-D	0x65397437	03-14-A	0x1602675F
Archive	02-06-A	0xB9652A43	03-10-D	0xB6E506A1
	02-07-A	0x420652AC	03-10-P	0x384639C5
	02-07-B	0x013C7919	03-11-C	0x9909DD67
Modbus	02-20-A	0x9221E790	03-12-B	0x8E1DD57B
	02-20-B	0xF4348ED8	03-17-A	0x47A64C44
	02-20-C	0xF20B85FE	03-19-B	0x6869AD67

**Notes:**

(★) These software modules are only mandatory if volume conversion is performed by the instrument. If this is not the case, the software modules are optional.

**Table 3 General characteristics of the Q.Sonic<sup>max</sup> family of instruments**

Diameter size		minimum Internal bore  $ID_{min}$	maximum Internal bore  $ID_{max}$	Minimum flow velocity  $V_{min}^{[1]}$	Minimum Transitional flow velocity  $V_t^{[1], [2]}$	Maximum flow velocity  $V_{max}^{[1]}$
Inch	DN	[mm]	[mm]	[m/s]	[m/s]	[m/s]
4	100	90	102,3	0,49	2,3	37,6
6	150	139	154,1	0,29	2,0	36,6
8	200	180	206,4	0,29	2,1	39,2
10	250	230	254,4	0,29	2,0	36,2
12	300	280	311,2	0,30	1,5	33,8
14	350	305	325	0,28	1,5	33,5
16	400	350	393,7	0,30	1,5	33,6
18	450	387,1	437,9	0,24	2,7	27,1
20	500	431,8	488,9	0,30	1,6	31,1
22	550	489	530	0,28	1,4	28,7
24	600	532,2	590,9	0,30	1,5	30,4
26	650	609,2	640,9	0,26	2,8	28,4
30	750	730,3	742,9	0,25	2,9	29,5
36	900	850,5	894,9	0,30	1,5	29,8

**Table 4 General characteristics of the Q.Sonic<sup>max6</sup> family of instruments**

Diameter size		minimum Internal bore	maximum Internal bore	Minimum flow velocity	Minimum transitional flow velocity	Maximum flow velocity		
Inch	DN	ID <sub>min</sub> [mm]	ID <sub>max</sub> [mm]	V <sub>min</sub> <sup>[1]</sup> [m/s]	V <sub>t</sub> <sup>[1]</sup> [m/s]	V <sub>max</sub> <sup>[1]</sup> [m/s]		
3	80	58	85	0,5	2,2	38,2		
4	100	80	112					
6	150	120	165					
8	200	165	215	0,3	1,8		38,2	
10	250	205	270					
12	300	255	320					
14	350	255	350					
16	400	325	400		1,5			33,0
18	450	365	450					
20	500	405	500					

**OIML Member State**  
The Netherlands

Number R137/2012-A-NL1-20.07 revision 5  
Project number 3937886  
Page 5 of 6

Diameter size		minimum Internal bore	maximum Internal bore	Minimum flow velocity	Minimum transitional flow velocity	Maximum flow velocity
Inch	DN	ID <sub>min</sub> [mm]	ID <sub>max</sub> [mm]	V <sub>min</sub> <sup>[1]</sup> [m/s]	V <sub>t</sub> <sup>[1]</sup> [m/s]	V <sub>max</sub> <sup>[1]</sup> [m/s]
22	550	450	550	0,3	1,5	33,0
24	600	490	600			
26	650	605	650			
30	750	695	750			
36	900	850	905			

For tables 3 and 4, the corresponding flow rates can be calculated as follows:

$$Q = V \cdot \frac{1}{4} \cdot \pi \cdot ID^2 \cdot 3600 = 900 \cdot \pi \cdot ID^2 \cdot V$$

Where:

Q = flow rate [m³/h]

V = velocity [m/s]

ID = inner diameter [m]

Notes:

[1] If higher values are chosen for Q<sub>min</sub> and/or Q<sub>t</sub> and/or lower values for Q<sub>max</sub>, it has to be taken into account that:

- $5 \leq Q_{\max}/Q_{\min} < 50$ :  $Q_{\max}/Q_t \geq 5$
- $Q_{\max}/Q_{\min} \geq 50$ :  $Q_{\max}/Q_t \geq 10$

## Installation conditions:

### Installation of the ultrasonic gas meter

For mild and severe flow disturbances the meter needs to be installed with the following minimum straight piping configuration as upstream inlet:

	<b>Q.Sonic<sup>max</sup></b>	<b>Q.Sonic<sup>max6</sup></b>
- Mild disturbances	≥5D	≥3D + FC + 5D or ≥6D
- Severe disturbances	≥5D + FC + 5D	≥3D + FC + 5D

The flow conditioner (FC) can be of the following types and shall always be placed at the exact distance from the ultrasonic gas meter as indicated in the table above:

- CPA50 type A
- NOVA 50E

The outlet piping shall comply with:

- ≥3D

Any components which could affect the gas flow must be avoided within the above prescribed inlet pipe length. The necessary straight pipe length is stated on the name plate of the meter. The inlet pipe must be designed as a straight pipe section of the same nominal diameter as the gas meter with a maximum tolerance of ±3%.

**OIML Member State**  
The Netherlands

Number R137/2012-A-NL1-20.07 revision 5  
Project number 3937886  
Page 6 of 6

## *Bi-directional flow measurement*

During conformity assessment it is sufficient to verify a bi-directional meter only in one direction.

## *Temperature sensor*

The installation of a temperature sensor is at 2–5D from the outlet of the meter or of a dedicated measuring skid section (as described in chapter *Measuring skid with two meters in series*). For bi-directional applications, an additional temperature sensor can be installed 2–5D upstream of the meter or of a dedicated measuring skid section. The pipe spools including the thermowell(s) shall be installed and considered during the examination for putting into use of the gas meter.

## *Measuring skid with two meters in series*

A conformity assessment is needed when the meter will be used in series with another ultrasonic meter (same or different type) and the length of the straight piping between the two meters is smaller than the minimum inlet or outlet length as mentioned in chapter 3.1 or if the meters are direct connected (flange to flange) to each other.

The conformity assessment has to be done on the complete measuring skid (USM package, including meter tubes, flow conditioner and thermowells) and the upstream meter must fulfil the inlet requirements of the downstream meter.

## *Alternative welded installation*

The meters can be welded directly without flanges to the inlet and outlet pipes. The inlet and outlet pipe length shall be according the requirements as prescribed above for mild and/or severe disturbances. The complete meter package (meter including welded piping) shall be calibrated in order to guarantee compliance with Class 0.5 for Q.Sonic<sup>max</sup> or Class 1.0 for Q.Sonic<sup>max</sup> or Q.Sonic<sup>max6</sup>.

## **Interchangeable components:**

The ultrasonic transducers and the electronics can be replaced with units of the same type and the meter still meets the requirements without the need for recalibration. After exchange of a part of the system, a diagnostic check shall be carried out. After exchange of an electronic board all parameters of the old electronics board need to be transferred to the replacement board.

## **Certificate history:**

This revision replaces the previous version.

Revision	Date	Description of the modification
Initial	2 November 2020	-
1	26 August 2021	Revision due to new hardware: - Field terminal board version BD. - Main Board version AJ.
2	18 August 2022	Addition of firmware V3.40.
3	13 December 2022	New Board (Ethernet Range Extender)
4	11 June 2025	Addition of Q.Sonic <sup>max6</sup> 6-path meters for accuracy Class 1.0 only.
5	14 July 2025	Addition of firmware V3.44.