



OIML Certificate

OIML Member StateThe Netherlands



Number R46/2012-A-NL1-21.11 revision 1 Project number2516581 Page 1 of 3

Issuing authority NMi Certin B.V.

Person responsible: M.Ph.D. Schmidt

+

Applicant and Manufacturer

Jiangsu Linyang Energy Co. Ltd.

Linyang Road 666 Jiangsu Province 226299

Didona

Qidong P.R. China

Identification of the certified type

A measuring instrument

Type: NW34-R08

Characteristics Se

See next page

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R 46-1/-2 (2012) "Active electrical energy meters"

Accuracy class B

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority NMi Certin B.V., OIML Issuing Authority NL1

7 July 2023

Certification Board





NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.









OIML Certificate



Number R46/2012-A-NL1-21.11 revision 1 Project number 2516581 Page 2 of 3

The conformity was established by the results of tests and examinations provided in the associated report(s):



- No. NMi-2516581-01 dated 23 February 2021 that includes 59 pages;
- No. NMi-2516581-02 dated 23 February 2021 that includes 11 pages.

Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented.

Table 1 General characteristics

General characteristics	General characteristics		
Meter type	static		
Connection mode (phase, wires, elements)	3p, 4w, 3e		
Direction of energy flow / registers	bi-directional		
Terminal arrangement	BS		
Protective class	Category 2		
Impulse voltage	8 kV		
Environmental application			
Ambient temperature range	-40 °C to +70 °C; tested up to +75°C as a specific customer requirement.		
Humidity class	H1		
IP Rating / environmental use	IP54 / Indoor		
Meter quantities			
Nominal voltage (U_{nom})	3x133/230 V and 3x230/400 V		
Nominal frequency (f_{nom})	60 Hz		
Maximum current (I _{max})	100 A		
Transitional current ($I_{\rm tr}$)	1 A		
Minimum current (/ _{min})	0,5 A		
Starting current (Ist)	0,04 A		
Meter constant	1.000 imp./kWh		
Product version			
Hardware version	7.825.002562v2.1		
Software identification	Version number: LY1N1-2020-06-16 Checksum: 5E2C		









Number R46/2012-A-NL1-21.11 revision 1 Project number 2516581 Page 3 of 3

Certificate history: This revision replaces the previous version.



Revision	Date	Description of the modification	
Initial	2021-02-25	-	
1	2023-07-07	Impulse voltage level included	









