



# OIML Certificate

**OIML Member State**  
The Netherlands

Number R60/2017-A-NL1-23.31 revision 1  
Project number 3806206  
Page 1 of 3

Issuing authority

NMi Certin B.V.  
Person responsible: M.Ph.D. Schmidt

Applicant and  
Manufacturer

Thames Side Sensors LTD.  
Unit 10, io Trade Centre, Deacon Way, Reading  
Berkshire RG30 6AZ  
United Kingdom

Identification of the  
certified type

A **bending beam load cell**, with strain gauges.  
Registered trade name : Thames Side  
Type : T16

Characteristics

See next page

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

**OIML R 60-1:2017** for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified.  
This Certificate does not bestow any form of legal international approval.

*Important note:* Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority

**NMi Certin B.V., OIML Issuing Authority NL1**  
29 April 2024

Certification Board

NMi Certin B.V.  
Thijssseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 6362332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at [www.oiml.org](http://www.oiml.org)

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon on top of the electronic version of this certificate.





# OIML Certificate

**OIML Member State**  
The Netherlands

Number R60/2017-A-NL1-23.31 revision 1  
Project number 3806206  
Page 2 of 3

The conformity was established by the results of tests and examinations provided in the associated reports:

- No. NMI-3613962-01 dated 23 October 2023 that includes 51 pages;
- No. NMI-3739199-01 dated 28 March 2024 that includes 49 pages.

## Characteristics of the load cell:

Characterization of load cell capabilities	Analog-passive load cell	
Maximum capacity ( $E_{\max}$ )	5 kg up to 10 kg	10 kg up to and including 50 kg
Minimum dead load	0 kg	
Accuracy Class	C	
Rated Output	2 mV/V $\pm$ 10%	
Maximum number of load cell intervals (n) <sup>(1)</sup>	2400	4000
Ratio of minimum LC Verification interval <sup>(1)</sup> $Y = E_{\max} / v_{\min}$	8300	15000
Ratio of minimum dead load output return <sup>(1)</sup> $Z = E_{\max} / (2 * DR)$	2400	4000
Input impedance	400 $\Omega \pm$ 30 $\Omega$	
Temperature range	-10 $^{\circ}$ C / +40 $^{\circ}$ C	
Fraction $p_{LC}$	0,7	
Humidity Class	CH	
Safe overload	150 % of $E_{\max}$	
Output impedance	350 $\Omega \pm$ 5 $\Omega$	
Recommended excitation	10 V AC / DC	
Excitation maximum	15 V AC / DC	
Transducer material	Aluminium	
Atmospheric protection	Hermetically welded	

Remark:

1. The characteristics for  $n_{\max}$ , Y and Z can be reduced separately.

Each load cell produced is provided with an accompanying document with information about its characteristics.

The above identified Type (represented by the sample(s) identified in the OIML Test Report) have been found to comply with the additional national requirements established by the United States of America (NIST Handbook 44 and NCWM Publication 14), included in the Utilizer Declaration:

- R 60 OIML-CS rev.2 Additional requirements from the United States Accuracy class III L;
- R 60 OIML-CS rev.2 Additional requirements from the United States Marking requirements.



**OIML Member State**  
The Netherlands

# OIML Certificate

Number R60/2017-A-NL1-23.31 revision 1  
Project number 3806206  
Page 3 of 3

## Revision History

This revision replaces the previous version.

Revision	Date	Change(s)
0	2023-11-13	Initial issue.
1	2024-04-29	Extension of capacity range and improved specifications based on type evaluation report NMI-3739199-01.