



**OIML Member State**

Czech Republic

**OIML Certificate No.**

R76/2006-A-CZ1-24.01

**OIML CERTIFICATE ISSUED UNDER SCHEME A**

**OIML Issuing Authority**

Name: **Czech Metrology Institute**

Address: Okružní 31

638 00 Brno

Czech Republic

Person responsible: Jan Kalandra

**Applicant**

Name: **Charder Electronic Co., Ltd.**

Address: No. 103, Guozhong Rd., Dali Dist.

Taichung City 41262

Taiwan (R.O.C)

**Manufacturer**

Name: **Charder Electronic Co., Ltd.**

Address: No. 103, Guozhong Rd., Dali Dist.

Taichung City 41262

Taiwan (R.O.C)

**Identification of the certified type** *(the detailed characteristics will be defined in the additional pages)*

**Non-automatic weighing instruments**

**type: MS4400I, M-310**

**Designation of the module** *(N/A)*

-

This OIML Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML type evaluation report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

**OIML R 76 Edition (year): 2006**

For accuracy class **III**



This OIML Certificate relates only to metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML Recommendation identified above.

This OIML Certificate does not bestow any form of legal international approval.

The conformity was established by the results of tests and examinations provided in the associated reports:

Test report 6052-PT-R0001-24 and 8551-PT-E0027-24.

OIML type evaluation report No. 0511-ER-N136-23 dated 4 April 2024 that includes 10 pages

The technical documentation relating to the identified type is contained in documentation file:

0511-UL-N136-23

#### **OIML Certificate History**

<b>Revision No.</b>	<b>Date</b>	<b>Description of the modification</b>
	10 April 2024	Issuing certificate

#### **The OIML Issuing Authority**

RNDr. Pavel Klenovský  
Head of Certification Body

Date: 10 April 2024



**Important note:** Apart from the mention of the Certificate's reference number and the name of the OIML MemberState in which the Certificate is issued, partial quotation of the Certificate and of the associated OIML type evaluation report(s) is not permitted, although either may be reproduced in full.

### Characteristics of the instrument

Non-automatic weighing instrument. Single interval class III. The instrument is designed as a single range non-automatic weighing instrument. Principle of measurement is that the analogue signal from one load cell is amplified and converted to a digital value.

### Main metrological characteristics

Max.	$\leq 20 \text{ kg}$
n	$\leq 2000$
e	$\geq 10 \text{ g}$
T	$\leq - \text{Max}$
Single range	
Accuracy class	III
Temperature range	0°C to + 40°C

### Main parts

#### Electronic part

The mechanical part consists of the indicating and processing unit connected to a load cell. The design of the unit is described in picture 1 below.



Picture 1 Indicating and processing unit

#### Mechanical part and load cell:

The mechanical part consists of the S – hook connected to a single point load cell.

#### Load cell

Manufacturer	Type	Test certificate
Charder Electronic Co., Ltd.	AL-2131	Non

$E_{\text{max}} = 20\text{kg}$

4-wire connection

### Main characteristic and functions

- Indication stabilization device
- semi-automatic zero setting - up to 4% Max
- zero tracking
- subtractive tare - up to - Max
- zero indication
- gravity compensation feature
- overload - at overload over 9e, the indicator displays "Err"

### Interface


Bluetooth (optional).

### Software

The scales are equipped with embedded software in IC and cannot be modified or uploaded via any interface. After turn on the software identification occurs. The software version is P 1.xx (xx is a number between 01~99)

### Securing components and verification marks

The main plate is secured against removal or shall be destroyed when tried to be removed. Access to test pin for calibration is secured:



The event counter value can be displayed after pressing [ON/OFF/ZERO] key.

The inscriptions contain the value of the event counter at the time of conformity assessment.

The gravity compensation mode is secured with a password and event counter that increments each time any parameter change or adjustment is made and saved.