







Number R76/2006-A-NL1-22.03 revision 1 Project number 3749298 Page 1 of 3

Issuing authority NMi Certin B.V.

Person responsible: M.Ph.D. Schmidt

Applicant and Mettler Toledo GmbH Manufacturer

Im Langacher 44 8606 Greifensee **Switzerland**

Identification of the certified type

An Indicator / terminal

Type: IND700

Characteristics See next page



This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

OIML R 76-1:2006 for accuracy class II or III or III

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.



Issuing Authority

NMi Certin B.V., OIML Issuing Authority NL1 9 February 2024



NMi Certin B.V. Thiissewea 11 2629 JA Delft The Netherlands T +31 88 6362332 certin@nmi.nl www.nmi.nl

provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon on top of the electronic version of this certificate.







Certification Board This document is issued under the





OIML Member State The Netherlands



Number R76/2006-A-NL1-22.03 revision 1 Project number 3749298 Page 2 of 3

OIML Certificate

The conformity was established by the results of tests and examinations provided in the associated reports:

- No. NMi-2657900-01 dated 12 April 2022 that includes 41 pages;
- No. NMi-2657900-02 dated 12 April 2022 that includes 20 pages.

Characteristics of the indicator / terminal:

Configuration	Analog load cells	Digital load cells or weighing module	
Accuracy class	Or O	II or III or III	
Weighing ranges	Single interval Multi-interval Multiple range	Single interval Multi-interval Multiple range	
Maximum number of scale intervals (one weighing range)	n ≤ 6000	n ≤ 100000	
Maximum number of scale intervals for multi-interval (per partial weighing range)	n ≤ 6000	n ≤ 100000	
Maximum number of partial weighing ranges	3	3	
Maximum number of scale intervals for multiple range (per weighing range)	n ≤ 6000	n ≤ 100000	
Maximum number of weighing ranges	3	3	
Load cell excitation voltage	10 V DC	-	
Load cell power supply voltage		12 V DC provided by IND700 or 24 V DC by external power supply	
Minimum signal input voltage	U _{min} = 0 mV	-	
Minimum input voltage per verification scale interval	0,5 μV	-	
Minimum load cell resistance	43 Ω	-	
Maximum load cell resistance	3300 Ω	-	
Fraction of the maximum permissible error	0,5	0	
Load cell interface	6-wire with sense technology, may be configured as 4-wire	- (







OIML Member State

The Netherlands



Number R76/2006-A-NL1-22.03 revision 1 Project number 3749298 Page 3 of 3

OIML Certificate

Maximum value of the cable length per cross wire section between the indicator and the junction box or load cells	153,9 m/mm ² In case sense technology is not used the load cells are connected directly without junction box or extension cable			<u>-</u>			
Maximum number of load platforms			2			2	
Temperature range				-10 °C / +4	10 °C		
Power supply voltage	100 - 240 V AC 50/60 Hz						

Software:

- The identification number will be displayed by pressing the metrology status icon at the top of the display area of the touch display;
- The indicator/terminal has loadable software and runs on a Windows operating system;
- See below table for details:

Softwar	e Module	Version	Remarks		
Boot Service	Version	V4.y.xx or 4.y.xx V5.yy.xxx or 5.yy.xxx			
	Thumbprint ID	B827409295			
Capla Cam		V4.y.xx	The letters x and y are not		
Scale Server		5.yy.xxx	relevant for legal metrology and can be represented by		
Analog s	cale module	V1.x.yy	numbers or letters.		
SICSpro r	nodule	V1.x.yy			
Scale mo	dule POWERCELL	V4.x.yy			

Revision History

This revision replaces the previous version.

Revision	Date	Change(s)
0	2022-04-12	Initial issue.
1	2024-02-09	Adding new Boot Service and Scale Server version. Correction of the software version number format.