



Working DRAFT OIML/ICD R139-2

Date: 2 May 2012

Reference number: TC8/SC7/036/1CD

Supersedes document: TC8/SC7-p4b-02
(2WD R139-2)

OIML TC8 / SC7

Title: **Project p4**

**Draft Revision OIML R 139
Compressed gaseous fuel measuring systems
for vehicles**

Secretariat: The Netherlands

Circulated to P- and O-members and liaison
international bodies and external organizations
for:

☐

discussion at (date and place of
meeting):

☒

comments by: 6 August 2012

☐

vote (P-members only) and comments
by

TITLE OF THE CD (English):

OIML R 139-2

Compressed gaseous fuel measuring systems for vehicles

Part 2: Metrological controls and performance tests

TITRE DU CD (French):

OIML R 139-2

Ensembles de mesurage de gaz comprimé pour véhicules

Partie 2: Contrôles métrologiques et essais de performance

Original version in: English

Explanatory note

Temporary section to be removed in the last phase of the revision

See explanatory note in Part 1.

Transposition of OIML R 139 (2007) into this CD

Temporary section to be removed from later Drafts

See table in 1CD Part 1

Contents

Compressed gaseous fuel measuring systems for vehicles.....	4
Part 2 - Metrological controls and performance tests	4
16 Metrological controls	4
16.1 General (New)	4
16.2 Responsibility for compliance with the requirements (New)	4
16.3 Uncertainty (8)	5
17 Instrument Evaluation (New).....	5
17.1 Examinations	5
17.1.2 Software evaluation	6
17.2 Performance tests on the measuring system	7
18 Type evaluation	14
18.1 Submission of assembly	14
18.2 Submission of documentation for type evaluation (8.1.2)	15
18.3 (B.3) Overview of accuracy tests during type evaluation.....	17
18.4 (B.3.1) Tests applicable to the Meter.....	20
18.5 Tests applicable to the measuring system.....	20
18.6 (B.3.4) Specific provisions	21
18.7 Execution of initial tests	22
18.8 Execution of tests under rated operating conditions ("Influence tests") (A.4)	23
18.9 Applying potential disturbances (A.4).....	27
18.10 Type evaluation report.....	35
18.11 Testing of modules	35
19 Initial verification.....	37
19.1 General considerations (New)	37
19.2 Legal status of the instrument submitted for verification (New)	37
19.3 Initial verification in one stage	38
19.4 Initial verification in two stages (8.2.2.1)	38
19.5 Examination at initial verification (New)	38
19.6 Tests at initial verification	39
19.7 Verification marks, seals and document (New)	40

20	Subsequent verification (8.3, B.5, new)	41
20.1	Examination before subsequent verification (Template 15.1.1/16.2)	41
20.2	Tests at subsequent verification (B.5) (Template 15.1.2/16.3)	41
Annex A (C)		42
Annex B (D)		44
B.1	Scope (D.1)	44
B.2	Preliminary considerations (D.3)	44
B.2.1	(D.3.1) Low flow cut-off	44
B.2.2	(D.3.2) No-flow conditions	44
B.2.3	(D.3.3) Temperature measurement	44
B.2.4	(D.3.4) Pressure measurement	45
B.2.5	(D.3.5) Warm up time	45
B.2.6	(D.3.6) Coriolis sensor	45
B.2.7	(D.3.7) Coriolis transducer	45
B.2.8	(D.3.8) Zero-setting	45
B.3	Test methods (D.4)	46
B.3.1	(D.4.1) Categories of test methods for influence factors at type evaluation	46
B.3.2	(D.4.2) General principle	46
B.3.3	(D.4.3) Before starting tests	46
B.3.4	(D.4.4) Specific aspects of the test method for influence factors	47
B.3.5	(D.4.5) Specific aspects of the test method for disturbances	47
B.3.6	(D.4.6) Specific aspects of the test method for the gas influence factors	47
Annex C: Description of selected validation methods		48
C.1	Analysis of Documentation and Specification and Validation of the Design (AD)	48
C.2	Validation by Functional Testing of the Metrological Functions (VFTM)	48
C.3	Validation by Functional Testing of the Software Functions (VFTSw)	48
C.4	Metrological Dataflow Analysis (DFA)	49
C.5	Code Inspection and Walk Through (CIWT)	49
C.6	Software Module Testing (SMT)	49

Compressed gaseous fuel measuring systems for vehicles

Part 2 - Metrological controls and performance tests

16 Metrological controls

16.1 General (New)

In general (depending on national or regional legislation), legal metrological control can consist of type approval, initial and subsequent verification, and metrological supervision.

This Part gives general guidelines for each of these steps.

16.2 Responsibility for compliance with the requirements (New)

16.2.1 (New) Notwithstanding the kind of legal metrological control in a country, the manufacturer (or his formal representative) has the full responsibility that the instruments comply with the requirements in Part 1 at the moment they are delivered to the user.

16.2.2 (New) After assignment, the owner of the instrument has the responsibility that the instrument is well maintained and complies with the requirements in Part 1 as long as the instrument is in use. The operational presence of the instrument in his premises is considered as “in use”.

Particular attention shall be paid to the future recovery of stored data (see 6.3.1).

16.2.3 (8.1.4) Modification of an approved type

16.2.3.1(8.1.4.1) The beneficiary of the type approval shall inform the body issuing the approval of any modification or addition which concerns an approved type.

16.2.3.2(8.1.4.2) Modifications and additions shall be subject to a supplementary type evaluation when they influence, or are likely to influence, the measurement results or the instrument's regulatory conditions of use.

The body having approved the initial type shall decide to which extent the examinations and tests described below shall be carried out on the modified type in relation with the nature of the modification.

16.2.3.3(8.1.4.3) When the body having approved the initial type judges that the modifications or additions are not likely to influence the measurement results, this body allows in writing the modified instruments to be presented for initial verification without granting a supplementary type approval. A new or supplementary type approval must be issued whenever the modified type no longer fulfils the provisions of the initial type approval.

16.2.3.4 The manufacturer may be granted permission to replace hardware elements which cannot influence the characteristics or the performance of the measuring systems merely comprising binary electric circuits (so called purely binary or digital elements) by other functionally-equivalent elements without having to submit the measuring instrument as to demonstrate that it continues to operate as designed. The manufacturer will be kept responsible regarding the continuation of operation under rated conditions specified. These hardware elements are to be identified during type evaluation and registered as such in the type approval certificate.

16.2.4 Application of the measuring system (2.3.4)

A measuring system shall exclusively be used for measuring gas having characteristics within its field of operation, as specified by the manufacturer and been validated during type evaluation, like stated in the type approval certificate. (see 8.2, q),

The field of operation of a measuring system shall be within the fields of measurement of each of its constituent elements, in particular the meter.

16.3 Uncertainty (8)

When a test is conducted, the expanded uncertainty¹ on the determination of errors on indications of mass shall be:

- for type evaluation :less than one-fifth of the applicable MPE;
- for verifications :less than one-third of the applicable MPE.

However, if the above-mentioned criteria cannot be met, the test results can be approved alternatively by reducing the applied maximum permissible errors with the excess of the uncertainties. In this case the following acceptance criteria shall be used:

- for type evaluation : $\pm(\% \cdot MPE - U)$
- for verifications : $\pm(\% \cdot MPE - U)$

while $U \leq MPE$

The estimation of expanded uncertainty U is calculated according to the Guide to the expression of uncertainty in measurement (GUM) [8] applying a coverage probability which corresponds the application of a coverage factor $k = 2$ for a normal distribution and which comprises approximately 95% of the measurement results in average.

This provision concerning the acceptable uncertainty versus maximum permissible error may not be fulfilled up to twice the minimum measured quantity.

Note: For calculation of the uncertainty the uncertainty contributions related to the EUT need to be taken into account, in particular the scale interval and, if applicable, the intrinsic instability at zero flow. The repeatability error of the EUT however shall not be included in the uncertainty.

In the case of repeatability tests (not performed in conjunction with accuracy tests), the above ratios apply to the stability of standards.

The working standards and their use will be the subject of specific International Documents as far as necessary.

17 Instrument Evaluation (New)

Examinations and testing of measuring instruments are intended to verify compliance with the requirements laid down in Part 1 of this Recommendation.

(New) If a specimen does not pass a specific part of the examination or test and as a result needs to be modified or repaired, the applicant shall apply this modification to all the specimens submitted for the test. These modified specimen(s) shall again be subjected to this particular test. If the testing laboratory has well-founded reasons to believe that the modification could have a negative impact on the result of another test or tests already performed, these tests shall be repeated as well.

17.1 Examinations

The instrument and the documentation shall be inspected as to obtain a general appraisal of its design and construction and the documentation shall be studied.

17.1.1 Design examination (8.1.9.1)

¹ As defined in OIML G 001-100 clause 2.3.5

The design examination aims at verifying that the design of devices and their checking facilities comply with the provisions of this Recommendation.

In general, it includes:

- a) an examination of the construction and of the electronic sub-systems and components used as to verify their appropriateness for their intended use,
- b) taking into consideration the faults likely to occur in order to verify that in all considered cases these devices comply with the provisions of 6.10,
- c) verification of the presence and effectiveness of the test device(s) for the checking facilities.

More in particular, the conformity to the referred requirements regarding the following aspects shall be examined:

- a) presentation of the measuring result (5.1, 6.2);
- b) measuring range (5.3);
- c) environmental classes and rated operating conditions (5.5);
- d) construction (6.1);
- e) price indicating device (6.2.8);
- f) printing device (6.2.9);
- g) storage of measuring results (6.3);
- h) data transmission (6.4);
- i) zero setting device (6.5);
- j) pre-setting device (6.6);
- k) calculator (6.7);
- l) emergency power supply device (6.8);
- m) protection against fraud (6.9);
- n) checking facilities (6.10);
- o) software (6.11);
- p) guarantee of delivery of the measured quantity. (6.14.3).
- q) inscriptions (7);
- r) verification of contents of instruction manual (8);
- s) sealing (9);
- t) stamping plate (10);
- u) suitability for testing (11);

17.1.2 Software evaluation

The software evaluation procedure concerns evaluation of compliance to the requirements as described in part 1 Annex A and comprises a combination of analysis and validation methods and tests as shown in Table 2.1. The explanation of the abbreviations used and the relation to the methods as described in detail in OIML D 31 is shown in Table 2.2.

Table 2.1 Software validation procedures applicable for verification of compliance to the software requirements

Requirement	Evaluation procedure
-------------	----------------------

A.1.1	Software identification	AD + VFTSw
A.1.2	Correctness of algorithms	AD + VFTSw
A.1.3	Fraud protection	AD + VFTSw + DFA/CIWT/SMT
	Parameter protection	AD + VFTSw + DFA/CIWT/SMT
A.2.1	Separation of electronic devices and sub-assemblies	AD
A.2.2	Separation of software parts	AD
A.2.3	Storage of data, transmission via communication systems	AD + VFTSw + CIWT/SMT
A.2.3.1	Data protection with respect to time of measurement	AD + VFTSw + SMT
A.2.4	Automatic storing	AD + VFTSw
A.2.3.4	Transmission delay	AD + VFTSw
A.2.3.5	Transmission interruption	AD + VFTSw
	Time stamp	AD + VFTSw

Table 2.2 Cross references of evaluation procedures to those described in Annex C and detailed in OIML D 31

Abbreviation	Description	Related Annex C and OIML D 31:2008 Clause
AD	Analysis of the documentation and validation of the design	Annex C (C1) → D 31 (6.2.3.1)
VFTM	Validation by functional testing of metrological functions	Annex C (C2) → D 31 (6.2.3.2)
VFTSw	Validation by functional testing of software functions	Annex C (C3) → D 31 (6.2.3.3)
DFA	Metrological data flow analysis	Annex C (C4) → D 31 (6.2.3.4)
CIWT	Code inspection and walkthrough	Annex C (C5) → D 31 (6.2.3.5)
SMT	Software module testing	Annex C (C6) → D 31 (6.2.3.6)

17.2 Performance tests on the measuring system

The instrument shall be submitted to performance tests to determine its correct functioning under various conditions.

(8.1.8) The execution of performance tests on the measuring system comprises the verification that constituent elements of the system, not yet been subjected to separate type evaluation, satisfy the applicable requirements, even in those cases where a separate type evaluation is not requested.

It also includes the verification that in any case these constituent elements are compatible. However when the measuring system contains a not yet approved meter, it is only possible to perform tests on the complete system, like specified in the sub clauses of clause 17.2.5 (Annex B) (without prejudice of having to perform the influence quantity tests specified in the sub clauses of clause 18.8 (Annex A) on the calculator).

The tests to be performed for obtaining the type approval for a measuring system shall therefore be determined on the basis of the type approval certificates already granted for the constituent elements of the system.

When none of the constituent elements has ever been submitted for a separate type evaluation all of the tests laid down in this Recommendation shall be performed on the complete measuring system or, where applicable, on specific devices .

In case the various constituent elements have all been evaluated and approved separately, it is possible to restrict to examination of documentation only. However, a functional test of the

complete measuring system should always be performed in particular at the lowest temperature intended for all components of the gas piping.

It is also acceptable to reduce the type evaluation program when the measuring system includes constituent elements identical to those which equip another measuring system that has already been approved, and when the operating conditions of these elements are identical.

Note: It is advisable that constituent elements be subject to separate type evaluation when these are intended to equip several types of measuring systems. This is particularly recommended when the manufacturers of the various measuring systems are not identical and/or different bodies are in charge of the type evaluations.

17.2.1 Simulation and testing modules

(New) As a general rule, tests shall be carried out on a complete measuring system or module, which is to be submitted for evaluation. This specimen shall represent a single type. Simulation of any part of the specimen to be tested should be avoided. In case the latter cannot be avoided, at least all parts of the instrument that could be affected by a test and which play an active role in the measurements shall be part of the assembly submitted for the applicable test.

If the size or configuration of the measuring instrument does not permit specific or all tests to be executed on the instrument as a whole, or if only a separate module (see 18.11) of the measuring instrument is concerned, the tests, or the specific tests, shall be carried out on the modules separately, provided that these devices are included in a simulation set-up which is proven valid to represent the normal operation. *Note: As a general rule, the dismantling of the measuring instruments or devices for the tests is to be avoided.*

17.2.2 (8.1.9.3) Assembly required for performance tests

Except in those cases specified in the sub clause 17.2.1 tests are to be performed on a complete measuring system where size and configuration permit.

In those cases where tests are not performed on a complete system, they shall be carried out on a sub-system comprising at least the following devices:

- a) measurement transducer;
- b) calculator;
- c) indicating device;
- d) power supply device;
- e) correction device, if appropriate.

This sub-system shall be included in a simulation set-up which is representing the normal operational of the measuring system. For example, the movement of the gas may be simulated by an appropriate device.

The calculator shall be in its final housing with all inputs and outputs connected and all peripheral equipment switched on.

In all cases, peripheral equipment may be tested separately.

17.2.3 Intermediate adjustments while performing tests

(8.1.1) A measuring system shall be capable of fulfilling the requirements without adjustment of the system or of its devices during the course of the tests. If an adjustment is carried out, it shall be verified that the measuring system would have been capable of fulfilling the full set of requirements with the new adjustment by restarting tests and/or recalculating errors obtained before adjustment if the corresponding tests are not performed again.

17.2.4 Preparations and preconditions for performance tests (B, B.1, B.2, B.3)

17.2.4.1 General considerations (Preliminary note)

In general, the major factors affecting the accuracy of compressed gaseous fuel (CGF) measuring systems are:

- a) meter sizes being suitable for the maximum flow obtainable applying the refueling system to which it is fitted.

Note: Higher flow rates will occur at the beginning of the refueling and just after each bank switching. Testing up to the measuring system's specified allowed maximum flow capacity will reveal the effect of meter undersizing,

- b) the quantity value of the measured batch,
- c) the ratio between the contributed low flow rate proportions and the total gas quantity delivered in a refueling transaction.

Note: These low flow rates will occur prior to bank switching and just before the very end of the refueling. Larger low flow rate proportions may reduce the meter accuracy.

- d) sudden flow acceleration and deceleration originating from interventions by the sequential control device.

The tests specified in the following sub clauses will take into account the influence of these potential accuracy reducing sources.

17.2.4.2 Test setup (B.1)

17.2.4.2.1 (B.1.1) Indicative volumes for the test receiver (representing the vehicle fuel storage system) are:

- a) 90 L minimum for testing low capacity meters (up to 30 kg/min).
Though 50 L may be accepted provided the test volumes fulfill the appropriate provisions specified in this Recommendation (which require at least 1000 scale intervals).
- b) 300 L minimum for medium capacity meters (from 30 kg/min to 70 kg/min).
- c) 600 L minimum for high capacity meters (above 70 kg/min).

The sizes of pipe work and valves utilized on the test receiver shall be adequate and at least equivalent to those normally utilized on the category of vehicles for which the measuring system is intended. In this context "low capacity", "medium capacity" and "high capacity" meters are intended for the refueling of cars, medium weight trucks and heavy duty vehicles (e.g. large trucks and buses) respectively.

17.2.4.2.2 (B.1.2) The test reservoir, representing the refueling station fuel storage system, shall during a fast filling of the vehicle be capable to supply the gas at the allowed maximum gas pressure (P_v) at the end of the test

Indicative volumes for the test reservoir are:

- a) 800 L for low capacity meter tests;
- b) 1600 L for medium capacity meter tests;
- c) 2400L for high capacity meter tests.

In each flow test, while taking into account the criteria specified in sub clause 17.2.4.2.4 (B.1.4), the actual test reservoir volume(s) used shall ensure that, within the last 20 seconds of filling, the test flow rate drops to 120 % or less of the specified minimum flow rate of the meter or of the measuring system. In order to fulfill these criteria it may be necessary in certain test conditions, to adjust the reservoir volume before starting the test, for example by closing some valves on the test reservoir cylinders.

Where a sequential control device is used, these conditions apply to the high (last) bank (refer to 17.2.4.2.4 (B.1.4)).

The above provision does not apply where the meter or the measuring system is designed to stop the flow when the flow rate decreases to below Q_{\min} and where the test is performed until the flow stops.

Information on the actual test reservoir volume used during the type evaluation tests shall be presented in the type approval certificate

Note: The rationale for this last test reservoir volume criterion is to prevent the flow test to end at a flow rate significantly higher than the specified minimum measuring system flowrate and thus missing the possible poor meter performance at the low flows.

17.2.4.2.3 (B.1.3) The sizes of pipe work and valving of the test rig shall be such that the flow capacity of the meter or measuring system will not be reduced when being connected to the test rig. In addition, unless otherwise agreed to by the measuring system's manufacturer, the test rig's control system shall be such that the maximum gas flow rate obtainable during testing will not exceed the measuring system's specified allowed maximum gas flow rate.

17.2.4.2.4 (B.1.4) Where relevant (see 17.2.5.2 (B.2.2)), the test reservoir volume shall be subdivided into 3 compartments. a volume ratio of 2:1:1 for the low bank, medium bank and high bank respectively is recommended. The test rig shall include a refueling sequential control device, piping and valving suitable for generating the specified maximum and minimum flow rates of the measuring system.

Notes: 1) The use of a common test rig for many meter sizes (flow capacities), may be possible when allowing for necessary adjustments or modifications in the test rig configuration.

2) The receiver volumes have been selected to reasonably represent a range of onboard CGF storage sizes of the different vehicle fuels capacities, and to minimize test equipment for cost and handling reasons.

3) The presented ratio of the test reservoir bank volumes is, up to a reasonably high degree, the typical representation of many actual conditions of use of refueling systems at the major storage stations.

17.2.4.2.5 (B.1.5) Simulated signals and or any fluid other than the one intended to be measured may be used for testing providing they do not influence the judgment on measuring results. If necessary, corrections shall be applied.

Nitrogen may be used instead of natural gas without corrections

17.2.5 (B.2) Types of measuring systems and associated accuracy test methods

For the purpose of tests, three types of measuring systems are considered:

- a) measuring systems utilizing a sequential control device of a refueling station;
- b) measuring systems that already incorporate their own sequential control device;
- c) measuring systems for refueling stations not utilizing a sequential control device.

The sequential control device of the test rig shall not be used for testing measuring systems of types b and c.

The following test program is appropriate for current technologies and may require adaptations in case of new technology

In all the following tests the pressure in the test receiver at the end of the test shall be P_v (the allowed maximum vehicle fast fill pressure) .

17.2.5.1 Tests at variable flow rate (new)

The flow rate of the gas in a measuring system varies during the course of a delivery. The flow rates' curve depends on the available supplying conditions. This results in a variety of operating conditions for a measuring system. For the CGF dispenser for vehicles the variety of operating conditions (filling curves) per delivery is limited as a consequence of the limited tank (vessel) volume the compression needed for sufficient storage efficiency and required safety. Taking this into account repetitive testing of such system by simulating these variable operating conditions is deemed to provide sufficient proof of accuracy.

Testing shall be carried out in the following sequence and under following conditions. Each bank shall be activated in the course of each test:

Table 2.3 variable flow rate testing	
Phase 1	<ul style="list-style-type: none"> Initial test receiver pressure of 0 kPa Initial station storage pressure of P_{stl} in the low pressure bank Connect nozzle Record initial mass indication of reference weighing instrument used Alternatively set mass indication to zero Start time registration at starting of the delivery Fill the testing vessel up to about the percentage of the mass capacity established for the low pressure phase Stop filling and time registration at the same instance Disconnect the nozzle, Record the indication of the weighing instrument, dispenser and time registration.
Phase 2	<ul style="list-style-type: none"> See to it that the initial station storage pressure is as established for the medium pressure bank Reconnect the nozzle and follow the same sequence as in phase 1, filling the testing vessel up to the percentage of mass capacity established for the medium pressure phase
Phase 3	<ul style="list-style-type: none"> See to it that the initial station storage pressure as established for the high pressure bank Reconnect the nozzle and follow the same sequence as in phase 1, filling the testing vessel up to the percentage of mass capacity established for the high pressure phase

17.2.5.1.1 Tolerance on batch sizes

The tolerance to be applied to the mentioned percentages of the maximum capacity of the test cylinders is $\pm 5\%$

17.2.5.2 (B.2.2) Accuracy tests involving three banks

Measuring systems (MS) tested with three banks may be used in all situations, regardless of the total number of banks (1, 2, 3, 4...).

The proposed procedure may be adapted by national Authorities, in particular for tests on site of use and/or taking into consideration the specific design of filling stations.

17.2.5.2.1 (B.2.2.1) Three bank testing shall be carried out under the following set of conditions, where P_{st} is the maximum station storage pressure and P_v the maximum allowable vehicle fast fill pressure. Each bank shall be activated in the course of each test:

Table 2.4	
Test 1	Initial test receiver pressure of 0 kPa

	Initial station storage pressure of P_{st} in all banks
Test 2	Initial test receiver pressure of $0.5 \times P_v$ Initial station storage pressure: <ul style="list-style-type: none"> - high bank at P_{st}, - medium bank at close to P_v, - low bank at $0.75 \times P_v$.
Test 3	Initial test receiver pressure of $0.75 \times P_v$ Initial station storage pressure: <ul style="list-style-type: none"> - high bank at P_{st}, - medium bank at close to P_v, - low bank at $0.75 \times P_v$.

17.2.5.2.2 (B.2.2.2) The bank volumes shall be such that refueling into the specified test cylinders will cause the activation of all stages of the operation of the refueling sequential control device. Where a sequential control device is not included in a measuring system, it shall complete the switching action from one bank to another within 3 s. Where a sequential control device is included in a measuring system, it shall complete the switching action from one bank to another within the minimum possible delay as designed by the manufacturer (if relevant). Where relevant the maximum allowed speed (the tested one) shall be specified in the type approval certificate.

In each filling phase the mass quantity shall be at least twice the minimum measured quantity.

The average maximum, medium and minimum flow rates are calculated through dividing the sequential measured masses by the applicable recorded filling time period.

The test volume ratio of receiver test reservoir and storage bank shall be as specified in 17.2.4.2.1 (B.1.1), 17.2.4.2.2 (B.1.2) and 17.2.4.2.4 (B.1.4). It may be necessary to close some valves on the test reservoir cylinders to achieve the required test reservoir volume and bank proportions.

17.2.5.3 (B.2.3) Accuracy tests involving only one bank

Tests without sequential controls shall be performed in the following conditions:

Table 2.5	
Test 4	Initial test receiver pressure of 0 bar Initial station storage pressure at P_{st}
Test 5	Initial test receiver pressure of $0.5 \times P_v$ Initial station storage pressure at P_{st}
Test 6	Initial test receiver pressure of $0.75 \times P_v$ Initial station storage pressure at P_{st}
Test 7 (minimum measured quantity)	The conditions for test 6 are adapted in order to test the minimum measured quantity. For this purpose, the pressure does not have to be P_v in the test receiver at the end, but may be any pressure (as close as practical to P_v) such that the quantity of transferred gas shall be at least the minimum measured quantity.

For tests without bank switching, the test reservoir pipework can simply be changed so that all test reservoir cylinder banks are joined together, i.e. there are no high, medium or low banks; the reservoir in this case is a uniform station storage pressure system.

17.2.5.4 (B.2.4) Tolerance on gas pressure

The tolerance to be applied to all test pressures is ± 1 MPa

17.2.5.5 (B.2.5) Durability test

It is recommended to perform the durability test on site in real conditions of use. It shall involve at least a total mass equal to 100 hours running at 0,8 Q_{max} performed in less than six months.

When the durability test is performed in a laboratory, it consists in performing a total mass of gas equal to 100 hours running at 0,8 Q_{max}, representing the real use and at least involving an action of the sequential control device where relevant. The test recommended is test 1 (table 2.4) or test 4 (table 2.5), depending on whether the measuring system is intended to operate with or without a sequential control device.

After the durability test, the meter is again subjected to the following tests.

For meters or measuring systems utilizing a sequential control device, test 1(2.4) shall be performed at least 3 times.

For meters or measuring systems not using a sequential control device, test 4 (table 2.5) shall be performed at least 3 times.

The mean value of the corresponding initial intrinsic errors is calculated. The mean value of the corresponding errors after the durability test is calculated. The deviation between these two values shall remain within the limit specified in 3.1.7.

The repeatability shall meet the requirement of 5.4.2 (3.1.6).

Note: National authorities may have the possibility to authorize the provisional use of instruments subjected to type approval for specific test purposes (after demonstration of an acceptable performance in laboratory).

17.2.5.6 (B.2.6) Testing the gas influence factors

Tests should be carried out at the limits of the meter's field of operation, i.e. at the limits of possible pressure, temperature and density for the gas.

The test lab may have the ability to validate alternative test methods and procedures and make use of these for testing gas influence factors.

In that case evidence of validity of the test method shall be provided in the test report, showing that the performance criteria are met. Such alternative method is only acceptable as long as the rationale comprises a fully documented justification on the reason for use of the alternative and proof that testing practices are applied within reasonable state-of-the-art

Annex B (D) gives information on a substitution test method for Coriolis meters. This information is only indicative and may not apply to all technologies and designs of meters.

The manufacturer shall specify and establish the validity of gas temperatures when operating in the specified range of ambient temperatures.

If the influence of the temperature of the gas needs to be tested according to this Annex, the following tests are performed for each temperature limit:

- a) Test 1 for measuring systems utilizing a sequential control device (types a and b);
- b) Test 4 for measuring systems for refueling stations not utilizing a sequential control device (type c).

In tests at the temperature limits, at least the meter or measuring system shall be placed in a controlled temperature chamber for a sufficient conditioning time to ensure they are at the intended test temperature prior to the commencement of the test. The gas supply system need not be placed in the temperature chamber provided that the temperature of the gas is at the appropriate temperature limit specified in 15.1.1 (4.1.1) within a tolerance of ± 5 °C.

Considerations on temperature may be transposed to pressure and density of the gas.

For the performance of temperature tests a liquid instead of a gas may be used. In this case there is no need for providing evidence about the similar behavior of the liquid and the gas

17.2.5.7 (B.2.7) Specific tests

If expected of critical influence on the basis of measuring principle the following tests shall also be carried out:

- a) determination of the zero stability;
- b) tests with flow disturbances.

For tests with flow disturbances, the applicable maximum permissible errors are those specified for the measuring system and not those fixed for the meter. These tests are performed in accordance with the state of the art (see in particular relevant ISO Standards), taking into consideration:

- c) flow disturbances existing in real life refueling station equipment;
- d) design of meters and measuring systems;
- e) circumstances which are known to affect their performances.

18 Type evaluation

18.1 Submission of assembly

18.1.1 Number of specimens to be submitted

(8.1.2.3) Type evaluation shall be carried out on at least one specimen, which represents the definitive type. The evaluation shall comprise the examination and tests specified in the sub clauses of 17.1 and 17.2.

Additional samples of the same type may be considered necessary by the body responsible for the type evaluation e.g. to estimate the reproducibility of the measurements.

In case the request for type evaluation concerns several versions of the same type or aims to cover several measuring ranges, the body involved and responsible for the evaluation decides on which version(s) are to be submitted and the range(s) to be selected for the evaluation.

18.1.2 Simultaneous evaluation

(New) In order to accelerate the test procedure, the testing laboratory could carry out different tests simultaneously on different specimens. In this case, the body responsible for the evaluation decides which version or measuring range will be subjected to a specific test, and it shall be verified that all submitted instruments are of the same type and in comparison to the original specimen no additional measures were taken to boost the immunity to the influence quantity.

In principle no more than two additional specimens shall be used for simultaneous evaluation. Table 2.6 specifies which tests may be performed on the additional specimens.

Table 2.6	
Tests that shall be performed on one and the same specimen	Tests that may be divided amongst no more than 2 additional specimens
Repeatability	Ambient temperature test
Dynamic flow	Gas temperature test
One /three bank testing	Pressure test
Durability	Vibration test

	Power supply voltage variation tests Verification of Checking facilities Damp heat Radiated and conducted RF EM Bursts on mains and control lines Surges on mains and control lines <= Dips and interruptions DC Ripple Emergency power? Electrostatic discharge
--	---

18.1.3 Modules which may be accepted for separate type evaluation

(8.1.1) If preferred by the manufacturer, and accepted by the body responsible for type evaluation the following modules of measuring systems may be submitted separately for type testing and approval:

- a) meter (see 18.11.1);
- b) transducer (see 18.11.1);
- c) calculator (including the indicating device) (see 18.11.2);
- d) ancillary devices providing or memorizing measurements results (see 18.11.3);
- e) self-service device (see 18.11.4);
- f) printing devices **(New)** (see 18.11.5);

The constituent elements of a measuring system shall comply with the relevant requirements, even when they have not been subject to separate type evaluation (except, of course, in the case of ancillary devices that are exempted from the controls).

As far as possible the type approval certificate of a constituent element shall contain the necessary metrological information on compatibility with other elements.

18.2 Submission of documentation for type evaluation **(8.1.2)**

18.2.1 General documentation **(8.1.2.1 & 8.1.2.2)**

The documentation submitted with the application for type approval shall include:

- a) description of its general principle of measurement;
- b) (mechanical) drawings and/or photographs;
- c) electric/electronic diagrams;
- d) lists of the essential sub-assemblies/modules, components (in particular electronics and other essential ones) with their essential characteristics;
- e) functional description of the various electronic devices;
- f) a flow diagram of the logic, showing the functions of the electronic devices;
- g) for measuring systems and meters fitted with correction devices, a description of how the correction parameters are determined;
- h) an assembly drawing with identification of different components;
- i) drawing(s) presenting the security sealing plan and the provisions and location for verification marks;
- j) drawing of regulatory markings;
- k) general information on the software required for a micro-processor equipped measuring instrument.

In particular the requirement 5.3 shall be covered;

- l) test in- or outputs, their use, and their relationships to the parameters being measured;
- m) installation requirements;
- n) operating instructions that shall be provided to the user,
- o) If applicable: the references of the approval certificates of the constituent elements;
- p) an overview of any purely digital elements that are considered to be replaceable (in accordance with the note in 5.5.2);
- q) documents or other evidence that supports the assumption that the design and characteristics of the instrument comply with the requirements of this Recommendation.

18.2.2 Software documentation

For type evaluation, the manufacturer of the measuring system shall explain and document all program functions, relevant data structures and software interfaces of the legally relevant part of the software that is implemented in the instrument. No hidden undocumented functions shall exist.

The commands and their effects shall be described exhaustive in the software documentation to be submitted for type approval. The manufacturer shall state the documentation of the commands being complete. If commands can be entered via a user interface, they shall be described extensively in the software documentation to be submitted for the type approval.

Furthermore, the application for type approval shall be accompanied by a document or other evidence that supports the assumption that the design and characteristics of the software of the measuring system comply with the requirements of this publication.

Typical documentation (for each measuring instrument and/or its constituents) basically includes:

- a) a description of the legally relevant software and how the requirements are met:
 - list of software modules that belong to the legally relevant part including a declaration that all legally relevant functions are included in the description;
 - description of the software interfaces of the legally relevant software part and of the commands and data flows via this interface including a statement of completeness;
 - description of the generation of the software identification;
 - list of parameters to be protected and description of protection means;
- b) a description of security means of the operating system (password, etc. if applicable);
- c) a description of the (software) sealing method(s);
- d) an overview of the system hardware, e.g. topology block diagram, type of computer(s), type of network, etc. Where a hardware component is deemed legally relevant or where it performs legally relevant functions, this should also be identified;
- e) a description of the accuracy of the algorithms (e.g. filtering of A/D conversion results, price calculation, rounding algorithms, etc.);
- f) a description of the user interface, menus and dialogues;
- g) the software identification and instructions for obtaining it from an instrument in use;
- h) list of commands of each hardware interface of the measuring instrument / electronic device / sub-assembly including a statement of completeness;
- i) list of durability errors that are detected by the software and if necessary for understanding, a description of the detecting algorithms;
- j) a description of data sets stored or transmitted;
- k) if fault detection is realized in the software, a list of faults that are detected and a description of the detecting algorithm;
- l) the operating manual.

18.2.3 Specific documentation concerning execution of performance tests

(3.2.2) When the verification of a measuring system or of a meter intended to measure gas may be carried out with air (or with another fluid), this shall be specified by the manufacturer and the validation shall be confirmed by appropriate tests. If necessary in this case, a more restricted range or a shift for maximum permissible errors may be laid down in the type approval certificate, in order to account for deviations and to provide for compliance to the maximum permissible errors for gas.

18.2.4 Additional documentation

More detailed documentation may be required if this is deemed necessary by the type evaluating laboratory, either to be able to study the quality of the instrument, or to be able to lay down the approved type, or both.

18.3 (B.3) Overview of accuracy tests during type evaluation

Table 2.7 (B.2) summarizes the required accuracy tests during type evaluation for various meter and measuring systems according to their configuration, i.e. whether they are used in conjunction with a sequential control system.

In principle all accuracy and influence tests (excluding disturbance tests) shall be performed on one and the same specimen.

Some tests however may need to be performed on site. This can be accepted provided that it is assured that test results will be equivalent to those which would be obtained when the tests were performed under reference conditions.

Table 2.7 (B.2)						
Test	name/ number	All meters	Meter intended for use with sequential control	Measuring system for use with sequential control	Measuring system with adjustable sequential control (test at extreme adjustment limits)	Measuring system for use without sequential control
Test at variable flowrate	Test 0	3x				
Tests with sequential control	Test 1		Optional, 3x	Mandatory, 3x	3x	
	Test 2			Mandatory, 3x		
	Test 3			Mandatory, 3x		
Tests without sequential control	Test 4	3x		2x		3x
	Test 5	3x				3x
	Test 6					3x
	Test 7					2x
Durability		1 x				
Gas influence factors		2 x per type of factor				
Flow disturbances etc.		Optional, 2x	2x if not already done on meter			2x if not already done on meter
Note: 2x = two times, 3x = three times						

18.4 (B.3.1) Tests applicable to the Meter

18.4.1 (B.3.1.1) General considerations concerning the assembly for testing

According to the request of the manufacturer, a type evaluation may be performed and type approval may be granted for a meter alone or any sub-assembly including a meter. However, in any case the test program applicable to meters shall be performed independent on the contents of the request for type approval.

In principle, the meter is tested stand-alone. However, it may be tested in any sub-assembly or a complete measuring system provided it is possible to assume that test results would be equivalent if they were performed on the stand-alone meter.

18.4.2 (B.3.1.2) Test program

1. Tests 0) shall be performed at least 3 times consecutively in the same conditions in order to establish the intrinsic behavior of the meter.
Each individual error shall conform to the MPEs specified in 5.2.1 (3.1.1) for the meter.
The requirement on repeatability specified in 5.4.1 (3.1.5) shall be fulfilled.
2. Tests 4 and 5 (see 17.2.5.3 (B.2.3)) shall be performed at least 3 times consecutively in the same conditions in order to establish the dynamic behavior of the meter.
Each individual error shall conform to the MPEs specified in 5.2.1 (3.1.1) for the meter.
The requirement on repeatability specified in 5.4.2 (3.1.6) shall be fulfilled.
3. The durability test (see 17.2.5.5) (B.2.5) shall be performed.
If the meter is intended to be included in a measuring system utilizing a sequential control device, the test shall be performed so that the meter operates in conjunction with such a device.
In the case of a meter accompanied with a particular sequential control device, this particular device shall be subject to the test associated with the meter. In the case where the result could be dependent on the type of sequential control device (whether it is included in a measuring system) and according to the manufacturer's specifications, the device providing the most severe flow switching effects shall be used. Any appropriate information shall be indicated in the type approval certificate.
The requirement on durability specified in 5.8.2 (3.1.7) shall be fulfilled and the requirement on repeatability specified in 5.4.2 shall be fulfilled.
4. If applicable (see Annex B (D) tests on gas influence factors (see 17.2.5.6) (B.2.6) shall be performed. If the test is applicable, each test shall be performed twice.
If the corresponding tests are not performed reason shall be given in the test report.
The individual registered error values shall not exceed the MPEs specified in 5.2.1 (3.1.1) for the meter.
5. If the manufacturer specifies that the meter is intended to be included in a measuring system utilizing a sequential control device, , test 2 (see 17.2.5.2) (B.2.2) may be performed at least 3 times consecutively in the same conditions.
The corresponding information is laid down in the type approval certificate.
Each individual error shall conform to the MPEs specified in 5.2.1 (3.1.1) for the meter.
The requirement on repeatability specified in 5.4.2 (3.1.6) shall be fulfilled.
6. Where appropriate specific tests (see 17.2.5.7) (B.2.7) may be performed.
If testing is applicable each test shall be performed twice.
The corresponding information is laid down in the type approval certificate.
Each individual error shall conform to the MPEs specified in 5.2.1 (3.1.1) for the meter.

18.5 Tests applicable to the measuring system

18.5.1 (B.3.2) Measuring systems utilizing a sequential control device (type a and type b)

1. Tests 1, 2, 3 shall be performed on the complete system at least 3 times consecutively in the same conditions.

Each individual error shall conform to the MPEs specified in 5.2.1 (3.1.1) for the measuring system.

The requirement on repeatability specified in 5.4.2 (3.1.6) shall be fulfilled.

2. Test 7 shall be performed on the complete system at least twice.
Each individual error shall conform to the MPEs specified in 5.2.4 (3.1.3) for the measuring system.
3. If relevant and not already performed on the meter, specific tests (see 17.2.5.7) (B.2.7) are performed.
If applicable each test shall be performed twice.
Each individual error shall conform to the MPEs specified in 5.2.1 (3.1.1) for the measuring system.
4. For measuring systems that may be used with a sequential control device (incorporated or not) fitted with adjustment parameters, test 1 shall be performed at least 3 times consecutively in the same conditions for each extreme value of the adjustment parameters. When a parameter is tested, other parameters are at reference condition as specified by the manufacturer.
Each individual error shall be conforming to the MPEs specified in 5.2.4 (3.1.1) for the measuring system.
The requirement on repeatability specified in 5.4.2 (3.1.6) shall be fulfilled.

18.5.2 (B.3.3) Measuring systems for refueling stations not utilizing a sequential control device

1. Tests 4, 5, 6 shall be performed on the complete system at least 3 times consecutively in the same conditions.
Each individual error shall conform to the MPEs specified in 5.2.1 (3.1.1) for the measuring system.
The requirement on repeatability specified in 5.4.2 (3.1.6) shall be fulfilled.
2. Test 7 shall be performed on the complete system at least twice.
Each individual error shall conform to the MPEs specified in 5.2.4 (3.1.3) for the measuring system.
3. If relevant and not already performed on the meter, specific tests (see 17.2.5.7) (B.2.7) are performed.
If testing is applicable each test shall be performed twice.
Each individual error shall conform to the MPEs specified in 5.2.1 (3.1.1) for the measuring system.

18.6 (B.3.4) Specific provisions

When it is the intention that the initial verification of the meter or of the system is to be performed with:

- a) a fluid (instead of the gas or gases which it is intended to measure when in use) or
 - b) only with one gas (in case the system is intended to measure two or more gases when in use)
- specific tests, similar to those referred to in 18.2.3 (3.2.2), shall be performed in order to determine whether a shift and/or reduction of maximum permissible errors is needed and if so to what extent.

In general this determination should involve more than one meter in order to take into account the reproducibility of the type of meter or measuring system.

The provisions in this paragraph shall be implemented in such a way that it may be assumed that the measuring systems in use respect the maximum permissible errors when employing the gas or all the gases they are intended to measure. .

18.7 Execution of initial tests

Prior to the execution of performance tests the initial intrinsic error is to be determined in order to verify compliance with the requirements 5.2 and to establish the reference for all further performance tests. The error curve of the indicated mass (= measurand) shall be established in a reproducible manner

In case of Coriolis meters the measurand includes the density indication.

In case of multiple indicating/printing devices, the indication of all these devices shall be recorded for every value of the measurand.

18.7.1 Overview of the execution of the initial tests

Table 2.8	Overview of the execution of the initial tests
Preconditions:	The EUT shall be switched-on in the operation mode for a time period of at least the warm-up time specified by the manufacturer. Subsequently the EUT is adjusted to indicate a useful reference value which may be to the zero indication as practicable prior to the test.
Condition of the EUT:	Power is to be "on" for the duration of the test. The EUT shall not be readjusted at any time during the test.
Execution	While keeping the reference conditions stable and applying (simulated) flow rate at least five different values of the measurand shall be recorded. Each record shall contain: a) date and time; b) temperature; c) relative humidity; d) measurand value; e) indicated value; f) error value; g) functional performance.
Allowed variations:	All functions shall operate as designed. All error values shall be within the maximum permissible error as specified in 5.2.

18.7.2 Reference conditions (A.3, with additions)

Except for the parameter being tested, the following reference conditions presented in table 2.9 shall be kept by the testing laboratory during the tests:

Table 2.9 Reference conditions		
	Parameter	Value
a)	Ambient temperature	20 °C ± 5 °C
b)	Temperature of the gas (if applicable) ^{(1), (2)}	Rated operating conditions range declared by the manufacturer
c)	Relative humidity	60 % RH ± 15 %
d)	Atmospheric pressure	86 kPa to 106 kPa
e)	Vibration	Negligible ⁽³⁾
f)	DC mains voltage ⁽³⁾	Less than 10 % of the variation specified by the manufacturer of the EUT

f)	AC mains voltage ⁽³⁾	$U_{\text{nom}} \pm 1 \%$
g)	AC mains frequency ⁽³⁾	$f_{\text{nom}} \pm 0,5 \%$ ⁽⁴⁾
i)	Radiated, radio-frequency, electromagnetic fields	$< 0,2 \text{ V/m}$ ⁽⁴⁾
j)	Conducted radio-frequency fields	$< 0,2 \text{ V e.m.f.}$ ⁽⁴⁾
k)	Electrostatic discharge	none
l)	Power frequency magnetic field	$< 1 \text{ A/m}$ ⁽⁴⁾
m)	Bursts (transients) on signal, data and control lines ⁽¹⁾	negligible ⁽⁴⁾
n)	Surges on signal, data and control lines ⁽¹⁾	negligible ⁽⁴⁾
o)	AC mains voltage dips, short interruptions and voltage variations ⁽¹⁾	negligible ⁽⁴⁾
p)	Bursts (transients) on AC and DC mains ⁽¹⁾	negligible ⁽⁴⁾
q)	Ripple on DC mains power ⁽¹⁾	negligible ⁽⁴⁾
r)	Surges on AC and DC mains power ⁽¹⁾	None ⁽⁴⁾
⁽¹⁾ For parts of the meter that are required to be tested with gas ⁽²⁾ Substitute gas or liquids may be used for safety reasons ⁽³⁾ If applicable ⁽⁴⁾ As in a normal laboratory condition these conditions can be expected to be fulfilled without specific measures, it is usually not deemed necessary to measure/monitor these values.		

18.8 Execution of tests under rated operating conditions ("Influence tests") (A.4)

The type of measuring instrument is presumed to comply with the provisions specified in 5.2 to 5.5 of this Recommendation, if it passes the tests specified in the sub clauses of this clause 18.8 confirming that the error of the measuring instrument as a consequence of the influence test parameter does not exceed the maximum permissible error specified in 5.2

When the effect of the application of one influence quantity is being evaluated, for all other influence quantities the ranges as specified in the reference conditions specified in clause 18.7.1 shall be maintained. (A.1)

The sequence of the tests shall start with the test under reference conditions; the further "influence tests" can be carried out in any order chosen.

18.8.1 Overview of influence factor tests

Table 2.10 Overview of influence factor tests	
	Test
18.7.1	Initial test
18.8.2.1	Dry heat
18.8.2.2	Cold
18.8.3	Vibration (random)
18.8.4.1	AC mains voltage variation
18.8.4.2	DC mains voltage variation
18.8.5	Voltage of internal battery

Note: Some influence quantities are likely to have a constant effect on measurement results and not a proportional effect related to the measurand value. The value of the significant fault is related to the measured mass; therefore, in order to be able to compare results obtained in different laboratories, it is necessary to perform a test on a mass corresponding to that delivered in one minute at the maximum flowrate, but not less than a quantity corresponding to the appropriate number of scale intervals specified in Annex C. Some tests, however, may require more than one minute, in which case they shall be carried out in the shortest possible time.

18.8.2 Static temperatures

(Template 13.4.2.2) At the discretion of the testing laboratory, despite the test procedures in brief presented the tests in clauses 18.7 and 18.8.2 may be combined, using the following sequence:

- Reference temperature;
- Specified high temperature;
- Specified low temperature;
- Reference temperature.

Note: Influence of the gas temperature (A.4, note 2)

Test temperature is the ambient temperature and not the temperature of the gas used. It is therefore recommended to use a simulation test method so that the temperature of the gas does not influence the test results.

18.8.2.1 Dry heat (A.4.1)

Applicable standards:	IEC 60068-2-2 [10], IEC 60068-3-1 [13]
Test method:	Exposure to dry heat
Object of the test:	To verify compliance with the provisions in 5.5.2.a (5.1.1) under conditions of high ambient temperature.
Test procedure in brief (*):	<p>The test comprises exposure of the EUT to a temperature (t_{ah}) under "free air" conditions for a 2-hour period after the EUT has reached temperature stability.</p> <p>The EUT shall be tested for at least one flow rate (or simulated flow rate as input signals):</p> <ul style="list-style-type: none">• at the reference temperature of 20 °C following conditioning;• at the temperature (t_{ah}), 2 hours after temperature stabilization;• after recovery of the EUT at the reference temperature of 20 °C.

Test level:	1) Temperature: (t_{ah}) 2) Duration: 2 hours
Number of test cycles:	One cycle
Allowed effects:	During the application of the influence factor: <ul style="list-style-type: none"> • All functions shall operate as designed, and • All errors shall be within the maximum permissible errors.
(*) This test procedure has been presented in condensed form and for information only. It is adapted from the referenced IEC publications. Before conducting the test, the applicable publications should be consulted.	

18.8.2.2 Cold (A.4.2)

Applicable standards:	IEC 60068-2-1 [9], IEC 60068-3-1 [13]
Test method:	Cold
Object of the test:	To verify compliance with the provisions in 5.5.2,b (5.1.1) under conditions of low ambient temperature.
Test procedure in brief (*):	<p>The test comprises the exposure of the EUT to a temperature (t_{al}) under "free air" conditions for a 2-hour period after the EUT has reached temperature stability.</p> <p>The change of temperature shall not exceed 1 °C/min during heating up and cooling down.</p> <p>The EUT shall be tested for at least one flow rate (or simulated flow rate as input signals):</p> <ul style="list-style-type: none"> • at the reference temperature of 20 °C following conditioning; • at the temperature of - 25 °C or - 10 °C, 2 hours after temperature stabilization; • after recovery of the EUT at the reference temperature of 20 °C.
Test level:	1) Temperature: (t_{al}) 2) Duration: 2 hours
Number of test cycles:	One cycle
Allowed effects:	During the application of the influence factor: <ul style="list-style-type: none"> • All functions shall operate as designed, and • All errors shall be within the maximum permissible errors.
(*) This test procedure has been given in condensed form, for information only, and is adapted from the referenced IEC publication. Before conducting the test, the applicable publication should be consulted. This comment also applies to the test procedures hereafter.	

18.8.3 Vibration (random) (A.4.4)

Applicable standard:	IEC 60068-2-64 [12]
Test method:	Exposure to random vibrations
Object of the test:	To verify compliance with the provisions in 5.5.2.d (5.1.1) after been exposed to conditions of random vibrations.
Test procedure in brief (*):	<p>The EUT shall, subsequently be tested in the three, orthogonally axes while mounted on a rigid fixture using its normal mounting means.</p> <p>The EUT shall normally be mounted in such a way that the gravity vector points in the same direction as it would in normal use. Where on basis of the measurement principle the direction of the effect can be assumed negligible, the EUT may be mounted in any position.</p> <p>For the purpose of applying the test the EUT:</p> <ul style="list-style-type: none"> • is to be switched off;

	<ul style="list-style-type: none"> is not to be mounted on a piping system; is not to be installed in any kind of protection case. 		
Test level:	Level index	1	Unit
	Total frequency range	10–150	Hz
	Total RMS level	1.6	$\text{m} \cdot \text{s}^{-2}$
	ASD level 10–20 Hz	0.05	$\text{m}^2 \cdot \text{s}^{-3}$
	ASD level 20–150 Hz	– 3	dB/octave
	Number of axes	3	
	Duration per axis (or a longer period if necessary for carrying out the measurement)	2	min
Allowed variations:	After the application of the influence factor: <ul style="list-style-type: none"> All functions shall operate as designed, and All errors shall be within the maximum permissible errors. 		

18.8.4 Mains power network variation

18.8.4.1 AC mains voltage variation (A.4.10)

(If applicable)

Applicable standards:	IEC/TR3 61000-2-1 [14], IEC 61000-2-2 [15], IEC 61000-4-1 [17]
Test method:	Variation in AC mains power voltage and frequency (single phase).
Object of the test:	To verify compliance with the provisions in 5.5.2,f (5.1.1) under conditions of varying AC mains network voltage and frequency.
Test procedure in brief:	The test comprises the exposure of the EUT to power voltage variations, while the EUT is operating under normal atmospheric conditions.
Test levels:	Mains voltage: upper limit: $U_{\text{nom}} + 10 \%$ lower limit: $U_{\text{nom}} - 15 \%$
Number of test cycles:	One cycle
Allowed effects:	During the application of the influence factor: <ul style="list-style-type: none"> All functions shall operate as designed, and All errors shall be within the maximum permissible errors.

18.8.4.2 DC mains voltage variation (A.4.9)

(If applicable)

Applicable standards:	IEC 60654-2 [16]
Test method:	Variation in DC mains power voltage and frequency (single phase).
Object of the test:	To verify compliance with the provisions in 5.5.2,e (5.1.1) under conditions of varying AC mains power voltage and frequency.
Test procedure in brief:	The test comprises the exposure of the EUT to power voltage variations, while the EUT is operating under normal atmospheric conditions.
Test severities:	The upper limit will be the DC level at which the EUT has been manufactured to automatically detect high-level conditions. The lower limit will be the DC level at which the EUT has been manufactured to automatically detect low-level conditions. The EUT shall comply with the specified maximum permissible errors at voltage levels between the two levels.

Number of test cycles:	One cycle
Allowed effects:	During the application of the influence factor: <ul style="list-style-type: none"> • All functions shall operate as designed, and • All errors shall be within the maximum permissible errors.

18.8.5 Voltage of internal battery (A.4.14)

(If applicable)

Applicable standards:	None
Test method:	Variation in supply voltage.
Object of the test:	To verify compliance with the provisions in 5.5.2,g (5.1.1) under conditions of low battery voltage.
Test procedure in brief:	<p>The test comprises the exposure to the specified condition of the battery(s) for a period sufficient for achieving temperature stability and for performing the required measurements.</p> <p>If an alternative power source (standard power supply with sufficient current capacity) is used in bench testing to simulate the battery, it is important that the internal impedance of the specified type of battery also be simulated. The maximum internal impedance of the battery is to be specified by the manufacturer of the instrument.</p> <p>Test sequence:</p> <p>Stabilize the power supply at a voltage within the defined limits and apply the measurement and/or loading condition. Record the following data:</p> <ol style="list-style-type: none"> date and time; temperature; power supply voltage; functional mode; measurements and/or loading condition; indications (as applicable); errors; functional performance; <p>Reduce the power voltage to the EUT until the equipment clearly ceases to function properly according to the specifications and metrological requirements, and note the following data:</p> <ol style="list-style-type: none"> power supply voltage; indications; errors; other relevant responses of the instrument.
Lower limit of the voltage:	The lowest voltage at which the EUT functions properly according to the specifications.
Number of cycles:	At least one test cycle for each functional mode
Allowed effects:	During the application of the influence factor: <ul style="list-style-type: none"> • All functions shall operate as designed, and • All errors shall be within the maximum permissible errors.

18.9 Applying potential disturbances (A.4)

The type of measuring instrument is presumed to comply with the provisions specified in 5.7 of this Recommendation, if it passes the following tests

These "disturbance tests" can be carried out in any order.

Table 2.11 Overview of further influence quantity tests	
18.9.1	Damp heat, cyclic
18.9.2.1	Radiated, radio frequency electromagnetic fields
18.9.2.2	Induced common mode currents by RF electromagnetic fields
18.9.3	Electrostatic discharge
18.9.4.1	Surges on AC and DC mains power lines
18.9.4.2	Surges on signal, data and control lines
18.9.5	AC mains voltage dips, short interruptions, and voltage variations
18.9.6	Bursts (transients) on AC and DC mains and on signal lines
18.9.7	Voltage dips, short interruptions and voltage variations on DC mains power (New)
18.9.8	Ripple on DC input power (New)

18.9.1 Damp heat, cyclic (condensing) (A.4.3)

Applicable standards:	IEC 60068-2-30 [11]
Test method:	Damp heat, cyclic
Object of the test:	To verify compliance with the provisions in 5.7.2,a (5.1.1) after being exposed to conditions of high humidity combined with cyclic temperature changes.
Test procedure in brief:	<p>The test comprises the exposure of the EUT to cyclic temperature variations between 25 °C and the temperature (t_{ah}), maintaining the relative humidity above 95 % during the temperature changes and during the phases at low temperature, and at 93 % at the upper temperature phases. Condensation should occur on the EUT during the temperature rise.</p> <p>The 24 h cycle comprises:</p> <ol style="list-style-type: none"> 1) a temperature rise during a 3 hours period; 2) maintaining temperature at upper value during a period of 12 hours from the start of the cycle; 3) lowering temperature to the lower value within a period of 3 to 6 hours , the declination (rate of fall) during the first hour and a half being such that the lower value would be reached in a 3 hours period; 4) maintaining temperature at the lower value until the 24 hours cycle is completed. <p>The stabilizing period before and recovery after the cyclic exposure shall be such that the temperature of all parts of the EUT is within 3 °C of its final value. The EUT is to be in switch off mode when the disturbance is applied.</p>
Test severities:	1) Upper temperature: (t_{ah}), 2) Duration: 24 hours
Number of test cycles:	Two cycles
Allowed effect:	After the application of the disturbance and the subsequent recovery, either the difference between each indication before the test and the associated indication after the test shall not exceed the values specified in sub clause 5.6.1 (T.3.12) or the measuring system shall detect and act upon a significant fault, in compliance with 6.10 (5.3.1).

18.9.2 Radio frequency immunity

Instruments that do not contain any active electronic circuits (transistors, IC's, radio tubes), are presumed to comply with the provisions in 5.7.1.a. (Template 6.12.1, a), without being subjected to these tests. This justification shall be mentioned in the test report.

In addition to the information to the IEC test procedures, the following test procedures in brief shall be applied:

18.9.2.1 Radiated, radio frequency, electromagnetic fields (A.4.5)

Applicable standard:	IEC 61000-4-3 [19]; IEC 61000-4-20 [..]		
Test method:	Radiated electromagnetic fields		
Object of the test:	For instruments containing electronics, this test is applied to verify compliance with the provisions in 5.7.1 a (5.1.2) under conditions of radiated electromagnetic fields.		
Test procedure in brief:	The EUT shall be exposed to electromagnetic fields in the frequency range and with field strength amplitude as specified below. while maintaining a field uniformity as defined by the referred standard. Different facilities may be applied to generate the required EM field , however the use of which is limited by the dimensions of the EUT and the frequency range of the facility.		
Test level:		3	Unit
	Frequency range	26 - 3000 ⁽¹⁾	MHz
		80 - 3000 ⁽²⁾	
	Amplitude	10	V/m
	Modulation:	80 % AM, 1 kHz, sine wave	
Allowed effect:	Either the difference between any indication during the test and the indication under reference conditions shall not exceed the values given in T.3.12 or the measuring system shall detect and act upon a significant fault, in compliance with 6.10 (5.3.1).		
Notes:	⁽¹⁾ For EUT lacking any cabling (mains or other input port) as is needed for applying the test specified in sub clause 18.9.2.2 the lower limit of the radiation test shall be 26 MHz, taking into account that the test specified in 18.9.2.2 cannot be applied (refer to Annex F of IEC 61000-4-3 [19]). In all other cases both 18.9.2.1 and 18.9.2.2 apply. ⁽²⁾ IEC 61000-4-3 [19] only specifies test levels above 80 MHz. For frequencies in the lower range the test method for common mode currents in the radio frequency range is applicable (test 18.9.2.2).		

18.9.2.2 Induced common mode currents by RF EM fields (A.4.6)

Applicable standard:	IEC 61000-4-6 [22]
Test method:	Conducted common mode currents generated by RF electromagnetic fields
Object of the test:	To verify compliance with the provisions in 5.7.1,b (5.1.2) while exposed to RF electromagnetic fields.
Test procedure in brief:	Radio frequency EM current, simulating the influence of EM fields shall be coupled or injected into the mains and input ports of the EUT using coupling/decoupling devices as defined in the referred standard.

Test level:	Level index	1	Unit
	Frequency range	0,15 - 80	MHz
	RF amplitude (50 Ω):	10	V (e.m.f.)
	Modulation:	80 % AM, 1 kHz, sine wave	
Allowed effect:	Either the fault value shall not exceed the values presented in sub clause 5.6.1 (T.3.12) or the measuring system shall detect and act upon a significant fault, in compliance with 6.10 (5.3.1).		
Note:	For the frequency range 26 ÷ 80 MHz, the testing laboratory may either carry out the test according to 18.9.2.1 or according to 18.9.2.2. But in case of a dispute, the results according to 18.9.2.2 shall prevail.		

18.9.3 Electrostatic discharge (A.4.7)

Instruments not equipped with any active electronic components (semiconductor circuits), are presumed to comply with the provisions in 5.7.2 b without being subjected to the following test. Such justification shall be recorded in the test report.

In addition to the information to the IEC test procedures, the following test procedures in brief shall be applied:

Applicable standard:	IEC 61000-4-2 [18]		
Test method:	Electrostatic discharge (ESD)		
Object of the test:	To verify compliance with the provisions in 5.7.2,b in case of direct exposure to electrostatic discharges, or to such discharges in the neighbourhood of the EUT		
Test procedure in brief:	<p>An ESD generator shall be used with a performance as defined in the referred standard.</p> <p>Before starting the tests, the performance of the generator shall be verified.</p> <p>At least 10 discharges shall be applied. The time interval between successive discharges shall be at least 10 seconds.</p> <p>For EUT not equipped with a ground terminal, the EUT shall be fully discharged between discharges.</p> <p>Contact discharge is the preferred test method. Air discharges shall be used where contact discharge cannot be applied.</p> <p>Direct application:</p> <p>In the contact discharge mode to be carried out on conductive surfaces, the electrode shall be in contact with the EUT.</p> <p>In the air discharge mode on insulated surfaces, the electrode is approached to the EUT and the discharge occurs by spark.</p> <p>Indirect application:</p> <p>The discharges are applied in the contact mode to coupling planes mounted in the vicinity of the EUT.</p>		
Test level:	Level index	3	Unit
	Test voltage	contact discharge	6
		air discharge	8
Allowed effect:	Either the difference between any indication during the test and the indication under reference conditions shall not exceed the values given in 5.6 (T.3.12) or the measuring system shall detect and act upon a significant fault, in compliance with 6.10 (5.3.1).		
Note:	In this case "level" means: up to and including the specified level (i.e. the test shall also be performed at the specified lower levels in the standard).		

18.9.4 Surges

Instruments that do not contain any active electronic circuits (transistors, IC's, radio tubes), are presumed to comply with the provisions in 5.7.2, c and 5.7.2,d without being subjected to these tests. This justification shall be mentioned in the test report.

In addition to the information to the IEC test procedures, the following test procedures in brief shall be applied:

18.9.4.1 Surges on AC and DC mains power lines (A.4.13)

Applicable standard:	IEC 61000-4-5 [21]		
Test method:	Electrical surges.		
Object of the test:	To verify compliance with the provisions in 5.7.2, c (5.1.1) under conditions where electrical surges are superimposed on the mains voltage.		
Test procedure in brief:	<p>A surge generator shall be used with the performance characteristics as specified the referred standard. The test comprises the exposure to surges for which the rise time, pulse width, peak values of the output voltage/current on high/low impedance load and minimum time interval between two successive pulses are defined in the referred standard.</p> <p>The characteristics of the generator shall be verified before connecting the EUT.</p> <p>On AC mains supply lines at least 3 positive and 3 negative surges shall be applied synchronously with AC supply voltage in angles 0°, 90°, 180° and 270°. On DC power lines, at least 3 positive and 3 negative surges shall be applied. The injection network depends on the lines the surge is coupled into and is defined in the referred standard.</p> <p>The test pulses shall be continuously applied during the measuring time.</p>		
Test level:	Level index (installation class):	3	unit
	Line to line:	1.0	kV
	Line to earth:	2.0	kV
Allowed effect:	After the application of the disturbance and recovery, either the difference between any indication before the test and the indication after the test shall not exceed the values given in 5.6.1 (T.3.12) or the measuring system shall detect and act upon a significant fault, in compliance with 6.10 (5.3.1).		

18.9.4.2 Surges on signal, data and control lines (A.4.8)

Applicable standard:	IEC 61000-4-5 [21]		
Test method:	Electrical surges.		
Object of the test:	To verify compliance with the provisions in 5.1.1 or 5.1.2 under conditions where electrical surges are superimposed on input/output and communication lines.		
Test procedure in brief:	<p>A surge generator shall be used with the performance characteristics as specified the referred standard. The test comprises the exposure to surges for which the rise time, pulse width, peak values of the output voltage/current on high/low impedance load and minimum time interval between two successive pulses are defined in the referred standard.</p> <p>A least 3 positive and 3 negative surges shall be applied. The injection network depends on the lines the surge is coupled into and is defined in the referred standard.</p> <p>The test pulses shall be continuously applied during the measuring time.</p>		

Test level:	Level index (installation class):		3	unit
	Unbalanced lines	Line to line:	1.0	kV
		Line to earth:	2.0 ⁽¹⁾	kV
	Balanced lines	Line to line:	N/A	-
		Line to earth:	2,0	kV
Note:	⁽¹⁾ Normally tested with primary protection			
Allowed effect:	After the application of the disturbance and recovery, either the difference between any indication before the test and the indication after the test shall not exceed the values given in 5.6.1 (T.3.12) or the measuring system shall detect and act upon a significant fault, in compliance with 6.10 (5.3.1).			

18.9.5 AC mains voltage dips and short interruptions (A.4.11)

Instruments that do not contain any active electronic circuits (transistors, IC's, radio tubes), are presumed to comply with the provisions in 5.7.1.e, without being subjected to these tests. This justification shall be mentioned in the test report.

In addition to the information to the IEC test procedures, the following test procedures in brief shall be applied:

Applicable standards:	IEC 61000-4-11 [...], IEC 61000-6-2 [...]						
Test method:	Short-time reductions in mains voltage.						
Object of the test:	To verify compliance with the provisions in 5.1.2 under conditions of short time mains voltage reductions.						
Test procedure in brief:	A test generator suitable to reduce for a defined period of time the amplitude of the AC mains voltage is used. The mains voltage reductions shall be repeated 10 times with an interval of at least 10 seconds.						
Test level:	Level index	3					Unit
	Test	a	b	c	d	e	
	Voltage reduction	0	0	40	70	80	%
	Duration	0,5	1	10/12 ⁽¹⁾	25/30 ⁽¹⁾	250/300 ⁽¹⁾	periods
Allowed effect:	During the application of the disturbance and recovery, either the difference between any indication before the test and the indication during the test shall not exceed the values given in 5.6.1 (T.3.12) or the measuring system shall detect and act upon a significant fault, in compliance with 6.10 (5.3.1).						
Note:	⁽¹⁾ These values are for 50 Hz / 60 Hz respectively						

18.9.6 DC mains voltage dips, short interruptions and voltage variations (new)

Instruments that do not contain any active electronic circuits (transistors, IC's, radio tubes), or that not (neither directly nor indirectly) connected to a DC mains power network, are presumed to comply with the provisions in 5.7.1g, without being subjected to these tests. This justification shall be mentioned in the test report.

In addition to the information to the IEC test procedures, the following test procedures in brief shall be applied:

Applicable standard	IEC 61000-4-29 [.....]		
Test method	Voltage dips, short interruptions and voltage variations on DC mains power.		
Object of the test	To verify compliance with the provisions in 5.7.1,g under conditions of voltage dips, voltage variations and short interruptions on DC mains power		
Test procedure in brief	<p>A test generator as defined in the referred standard shall be used.</p> <p>The voltage dips and short interruptions shall be tested on the EUT, for each selected combination of test level and duration, with a sequence of three dips/interruptions with intervals of 10 s minimum between each test event.</p> <p>The EUT shall be tested for each of the specified voltage variations, three times at 10 s intervals in the most representative operating modes.</p> <p>The disturbances are applied during all the time necessary to perform the test; to that purpose more disturbances than indicated above may be necessary. During tests, the EUT shall be in operation; simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.</p>		
Test level	1		unit
Voltage dips	Test levels	40 and 70	% of the rated voltage
	Duration	0.1	s
Short interruptions ⁽⁴⁾	Test condition	High impedance and/or low impedance	
	Test levels	0	% of the rated voltage
	Duration	0.01	s
Voltage variations	Level index	1 ⁽¹⁾	
	Test level	85 and 120	% of the rated voltage
	Duration	10	s
Note	If the EUT is tested for short interruptions, it is unnecessary to test for other levels of the same duration, unless the immunity of the equipment is detrimentally affected by voltage dips of less than 70% of the rated voltage.		
Allowed variations:	During the application of the disturbance and recovery, either the difference between any indication before the test and the indication during the test shall not exceed the values given in 5.6.1 (T.3.12) or the measuring system shall detect and act upon a significant fault, in compliance with 6.10 (5.3.1).		

18.9.7 Bursts (transients) on AC and DC mains and on signal lines (A.4.12)

Instruments that do not contain any active electronic circuits (transistors, IC's, radio tubes), or that not (neither directly nor indirectly) connected to a mains power, are presumed to comply with the provisions in 5.7.1,c and 5.7.1,d without being subjected to these tests. This justification shall be mentioned in the test report.

In addition to the information to the IEC test procedures, the following test procedures in brief shall be applied:

Applicable standards:	IEC 61000-4-1 [17], IEC 61000-4-4 [20]		
Test method:	Electrical bursts.		
Object of the test:	To verify compliance with the provisions in 5.1.2 under conditions where electrical bursts are superimposed on the mains voltage and if applicable on input/output and communication ports.		
Test procedure in brief:	A burst generator shall be used with the performance characteristics as specified in the referred standard. The test comprises the exposure to bursts of voltage spikes for which the repetition frequency of the impulses and peak values of the output voltage on 50 Ω load are defined in the referred standard. At least 10 positive and 10 negative randomly phased bursts shall be applied. For the coupling of the bursts into the input/output and communication lines, a capacitive coupling clamp as defined in the standard shall be used.		
Level index:	3		unit
Amplitude (peak value):	Supply lines ⁽¹⁾	2	kV
	Signal lines ⁽²⁾	1	kV
Repetition rate:	5		kHz
Allowed variations:	During the application of the disturbance and recovery, either the difference between any indication before the test and the indication during the test shall not exceed the values given in 5.6.1 (T.3.12) or the measuring system shall detect and act upon a significant fault, in compliance with 6.10 (5.3.1).		
<i>Notes:</i>			
⁽¹⁾ Only for instruments powered by AC or DC mains power supply.			
⁽²⁾ I/O signal, data and control ports.			

18.9.8 Ripple on DC mains power (New)

Instruments that do not contain any active electronic circuits (transistors, IC's, radio tubes), or that not (neither directly nor indirectly) connected to a DC mains power network, or instruments connected to battery charger systems incorporating switch mode converters, are presumed to comply with the provisions in 5.7.1,h, without being subjected to this test. This justification shall be mentioned in the test report.

In addition to the information to the IEC test procedures, the following test procedures in brief shall be applied:

Applicable standard	IEC 61000-4-17 [.....]
Test method	Ripple on DC input power port.
Object of the test	To verify compliance with the provisions in 5.7.1,h under conditions of ripple on the low voltage DC mains power.
Test procedure in brief	<p>A test generator as defined in the referred standard shall be used.</p> <p>The test consist subjecting the EUT to ripple voltages such as those generated by rectifier systems and/or auxiliary service battery chargers overlaying on DC power supply sources. The frequency of the ripple is the power frequency. The waveform of the ripple, at the output of the test generator, has a sinusoid-linear character.</p> <p>The test shall be applied for at least 10 min or for the period time necessary to allow a complete verification of the EUT's operating performance.</p> <p>During tests, the EUT shall be in operation; simulated inputs are permitted. Tests shall be performed at a minimum of one flow rate.</p>
Test level	1
Level of the ripple	2 % of the nominal DC voltage ⁽¹⁾
Notes	⁽¹⁾ The test levels are a peak-to-peak voltage expressed as a percentage of the nominal DC voltage.
Allowed variations:	During the application of the disturbance and recovery, either the difference between any indication before the test and the indication during the test shall not exceed the values given in 5.6.1 (T.3.12) or the measuring system shall detect and act upon a significant fault, in compliance with 6.10 (5.3.1).

18.10 Type evaluation report

The type evaluation Report shall comply with Part 3 of this Recommendation.

[Part 3 will be drafted later]

18.11 Testing of modules

18.11.1 Meters or measurement transducers (8.1.5)

18.11.1.1 (8.1.5.1) A type approval may be granted for a complete meter; it may also be granted for the measurement transducer only when this is intended to be connected to different types of calculators.

The examinations and tests shall be carried out on the meter alone or on the measurement transducer using appropriate devices. However, these may be carried out on the whole measuring system when it can be assumed that it will not influence the conclusion concerning the meter or the measurement transducer. The maximum permissible errors applicable to the meter apply in all cases.

Tests are normally carried out on the complete meter, fitted with an indicating device, with all the ancillary devices and with the correction device, if any. However, the meter subject to testing need not be fitted with its ancillary devices when the latter are not likely to influence the accuracy of the meter and when they have been verified separately (for example: electronic printing device). The measurement transducer may also be tested alone provided that the computing and indicating device has been subject to a separate type approval. If this measurement transducer is intended to be connected to a calculator fitted with a correction device, the correction algorithm as described by the manufacturer must be applied to the output signal of the transducer to determine its errors.

- 18.11.1.2 (8.1.5.2) The test program specified in the sub clauses 18.3, 18.8 and 18.9 (Annex B) shall be performed on meters or measurement transducers.

18.11.2 Electronic calculators (including the indicating devices) (8.1.6)

When an electronic calculator is submitted to separate tests, the tests are conducted on the calculator alone, simulating different inputs with appropriate standards.

- 18.11.2.1 (8.1.6.1) Accuracy tests include an accuracy test on the indications of measurement results (mass or price to pay). For this purpose, the error obtained on the indication of the result is calculated considering the true value is the one calculated taking into account the value of the simulated quantities applied to inputs of the calculator and using standard methods for calculation. The maximum permissible errors are those fixed in 6.7.1 (4.8.1) for the mass and only rounded errors for calculation of the price to pay.

- 18.11.2.2 (8.1.6.2) Examinations and tests described in 17.7, 18.8 and 18.9 (8.1.9) shall be performed. In general, the test volume is at least 10 000 scale intervals (see Annex A (C)).

18.11.3 Emergency power supply

Where a test is deemed to be necessary to verify that the measuring system fulfils the requirement specified in 6.8.2, in general the instrument has to be supplied with electric power for a period of at least 12 hours preceding the test. Initially the battery (if provided) may be uncharged.

18.11.4 Ancillary devices providing or memorizing measurements results (8.1.7)

- 18.11.4.2 (8.1.7.1) In case of a separate module evaluation on an ancillary device that provides primary indications is, its indications shall be compared with those provided by an already approved indicating device having the same scale interval. Both mentioned indicating devices shall present exactly the same results.

As far as possible, the necessary conditions for compatibility with other devices of a measuring system are stated in the type approval certificate.

- 18.11.4.2 (8.1.7.2) Specific electronic devices may be evaluated separately when they are used for the transmission of primary indications or other information necessary for the determination of these indications. e.g. a device which compresses information from two or more calculators and transmits it to a single printing device.

When the transmitted information comprises at least one o analog (non- A/D converted) signal, the device shall be tested in conjunction with one of the other modules for which the maximum permissible error is specified in this Recommendation.

When the transmission only concerns the digital information, the above provision may be applied; however, when the inputs and outputs of the device are available, the device may be tested separately, in which case it shall introduce no error or faults

In both cases, the necessary conditions for compatibility with other devices of a measuring system are to be stated in the type approval certificate in the most extensive way.

18.11.3.3 If the ancillary device is a purely digital device which:

- is not required to ensure correct measurement or intended to facilitate the measuring operations, or
- could not in any way affect the measurement, and
- does not include the power supply for the measuring instrument, and
- is equipped with the necessary checking facilities,

then the influence quantity tests do not need to be performed on the hardware of the ancillary device.

18.11.5 Self-service devices

Self service devices are considered to be ancillary devices for which the sub clauses of 18.11.3 are applicable.

[According to the old sub clause 8.1.1 (edition 2007), self service devices may be subject to separate type evaluation, but no details about the tests are given. There further should not be any difference between the tests to be performed on self service devices between OIML R 117-2 and OIML R 139-2. It requires parallel drafting of the secretariats. The sub clause will be completed (if needed) when such a draft becomes available]

18.11.6 Printing devices

Printing devices are considered to be ancillary devices for which the sub clauses of 18.11.3 are applicable.

[Similar 18.11.4 there should not be any difference between the tests to be performed on self service devices between OIML R 117-2 and OIML R 139-2. It requires parallel drafting of the secretariats. The sub clause will be completed (if needed) when such a draft becomes available]

19 Initial verification

19.1 General considerations (New)

(Template 14.1) A new instrument shall undergo initial verification only after type approval. The verification shall be carried out using suitable standards, of adequate accuracy. These standards shall be subjected to a suitable calibration program, assuring their traceability.

Before being taken into service, the initial verification of each individual instrument is intended to verify compliance with the requirements of clauses 4 - 11 **(Template 5 - 10)**.

As a rule, the tests should be carried out on the complete measuring system. If the size or configuration of the measuring system does not render it suitably to being tested as a unit or if only a particular component or device of the instrument is concerned, a test may be carried out on the component or device separately. Such tests may only be performed if a simulated measurement set-up can be achieved that reflects the rated operating conditions of the component or device.

The initial verification can consist of 2 stages; see 19.4.

Note: It is not intended that the instrument or its components should be dismantled for a test.

19.2 Legal status of the instrument submitted for verification (New)

(Template, 14.2) Production measuring systems shall be in conformance with the approved type.

Initial verification of a measuring system includes a procedure to ensure that the individual measuring instruments conform to the approved type. But, notwithstanding this initial verification carried out by the appropriate Legal Authority or under its responsibility, the manufacturer has the full responsibility that the instrument complies with all the applicable requirements according to this Recommendation and other relevant requirements.

19.3 Initial verification in one stage

(8.2.1) Initial verification of a measuring system is carried out in a single stage when the system can be transported without dismantling and when it is verified under conditions representative of the intended conditions of use; in all other cases, it is carried out in two stages.

(8.2.2.2) When initial verification takes place in one stage, all examination and tests in 19.4 to 19.6 (8.2.2.1) shall be performed.

19.4 Initial verification in two stages (8.2.2.1)

When initial verification takes place in two stages, the first stage shall include in principle:

- a) an examination for conformity of the meter, including the associated ancillary devices (conformity with the respective types);
- b) a metrological examination of the meter, including the associated ancillary devices.

The second stage shall include:

- c) an examination for conformity of the measuring system, including the meter and the ancillary and additional devices;
- d) a metrological examination of the measuring system; if possible, this examination is carried out within the limits of operating conditions for the system.

19.5 Examination at initial verification (New)

(Template 14.3.1) Before starting the tests, the following examinations shall be performed (in case of two stages, this shall be done as far as possible in the first stage):

- a) a visual inspection to determine conformance with the approved type and to obtain a general appraisal of its design and construction;
- b) completeness and the correctness of the inscriptions (markings 7);
- c) presence, the completeness, and the language of the documentation meant for the user (8);
- d) compliance of the power supply voltage and frequency at the location of use to with the specifications on the measuring instrument's label;
- e) the practical environmental conditions comply with the relevant inscriptions and documentation;
- f) presentation of the measuring result (5.1);
- g) (if applicable:) the visibility of the indication(s) for the customer is adequate (6.12.1.6);
- h) printing device and type of paper (6.2.9.6);
- i) measuring range (5.3);
- j) resolution (5.1.4);
- k) construction (6.1);
- l) protection against fraud (6.9);
- m) durable storage / printing device (6.3, 6.2.9);
- n) compliance of the software with the approved type (6.11);
- o) sealing devices (9);
- p) provisions for stamping (10)
- q) suitability for testing (11).

19.6 Tests at initial verification

19.6.1 Metrological preconditions for performing tests (new)

The performance tests shall be executed under rated operating conditions **(Template 14.3.2)**.

Before starting the tests, it shall be verified that the measuring system is in switch on mode for the time period which, according to the instructions from the manufacturer is considered to be sufficient to allow thermal stabilization (see 8.2, c).

19.6.2 (3.2.2) Fluid to be used for the tests

When specified by the manufacturer and validated by type evaluation the verification of a measuring system or of a meter intended to measure gas may be carried out with air (or with another fluid). In this case and if necessary, the type approval certificate will provide a more restricted range or a shift for maximum permissible errors, so that compliance to the maximum permissible errors will be fulfilled when measuring gas.

19.6.3 The stages of initial verification (8.2.1)

In each stage the tests shall be performed with the gas or the gases to be measured except when the type approval certificate allows for a different approach as laid down in this Recommendation.

During the first stage at least the measurement transducer is involved; stand-alone or fitted with associated ancillary devices, or possibly included in a sub-system. Tests concerning the first stage may be carried out on a test bench, possibly in the factory of the manufacturer, or on the installed measuring system.

The calculator also is to be involved in first stage. If necessary, the measurement transducer associated with the metering calculator and the operational calculator can be verified separately.

The second stage concerns the measuring system in actual working condition. It is performed on site of installation within actual operating conditions. The second stage may however be carried out on an alternative location chosen by the verification body in case it is possible to transport the measuring system without disassembling and when the tests can be performed under the intended operating conditions for the measuring system.

The initial verification of the electronics part of the measuring systems shall include a procedure for verifying the presence and correct functioning of checking facilities when this conformity was not yet ensured during the type evaluation.

19.6.4 Tests to be performed (B.4)

The testing procedure considered the most ideal is specified in 19.6.4 (B.4.1). However alternatively the practical procedure specified in 19.6.5 (B.4.2) may be applied.

19.6.5 (B.4.1) Theoretical procedure

Note: For the numbers of the tests quoted in the following sub clauses. refer to table 2.5 in 17.2.5.3.

19.6.5.1 (B.4.1.1) The initial verification shall include at least:

- a) for all measuring systems, one test in any one possible condition available in the refueling station, provided that if applicable, the bank pressures shall be such that refueling into the specified test cylinders will cause the activation of all stages of the operation of the sequential control device;
- b) for measuring systems for refueling stations utilizing the sequential control device of a refueling station or systems that incorporate their own sequential control device, one test corresponding as far as possible to test 1 (test 3 may also be considered);

- c) for testing measuring systems that do not incorporate their own sequential control device or that are to be used in refueling stations not using a sequential control device, one test corresponding as far as possible to test 4 (test 6 may also be considered).

The type approval certificate may provide for more the tests to be performed.

19.6.5.2 (B.4.1.2) At least one of the tests should be performed on site in the real refueling station. Test 1 (and/or 3) or test 4 (and /or 6), depending on the case, may be performed in laboratory.

The test conditions shall be such that:

- a) the maximum flow rate available in the particular refueling station for the particular measuring system shall be reached;
- b) the maximum flow rate available in the particular refueling station for the particular measuring system shall be smaller than or equal to the specified maximum permissible flow rate of the measuring system;
- c) the test conditions specified in 17.2.4.2 (B.1.1, B.1.2 and where relevant B.1.4) shall be met;
- d) the sequential control action of the real life system shall be no faster than that used in the laboratory.

19.6.5.3 (B.4.1.3) The tests at initial verification are performed at ambient temperature within rated operating conditions.

Each applicable test is performed twice.

Each individual error shall fulfill the requirement on MPEs specified in 5.2.1 (3.1.1) or 5.2.3 (3.1.2), depending on whether the verification is done on site or in the laboratory.

19.6.6 (B.4.2) Practical procedure

The tests are performed in conditions available in the refueling station, provided that, if applicable, the bank pressures shall be such that refueling into the specified test cylinders will cause the activation of all stages of the operation of the sequential control device.

The test conditions shall be such that the maximum observed flow rate during the tests is no less than 80 % of theoretical maximum flow rate available in the particular refueling station for the particular measuring system.

It shall be checked by design that the theoretical maximum flow rate available in the particular refueling station for the particular measuring system is smaller than or equal to the specified maximum permissible flow rate of the measuring system.

The tests at initial verification are performed at ambient temperature within rated operating conditions.

Tests sufficiently representative of real conditions of use are performed. In general this condition is supposed to be fulfilled with the following sequence:

- a) filling the test receiver from empty to P_v ;
- b) venting the test receiver to a pressure of $0.5 \times P_v$;
- c) re-filling the test receiver from $0.5 \times P_v$ to P_v .

This sequence provides two metrological results to be compared with the MPEs. Each applicable test is performed at least twice and as far as necessary to fulfill the requirement in the first paragraph of this sub clause.

Each individual error shall fulfill the requirement on MPEs specified in 5.2.3 (3.1.2).

The type approval certificate may provide for more information on the tests to be performed.

19.7 Verification marks, seals and document (New)

After successful initial verification, the verification marks and the sealings shall be attached and/or an accompanying document shall be made up according to national regulations.

20 Subsequent verification (8.3, B.5, new)

For countries having a system of mandatory subsequent verification, an interval between verifications not exceeding 5 years is suggested.

The subsequent verification shall be carried out using suitable standards, of adequate accuracy. These standards shall be subjected to a suitable calibration program, assuring their traceability.

As a rule, the tests for subsequent verification shall be carried out on the complete instrument.

20.1 Examination before subsequent verification (Template 15.1.1/16.2)

Subsequent verification shall only be performed if it can be proven that:

- a. the preceding initial verification has been successful and the appropriate verification marks are undamaged;
- b. the period elapsed since the previous verification does not exceed the prescribed period by more than 10 %;
- c. the seals are not broken;
- d. (if applicable:) the proper type of paper is used for printing (risk of fading when exposed to light);
- e. (if applicable:) the visibility of the indication(s) for the customer is adequate;

It shall be checked that the practical environmental conditions comply with the relevant inscriptions and documentation.

20.2 Tests at subsequent verification (B.5) (Template 15.1.2/16.3)

20.2.1 Subsequent verification tests shall be carried out as specified in 19.6.

20.2.2 (8.3.2) The first stage of the verification (of the meter) should only be repeated if the protective marks on the measuring element of the meter have been damaged. This stage may be replaced by a test of the measuring system if the conditions for the first stage of the verification are met and if the measuring system can undergo testing with a delivered gas quantity corresponding to the minimum measured quantity and larger quantities. For the determination of the errors, the maximum flowrate should be reached where possible.

20.2.3 (8.3.3) The ancillary devices shall be considered as having been subjected to the preliminary examination if the protective marks are not damaged. It is sufficient to carry out a reduced number of measurements during the simplified examination of the ancillary devices.

Annex A (C)

MINIMUM TEST QUANTITIES FOR MEASURING SYSTEMS AND DEVICES (Informative)

Provided that the assumption appears valid that the largest contribution to the measurement uncertainty is the rounding of the digital scale interval s , the following may be considered.

In case of a digital scale interval s and determination of errors of a meter it can be demonstrated that the distribution law is triangular and that the standard uncertainty u_s is:

$$u_s = \frac{s}{\sqrt{6}}$$

With a coverage factor equal to 2, the expanded corresponding uncertainty U is:

$$U = 2 u_s$$

The requirement on uncertainty at type approval comparing to the tolerance T is:

$$U \leq \frac{T}{5}$$

That is:

$$\frac{10 \times s}{\sqrt{6}} \leq T$$

A.1 Case of determining the error of a complete measuring system with MPE = $\pm 1,5$ %

$$T = \text{MPE} = 1,5 \times 10^{-2} \times Q$$

The quantity Q is: $Q = n \times s$

Where n is the number of scale intervals. This leads to: $\frac{10 \times s}{\sqrt{6}} \leq 0,015 \times n \times s$

$$\text{That is: } n \geq \frac{1000}{1,5\sqrt{6}} = 272,16$$

Rounded to $n \geq 273$

A.2 Case of determining the error of a meter with MPE = ± 1 %

$$n \geq 272.16 \times 1.5/1 \text{ (ratio of MPE)}$$

$$n \geq 409$$

A.3 Case of determining the repeatability of a meter with a tolerance = $\pm 0,6$ %

$$n \geq 272.16 \times 1.5/0.6$$

$$n \geq 681$$

A.4 Case of determining the repeatability of a measuring system with a tolerance = ± 1 %

$$n \geq 272.16 \times 1.5/1$$

$$n \geq 409$$

A.5 Case of determining the error of a calculator

$$T = 5 \times 10^{-4} \times n \times s$$

$$n \geq 272.16 \times 1.5 \times 10^{-2} / 5 \times 10^{-4}$$

$$n \geq 8165$$

A.6 Case of determining the fault of a MS, calculator or other device

$$T = \text{SF (significant fault)}$$

$$T = \text{MPE} / 10 = 1,5 \times 10^{-3} \times n \times s$$

$$n \geq 2722$$

CONCLUSION

In general and except for testing at the minimum measured quantity, it is proposed to perform tests corresponding to cases 1) to 4) on quantities corresponding to at least 1 000 scale intervals and to perform tests corresponding to cases 5) and 6) on quantities corresponding to 10 000 scale intervals. However in case of necessity (long tests) 5 000 scale intervals are sufficient for case 6).

Annex B (D)

TEST METHODS FOR INFLUENCE QUANTITIES FOR CORIOLIS METERS (Informative)

Although this annex is informative, the guidelines below should be respected in case it is decided to perform tests according to this Annex,.

B.1 Scope (D.1)

This Annex describes how influence quantity tests may be performed for Coriolis meters without the test means specified in 17.6 (Annex B). It concerns the tests on performance with respect to the influence factors and the disturbances, being the tests as specified in the clauses 17.7 and 18.9 (Annex A and tests in B.2.6 of Annex B). All other tests shall be performed according to clause 17.6 (Annex B).

The method described is a substitution static method, and therefore not applicable to accuracy tests required for the gas or substitution fluid. It may be used in those cases where it would not be feasible to perform the tests in a normal situation (for instance in order to avoid having to implement a climatic chamber with normal test means) or where testing means do not exist (for instance testing means fully controlling the temperature of the gas).

It could be adapted to other meters utilizing an electronic sensor/transducer but could necessitate specific considerations. So as it is, its application is limited to Coriolis meters which is today the only well-known technology used in CGF dispensers.

According to the case, these tests are performed on the meter (and not on the complete measuring system) or an appropriate part of the meter (EUT).

~~Additional definition (D.2)~~ **Moved to definitions in clause 31**

B.2 Preliminary considerations (D.3)

Below some aspects of a Coriolis meter are given, that should be taken into account when testing these types of meters according to this annex.

B.2.1 (D.3.1) Low flow cut-off

Coriolis meters in general are equipped with a so-called 'low flow cut-off' feature. This feature will not allow a flowrate below this cut-off value to be measured. Flow rates above this value are registered (without subtraction of the low-flow-cutoff value) as a measurement. During testing, it could be desired to monitor all flowrate indications, even if below the normal low-flow-cut-off value. Therefore, during most performance tests the low-flow-cut-off will need to be set to zero.

For the **tests in application** of this annex, the low-flow-cut-off shall be set to zero.

During normal on-site operation a cut-off value different from zero will need to be applied. In practice generally the optimal value depends on the zero-stability of the meter, the minimum measured quantity of the complete measuring instrument and the **application** itself.

B.2.2 (D.3.2) No-flow conditions

Typically, Coriolis meters are measuring continuously meaning that independent of flow or no-flow conditions the same processes will keep running.

B.2.3 (D.3.3) Temperature measurement

Most Coriolis meters are equipped with an internal temperature sensor for the purpose of correction. In this case, the meter shall be tested with temperature measurement function activated.

B.2.4 (D.3.4) Pressure measurement

Pressure transmitters may be connected to a Coriolis meter for various purposes. When this is the case, the meter shall be tested with pressure measurement function activated.

B.2.5 (D.3.5) Warm up time

All Coriolis meters use electronics, which are partly analogue. Because the characteristics of analogue components are temperature dependent, the device's characteristics are only stable when the electronics have reached a stable temperature. The test shall be performed in conditions representative of the warming time of the meter in the complete measuring system.

B.2.6 (D.3.6) Coriolis sensor

All the currently known coriolis meters basically comprise two sensors: a flow sensor (usually consisting of one or two parallel measurement tubes) and a temperature sensor for correction of the temperature dependent vibration properties of the flow sensor.

The primary measurement signals of a Coriolis meter are:

- a. a time difference value related to the mass flowrate through the flow sensor;
- b. a resonant frequency related to the density of the gas in the flow sensor;
- c. a resistance value related to the temperature of the measurement tube(s).

The measurement tube(s) is/are set into motion (a sinusoidal vibration) by means of an alternating current through one or more so-called drive coils. The movement of the measurement tubes is detected using at least two pick-off coils.

As stated above, usually a temperature sensor is implemented to be able to perform corrections on the flow signals. The vibrating tube will get more or less rigid, as a function of its temperature. As a consequence of this purely mechanical phenomenon, the temperature of the measurement tubes will affect the primary signals for mass and density.

Performance tests, including tests on climatic effects, have to be carried out to verify that measuring instruments (or components thereof) operate within their maximum permissible errors over their rated operating conditions. In the case of Coriolis sensors, two separate effects may occur as a consequence of changing temperatures: A mechanical effect due to the changing vibration properties of the measurement tubes and an effect on the device's electronics. Applying the influence quantity test condition, in this case ambient temperature, will lead to two separate effects on the Coriolis flow sensor. Knowing the original purpose of the performance tests, it may be necessary to observe these two effects separately.

Consequently, even if some parts of the flow sensor may be considered as mechanical components, they need to be subjected to the influence of gas temperature in accordance with 17.2.5.6 (B.2.6) (see B.3.6) (D.4.6). These tests could be performed using a fluid instead of a gas.

B.2.7 (D.3.7) Coriolis transducer

An electronic device which processes the primary analog measurement signals is connected to the sensors. These signals are subsequently processed by a calculating device and sent to outputs such as an indicating device and/or to the (main) calculator. Before the mass flowrate can be determined, two important calculations are performed: a correction calculation based on the temperature of the measurement tubes and the adjustment for the zero-setting of the device (see B.2.8) (D.3.8).

B.2.8 (D.3.8) Zero-setting

The vibrations related behavior of a Coriolis flow sensor is mainly determined by the way of installation, changes in temperature and changes in density. Since a Coriolis meter continuously processes the sensor signals, also during no-flow conditions, any time difference between the signals of the pick-off coils is converted into a mass flow rate. Depending on the properties of the measurement tubes and the stresses on the tubes caused by the installation, also during no-flow conditions a mass flow rate may be observed. The observed mass flow rate during no-flow conditions

is known as the zero-flow. After input of special commands the zero-flow value is determined by the measurement device. This value (which can be either a positive or a negative mass flowrate) is stored and memorized in the Coriolis transducer and subtracted from, or added to the flow rate values determined by the transducer.

B.3 Test methods (D.4)

B.3.1 (D.4.1) Categories of test methods for influence factors at type evaluation

The tests can be divided into three categories:

- a) influence factors tests in 18.8 (Annex A);
- b) disturbances tests in 18.9 (Annex A);
- c) specific gas influence factors tests (17.2.5.6) (B.2.6).

For each of these categories specific information on the test method is given though the same general principle applies.

B.3.2 (D.4.2) General principle

All performance tests applicable to a certain EUT are performed one after another in one series of tests. Before the series of tests, the EUT's performance under reference is determined. For each influence quantity, another test is then performed during the application of the quantity or after its application, according to what is appropriate. In case of an effective influence, a change in flowrate (CF) is observed.

For tests defined in 18.8 and 18.9 (Annex A), a virtual flow signal is created by implementing a systematic offset to obtain a flowrate as close as possible to Q_{\min} . The implementation of this offset must allow the detection of the disturbances effects on the electronic components of the sensors (including the coils). If it is not the case, the method described below for the application of 17.2.5.6 (B.2.6) should be considered.

For application of 17.2.5.6 (B.2.6) the actual signal at zero flow is considered. For this purpose the low-flow-cut-off is set to zero.

For each influence quantity CF is recorded and the relative influence (RCF) is determined using the formula: $RCF (\%) = CF / Q_{\min} \times 100$

Note: For application of B.2.6, RCF decreases with increasing the flowrate and a reference to the minimum flowrate in the formula provides the most severe criterion.

The value of RCF shall be smaller than the applicable MPE or the significant fault, according to the case.

During each measurement, the flowrate of the meter is monitored. One immediately obtains information on the stability of the device. For the measurement under reference conditions, the flowrate should be stable. For some tests under influence quantities, the flowrate may fluctuate. As a general principle, the flowrate taken into consideration should be that corresponding to the maximum change. However it is possible to use a flowrate more representative of the actual accuracy if it can be assumed that the flowrates providing larger changes are purely transitory phenomenon which can not lead to inaccurate measurements.

B.3.3 (D.4.3) Before starting tests

To prevent damage to the flow sensor due to temperature expansion or contraction, except where necessary, do not close the flow sensor by means of rigid blinding flanges.

Before the temperature of the gas is fully stabilized, temperature convection will cause small flows of gas to move up and down through the EUT. On some meters this will appear as a flow indication where none is expected.

B.3.4 (D.4.4) Specific aspects of the test method for influence factors

The object of an influence factor test is to verify that the EUT operates within its maximum permissible errors.

For ambient temperature tests, it should be possible to test the effects on the EUT's electronics separately when the mechanical effect due to changing the temperature of the tube can be eliminated. When one pick-off coil is connected in parallel to both applicable inputs, the mechanical effect of temperature changes is eliminated, whereas an effect on the electronics is still observed.

Where the effect of the influence factor on the mechanical parts of the EUT can be eliminated, the MPEs specified for the calculator in 6.7 (4.8) apply.

Where the effect of the influence factor on the mechanical parts of the EUT cannot be eliminated, the MPEs specified for the meter in 5.2.1 (3.1.1) apply.

B.3.5 (D.4.5) Specific aspects of the test method for disturbances

Where tests are applied which are intended to simulate potential disturbances the fault shall in all cases not exceed the significant fault.

B.3.6 (D.4.6) Specific aspects of the test method for the gas influence factors

The complete flow sensor shall be used in the test; the applicable MPEs are those specified for the meter. The temperature correction shall be active and operating in the same manner than during normal measurements.

If it is not possible to heat or to cool the temperature of the gas inside the flow sensor to the required temperatures, the complete flow sensor may be put in the temperature chamber. The measurements are performed when the temperature inside the flow sensor is stabilized at the temperature limits (T_{\max} and T_{\min}) of the rated operating conditions for the temperature of the gas specified by the manufacturer.

As an alternative these tests may be performed using a liquid instead of a gas.

For the test under the influence of pressure, the flanges closing the flow sensor shall be rigid enough so that the pressure limits (max and min) of the rated operating conditions for the pressure of the gas specified by the manufacturer may be reached.

When it is considered appropriate to tests the meter according to the nature or density of the gas, the reference gas is that specified by the manufacturer.

Annex C: Description of selected validation methods

C.1 Analysis of Documentation and Specification and Validation of the Design (AD)

Application:

Basic procedure, applicable during all software validation assessments.

Description:

The examiner evaluates the functions and features of the measuring instrument using the description in text and graphical representations and decides whether these comply with the requirements of the relevant OIML Recommendation. Metrological requirements as well as software-functional requirements (e.g. fraud protection, protection of adjustment parameters, disallowed functions, communication with other devices, update of software, fault detection, etc.) have to be considered and evaluated. This task may be supported by the Software Evaluation Report Format as presented in OIML D 31 Annex B.

References:

For further details refer to: OIML D 31 sub clause 6.3.2.1

C.2 Validation by Functional Testing of the Metrological Functions (VFTM)

Application:

For validating the correctness of algorithms for calculating the measurement value from raw data, for linearization of a characteristic, compensation of environmental influences, rounding in price calculation, etc.

Description:

Most of the evaluation and test methods described in OIML Recommendations are based on reference measurements under various conditions. Their application is not restricted to a certain technology of the instrument. Although not aimed primarily at validating of the software, the test results can be interpreted as a validation of some parts of the software being in general those metrologically most important ones. If the tests described in the relevant OIML Recommendation cover all the metrologically relevant features of the instrument, the corresponding software parts can be regarded as being validated. In general, no additional software analysis or test has to be applied to validate the metrological features of the measuring instrument.

References:

For further details refer to: OIML D 31 sub clause 6.3.2.2 and the various specific OIML Recommendations.

C.3 Validation by Functional Testing of the Software Functions (VFTSw)

Application:

For validation of e.g. protection of parameters, indication of a software identification, software supported fault detection, configuration of the system (especially of the software environment), etc.

Description:

Required features described in the operating manual, instrument documentation or software documentation is checked in practice. If software controlled and functioning correctly, they are to be regarded as validated without any further software analysis.

References:

For further details refer to: OIML D 31 sub clause 6.3.2.3 and the various specific OIML Recommendations

C.4 Metrological Dataflow Analysis (DFA)

Application:

For analysis of the software design concerning the control of the data flow of measurement values through the data domains being subject to legal control including the examination of the software separation.

Description:

It is the aim of this analysis to find all parts of the software that are involved in the calculation of the measurement values or that may have an impact on it.

References:

For further details refer to: OIML D 31 sub clause 6.3.2.4

C.5 Code Inspection and Walk Through (CIWT)

Application:

Any feature of the software may be validated with this method if enhanced examination intensity is considered necessary.

Description:

The examiner walks through the source code assignment by assignment, evaluating the respective part of the code to determine whether the requirements are fulfilled and whether the program functions and features are in compliance with the documentation.

The examiner may also concentrate on algorithms or functions that he has identified as complex, error-prone, insufficiently documented, etc. and inspect the respective part of the source code by analyzing and checking.

References:

For further details refer to: OIML D 31 sub clause 6.3.2.5

C.6 Software Module Testing (SMT)

Application:

Only if a high level of security and protection against fraud is required. This method is to be applied when routines of a program cannot be examined exclusively on the basis of written information and is appropriate and economically advantageous in validation of dynamic measurement algorithms.

Description:

The software module under test is integrated in a test environment, i.e. a specific test program module that calls the module under test and provides it with all necessary input data. The test program compares the output data from the module under test with the expected reference values.

References:

For further details refer to: OIML D 31 sub clause 6.3.2.6